

**RETURN BIDS TO:  
RETOURNER LES SOUMISSIONS A:**

**Bid Receiving/Réception des soumissions**

Procurement and Contracting Services  
73 Leikin Drive,  
Visitor Center - Building M1  
Mailstop # 15  
Ottawa, ON K1A 0R2

**Attn: Shannon Plunkett 613-843-3798**

**Facsimile Number for Amendments: 613-825-0082**

**AMENDMENT - INVITATION TO TENDER**

**MODIFICATION - APPEL D'OFFRES**

**Tender to: Royal Canadian Mounted Police**

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services and construction listed herein and on any attached sheets at the price(s) set out therefore.

**Soumission aux: Gendarmerie royale du Canada**

Nous offrons par la présente de vendre à Sa Majesté la Reine du chef du Canada, aux conditions énoncées ou incluses par référence dans la présente et aux annexes ci-jointes, les biens, services et construction énumérés ici sur toute feuille ci-annexée, au(x) prix indiqué(s).

**Comments - Commentaries**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du fournisseur/de l'entrepreneur**  
**Facsimile No. - No de télécopieur:**  
**Telephone No. - no de telephone:**

|  |  |
|--|--|
| <b>Title-Sujet:</b><br><br>CONSTRUCTION – Gun Range Renovations, AB Various Locations  |  |
| <b>Solicitation No. - No. de l'invitation</b><br><br>201702170   | <b>Date</b><br><br>2016/09/09                        |
| <b>Client Reference No. - No. De Référence du Client</b><br><br>201702170  | <b>Amendment No. – N° du modification</b><br><br>002 |
| <b>GETS Reference No. - No. de Référence de SEAG</b>   |  |
| <b>Solicitation Closes –L'invitation prend fin</b><br><br><b>at - à</b> 14 :00 ET<br><b>on - le</b> Sept 22, 2016  |  |
| <b>F.O.B. - F.A.B.</b><br>Destination  |  |
| <b>Address Enquiries to: - Adresser toutes questions à:</b><br><br><a href="mailto:dale.rudderham@rcmp-grc.gc.ca">dale.rudderham@rcmp-grc.gc.ca</a>                          |  |
| <b>Telephone No. - No de telephone</b><br><br>613-843-5313   | <b>Fax No. - N° de FAX:</b>                          |
| <b>Destination of Goods, Services, and Construction:</b><br><b>Destinations des biens, services et construction:</b>   |  |
| <b>This document contains a Security Requirement</b>   |  |
| <b>Delivery Required - Livraison exigée:</b>   | <b>Delivery Offered - Livraison proposée</b>         |
| <b>Name and title of person authorized to sign on behalf of Vendor/Firm</b><br><b>Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur</b> |  |

## **Amendment #002**

Amendment #002 of Solicitation 201702170 has been issued to **schedule a site visit, modify the closing date, incorporate Addendum No.002, and respond to Questions – Part 2**

---

### **1. OPTIONAL SITE VISIT**

**There will be another site visit on the following dates and local times. Interested bidders are to meet at the main entrance 10 minutes in advance of the scheduled site visit:**

Location: 4300 55th St, Red Deer, Alberta  
Date: Sept 12th 2016  
Time: 09:00 to 10:30 Local Time

Location: 115 55th St, Edson, Alberta  
Date: Sept 12th 2016  
Time: 14:30 to 16:00 Local Time

Location: 4806 55th St, St Paul, Alberta  
Date: Sept 13th 2016  
Time: 10:00 to 11:30 Local Time

Location: 11140 109th St, Edmonton, Alberta  
Date: Sept 13th 2016  
Time: 14:30 to 16:00 Local Time

### **2. Delete solicitation closing date in its entirety;**

**And replace with the following:**

**Solicitation Closes –L’invitation prend fin**

**at - à 14 :00 ET  
on - le Sept 22, 2016**

### **3. Please find Addendum No.002 attached to Notice of Proposed Procurement 201702170\_adn-02.pdf**

### **4. QUESTIONS AND ANSWERS – PART1**

- Q5. With regards to the Granular Ballistic Trap. Are you looking for OTR (off the road) ballistic rubber media using recycled chunk rubber, free of all fibres (including nylon and steel)?
- A5. *Yes refer to specification section 11 67 23*

Q6. Are recycled tires allowed if that type of recycled granulated rubber is prevalent in most of the rubber trap range fires?

A6. *Yes provided they meet the specifications section 11 67 23*

Q7. Are you looking for the ballistic rubber chunk bullet trap to have a Class-A Fire rating?

A7. *No a class-A fire rating is not required.*

Q8. Are you looking for the ballistic rubber bullet trap system to immobilize lead and minimize hazmat conditions in the shooting range room?

Q8. *Yes, refer to specification section 11 67 23*

**ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED**