



Date

RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Parks Canada National Contracting Services

Parks Canada 30 Victoria Street Gatineau, Quebec, J8X 0B3

AMENDMENT # 2

INVITATION TO TENDER APPEL D'OFFRES

Tender To: Parks Canada Agency

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

Soumission à: l'Agence Parcs Canada


Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente et aux annexes cijointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaires

Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Parks Canada Mailroom 30 Victoria Street Gatineau, Quebec, J8X 0B3



Title-Sujet Cape Spear WW2 Bunker Recap September 19, 2016 Solicitation No. - No. de l'invitation Client Ref. No. - No. de réf du client. 5P300-16-5335 GETS Reference No. - No de reference de SEAG **Solicitation Closes** Time Zone Fuseau horaire -L'invitation prend fin – at - à 02:00 PM **EASTERN DAYLIGHT** TIME (EDT) on - le 2016-09-23 F.O.B. - F.A.B. Plant-Usine: ☐ Destination: ⊠ Other-Autre: Address Inquiries to: - Adresser toute demande de renseignements à : Marko Muradori marko.muradori@pc.gc.ca Telephone No. - No de téléphone Fax No. - No de FAX: (819)-420-9661 **Destination of Goods, Services, and Construction:** Destinations des biens, services et construction: See Herein Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur Telephone No. - No de telephone: __ Facsimile No. - N° de télécopieur: Email - Courriel : Name and title of person authorized to sign on behalf of the Vendor/Firm Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur Title / Titre Name / Nom

Signature







SOLICITATION AMENDMENT # 2

THIS AMENDMENT CONSISTS OF QUESTION AND ANSWERS.

1. QUESTION AND ANSWERS.

Q1 – After taking a look through the tender specifications with regard to the above mentioned project, I see that there are a couple of spots where we would like to request review for alternate approval:

GENERAL NOTES; Bonding Agent and Mortar

SIKATOP 123 PLUS & SIKATOP 123 PLUS EXTENDED = **MEADOW-CRETE FNP** or

MEADOW-CRETE GPS

S109; Concrete Tunnel Cross Section & Details

Waterproofing Membrane = MEL-ROL LM OR MEL-ROL

A1 - We will not be assessing the suitability of alternative materials during this Solicitation. Bidders are to price their bids according to the materials specified in the tender package. After contract award, the successful contractor is invited to submit data sheets for proposed material substations. If the use of the alternative materials is approved by the Departmental Representative, price adjustments will be made if necessary as per General Instruction 15 of the ITT.

Q2 – I wish to get clarification on the waterproofing/damproofing requirements for this project.

The specification section 07 11 13 makes reference to waterproofing protection course and Bituminous damproofing. On the drawings there are references to "waterproof foundation coating". Are these in fact the same item?

• See note 1 below:

The specification section on Bituminous damproofing lists material items for damproofing as well as waterproofing. Where are each item required? I can see no indication on drawings to differentiate between the two.

See note 2 below;

The drawings make reference to "10 mm protection board". The only reference i can find in Specification is for a 2 mm protection board.

• See note 3 below;

After the damproofing/waterproofing membrane is applied is the protection board required for vertical as well as horizontal sections?

See note 4 below;

Is the drainage course required for any horizontal sections or just the vertical sections?

See note 5 below;



A2-

- 1. There is both Waterproofing and Damp proofing
- 2. Damp proofing is only to be used on the replaced ventilation shafts for the magazines and ready rooms (8 total, 600mm x 600mm with various depths) Detail 9 on drawings S108. All other concrete surfaces are to have the noted waterproofing membrane.
- 3. The 2mm reference in the specification for the protection board is incorrect. All protection board to be 10mm
- 4. In general protection board is only required on the horizontal surfaces not the vertical See Detail 7 on S108 for typical arrangement. The only time this is different is a small vertical section on the high wall in front of the magazines See Detail 8 on S108.
- 5. Drainage course to be provided on all sides of the structure including horizontal.

END OF SECTION.

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.