



- NOTES:**
1. ALL CONCRETE, FORMWORK AND REINFORCEMENT TO CONFORM TO MOST RECENT CSA/ASTM STANDARD.
 2. ALL REINFORCEMENT AND PVC SHALL HAVE MINIMUM 6" CONCRETE CLEAR COVER.
 3. STANDARD CONCRETE MIX DESIGN, 30 MPA MINIMUM.
 4. THE ESTIMATED GROSS WEIGHT OF THE BLOCK IS 19,000LBS.

5 T ANCHOR

Project No./No. du projet	Sheet/Fauille	Revision no./La Révision no.
FV-BW	003	
	OF 003	

Project title/Titre du projet	PRINCE RUPERT (FAIRVIEW) HARBOUR CATAMARAN MOORING INSTALLATION
Approved by/Approuvé par	RC
Designed by/Concepté par	TA
Drawn by/Dessiné par	WSSL
PWOSC Project Manager/Administrateur de Projets TRSoc	
PWOSC Architectural and Engineering Resources Manager/Ressources Architecturales et de Directeur d'Ingénierie, TRSoc	
Client/client	
Drawing title/Titre du dessin	