



**RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:**

Regional Manager/Real Property
Contracting/PWGSC
Ontario Region, Tendering Office
12th Floor, 4900 Yonge Street
Toronto, Ontario
M2N 6A6
Ontario

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Regional Manager/Real Property Contracting/PWGSC
Ontario Region, Tendering Office
12th Floor, 4900 Yonge Street
Toronto, Ontario
M2N 6A6
Ontario

Title - Sujet Building CBI B1 Interior Demolition	
Solicitation No. - N° de l'invitation EQ754-171352/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client R.051672.001	Date 2016-09-26
GETS Reference No. - N° de référence de SEAG	
File No. - N° de dossier PWL-6-39081 (003)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2016-10-04	
Time Zone Fuseau horaire Eastern Daylight Saving Time EDT	
F.O.B. - F.A.B.	
Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Dhanna, Sheila	Buyer Id - Id de l'acheteur pw1003
Telephone No. - N° de téléphone (416) 512-5855 ()	FAX No. - N° de FAX (416) 512-5862
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: correctional Services Canada Collins Bay Institution 1455 Bath Road Kingston, ON K7M 4X2	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation

EQ754-171352/A

Amd. No. - N° de la modif.

01

Buyer ID - Id de l'acheteur

pwl003

Client Ref. No. - N° de réf. du client

R.051672.001

File No. - N° du dossier

PWL-6-39081

CCC No./N° CCC - FMS No./N° VME

Questions and Answers:

Q: What are the walls composed of for rooms 101 through 106 on drawing A101 which are being demolished?

A: The walls are composed of a combination of drywall on steel studs and masonry construction. Contractor to price based on worst case.

Q: With reference to the two attached drawings, they show a different wall makeup for the interior terra cotta. Please confirm which is correct? Please advise what material is to replace the interior terra cotta when the temporary access wall area is reinstated.

A: Contractor to price based on original building drawings.

Q: Hours of Work: Can these hours 0730 - 1530 be increased? This only gives us 7.5 hours of onsite work and we would like to increase this to at least 10 hours per day?

A: Yes that work hours are negotiable; however there will be limitations on noise and access to the Sally Port. Approval for increase the work hours is required from CSC after the start-up meeting.

Q: As per drawing S000, please specify "approved rust inhibitive paint". Is there a specific product / supplier?

A: Painting to be as per spec section 05 12 23 item 2.3.

Q: Can contractor tools and consumables be left on site during the duration of our work? Are there restrictions placed on Gas or diesel powered equipment?

A: Contractors can leave their tools consumables on site as long as they are locked in a lock box. There are no restrictions on gas or diesel powered equipment.

Q: Are there any load / weight restriction on the interior floor slab for equipment and or steels?

A: Contractor is responsible to confirm the existing structure can safely support any required equipment.

Q: Will the fence located at the South East corner restricting access to the new construction door be removed?

A: Yes, the fence at South East corner will be removal and replacement and it should be part of this contract.