

SYMBOL LEGEND

- 15A, 120V QUADPLEX RECEPTACLE (WALL MOUNT)
- 15/20A, 120V QUADPLEX RECEPTACLE
- 15A, 120V DUPLEX RECEPTACLE (WALL MOUNT)
- 15A, 120V DUPLEX RECEPTACLE (INTEGRAL TO FURNITURE)
- 15/20A, 120V DUPLEX RECEPTACLE
- VOICE/DATA OUTLET (DUAL WALL MOUNT OUTLET)
- VOICE/DATA OUTLET (DUAL OUTLET) (INTEGRAL TO FURNITURE)
- DATA OUTLET
- USB PORT (INTEGRAL TO ADJACENT RECEPTACLE)
- SERVICE POLE
- SERVICE POLE (SUPPLIED WITH FURNITURE)
- CONNECTRAC A/V/POWER MODULE (4 POWER, 4 DATA, 1 VOICE)
- DIRECT CONNECTION TO MECHANICAL EQUIPMENT
- SPEAKER
- SOUND MASKING SPEAKER
- LIGHT SWITCH
- VACANCY SENSING LIGHT SWITCH c/w WITH 347V POWER PACK
- 0-10V DIMMER c/w WITH 347V POWER PACK
- DIMMER
- CEILING MOUNTED OCCUPANCY SENSOR
- RECESSED LINEAR LIGHTING FIXTURE
- RECESSED DOWNLIGHT
- SUSPENDED LINEAR LIGHTING FIXTURE
- SURFACE MOUNTED LINEAR LIGHTING FIXTURE
- SUSPENDED DECORATIVE FIXTURE
- JUNCTION BOX
- EXISTING RECESSED ELECTRICAL PANEL
- NEW RECESSED ELECTRICAL PANEL
- FLOOR RECEPTACLE
- MOTION DETECTOR
- DOOR CONTACT
- KEYPAD
- SMOKE DETECTOR
- FIRE ALARM SPEAKER
- FIRE ALARM PULL STATION
- WALL VIBRATION SENSOR
- ELECTRIC STRIKE
- MAGNETIC DOOR HOLDER
- CARD READER
- SOUND MASKING POWER HUB
- SOUND MASKING CLASS 2 POWER SUPPLY
- SOUND MASKING NETWORK CONTROL PANEL
- REQUEST TO EXIT DEVICE
- ADDRESSABLE INTERFACE MODULE
- EXISTING WALLS TO BE REMOVED

ANNOTATION LEGEND

- CTP DEVICE TO BE MOUNTED 150mm ABOVE COUNTERTOP
- GFCI GROUND FAULT CIRCUIT INTERRUPTER DEVICES
- AFB ABOVE FINISHED FLOOR
- RR REMOVE AND REINSTALL
- R REMOVE EQUIPMENT AND ALL ASSOCIATED WIRING BACK TO PANEL
- E EXISTING DEVICE (TO REMAIN)
- CLG DEVICE TO BE CEILING MOUNTED
- WS WORKSTATION
- MFD MULTI-FUNCTIONAL DEVICE
- RP REUSE EXISTING OUTLET BOX. REPLACE DEVICE, CIRCUIT AND COVERPLATE WITH NEW.
- RL RELOCATE EXISTING DEVICE
- * INTEGRAL TO FURNITURE
- # QUANTITY OF VOICE/DATA, THESE QUANTITIES ARE FOR SHARED SERVICES CANADA INFORMATION ONLY. CABLING IS NOT IN THIS CONTRACT

NOTES:

1. AREA DESIGNATED AS "NOT IN CONTRACT" ARE TO REMAIN IN OPERATION. CONFIRM CIRCUIT FEEDING EQUIPMENT IN THESE AREAS PRIOR TO DISCONNECTION IN DEMOLITION AREAS AS SOME CIRCUIT SHARING MAY BE POSSIBLE.
2. NOT ALL DEVICES ARE INDICATED ON WALLS BEING REMOVED.
3. ALL DEVICES AND CIRCUITS TO BE REPLACED IN CRISIS ROOM. REUSE EXISTING OUTLET BOXES AND EMT STUBS TO CEILING SPACE WHERE PRACTICAL. REFER TO REVISED ELECTRICAL LAYOUT FOR MORE DETAILS.
4. ALL DEVICES AND CIRCUITS TO BE REPLACED IN MEETING ROOM. REUSE EXISTING OUTLET BOXES AND EMT STUBS TO CEILING SPACE WHERE PRACTICAL. REFER TO REVISED ELECTRICAL LAYOUT FOR MORE DETAILS.
5. REMOVE ALL JUNCTION BOXES AND ASSOCIATED EMT BACK TO SOURCE PANEL.

DEMOLITION AND REMOVALS PLAN - 2ND FLOOR CSC

SCALE: 1:100

0m 1m 2m 3m 4m 5m 6m 7m 8m 9m 10m

1