


DETAIL - CABLE TRAY WALL PENETRATION 1
SCALE : N.T.S.



SYMBOL LEGEND

- 15A, 120V QUADRAPLEX RECEPTACLE (WALL MOUNT)
- 15/20A, 120V QUADRAPLEX RECEPTACLE
- 15A, 120V DUPLEX RECEPTACLE (WALL MOUNT)
- 15A, 120V DUPLEX RECEPTACLE (INTEGRAL TO FURNITURE)
- 15/20A, 120V DUPLEX RECEPTACLE
- VOICE/DATA OUTLET (DUAL WALL MOUNT OUTLET)
- VOICE/DATA OUTLET (DUAL OUTLET) (INTEGRAL TO FURNITURE)
- DATA OUTLET
- USB PORT (INTEGRAL TO ADJACENT RECEPTACLE)
- SERVICE POLE
- SERVICE POLE (SUPPLIED WITH FURNITURE)
- CONNECTRAC A/V/POWER MODULE (4 POWER, 4 DATA, 1 VOICE)
- DIRECT CONNECTION TO MECHANICAL EQUIPMENT
- SPEAKER
- SOUND MASKING SPEAKER
- LIGHT SWITCH
- VACANCY SENSING LIGHT SWITCH c/w 347V POWER PACK
- 0-10V DIMMER c/w 347V POWER PACK
- DIMMER
- CEILING MOUNTED OCCUPANCY SENSOR
- RECESSED LINEAR LIGHTING FIXTURE
- RECESSED DOWNLIGHT
- SUSPENDED LINEAR LIGHTING FIXTURE
- SURFACE MOUNTED LINEAR LIGHTING FIXTURE
- SUSPENDED DECORATIVE FIXTURE
- JUNCTION BOX
- EXISTING RECESSED ELECTRICAL PANEL
- NEW RECESSED ELECTRICAL PANEL
- FLOOR RECEPTACLE
- MOTION DETECTOR
- DOOR CONTACT
- KEYPAD
- SMOKE DETECTOR
- F.A. FIRE ALARM SPEAKER
- FIRE ALARM PULL STATION
- WALL VIBRATION SENSOR
- ELECTRIC STRIKE
- MAGNETIC DOOR HOLDER
- CARD READER
- SOUND MASKING POWER HUB
- SOUND MASKING CLASS 2 POWER SUPPLY
- SOUND MASKING NETWORK CONTROL PANEL
- REQUEST TO EXIT DEVICE
- ADDRESSABLE INTERFACE MODULE
- DEMOUNTABLE PARTITION WALL

ANNOTATION LEGEND

- CTP DEVICE TO BE MOUNTED 150mm ABOVE COUNTERTOP
- GFI GROUND FAULT CIRCUIT INTERRUPTER DEVICES
- AFF ABOVE FINISHED FLOOR
- RR REMOVE AND REINSTALL
- R REMOVE EQUIPMENT AND ALL ASSOCIATED WIRING BACK TO PANEL
- E EXISTING DEVICE (TO REMAIN)
- CLG DEVICE TO BE CEILING MOUNTED
- WS WORKSTATION
- MFD MULTI-FUNCTIONAL DEVICE
- RP REUSE EXISTING OUTLET BOX. REPLACE DEVICE, CIRCUIT AND COVERPLATE WITH NEW.
- RL RELOCATE EXISTING DEVICE
- * INTEGRAL TO FURNITURE
- # QUANTITY OF VOICE/DATA. THESE QUANTITIES ARE FOR SHARED SERVICES CANADA INFORMATION ONLY. CABLING IS NOT IN THIS CONTRACT

CABLE TRAY LAYOUT - 2ND FLOOR CSC

SCALE : 1:100
0m 1m 2m 3m 4m 5m 6m 7m 8m 9m 10m

6



1	ISSUED FOR TENDER	SEP 13 2013
revisions		date

project
CORRECTIONAL SERVICES CANADA 2ND FLOOR FIT-UP

drawing
design

ELECTRICAL CABLE TRAY LAYOUT

designed TML comp

date
drawn ARJ des

date
approved

date
Tender Submission

PWSC Project Manager
Project number no. du projet

R.083937.002

drawing no. no. du dessin

E6