



SYMBOL LEGEND

- 15A, 120V QUADRAPLEX RECEPTACLE (WALL MOUNT)
- 15/20A, 120V QUADRAPLEX RECEPTACLE
- 15A, 120V DUPLEX RECEPTACLE (WALL MOUNT)
- 15/20A, 120V DUPLEX RECEPTACLE (INTEGRAL TO FURNITURE)
- VOICE/DATA OUTLET (DUAL WALL MOUNT OUTLET)
- VOICE/DATA OUTLET (DUAL OUTLET) (INTEGRAL TO FURNITURE)
- DATA OUTLET
- USB PORT (INTEGRAL TO ADJACENT RECEPTACLE)
- SERVICE POLE
- SERVICE POLE (SUPPLIED WITH FURNITURE)
- CONNECTRAC A/V/POWER MODULE (4 POWER, 4 DATA, 1 VOICE)
- DIRECT CONNECTION TO MECHANICAL EQUIPMENT
- SPEAKER
- SOUND MASKING SPEAKER
- LIGHT SWITCH
- VACANCY SENSING LIGHT SWITCH c/w 347V POWER PACK
- 0-10V DIMMER c/w 347V POWER PACK
- DIMMER
- CEILING MOUNTED OCCUPANCY SENSOR
- RECESSED LINEAR LIGHTING FIXTURE
- RECESSED DOWNLIGHT
- SUSPENDED LINEAR LIGHTING FIXTURE
- SURFACE MOUNTED LINEAR LIGHTING FIXTURE
- SUSPENDED DECORATIVE FIXTURE
- JUNCTION BOX
- EXISTING RECESSED ELECTRICAL PANEL
- NEW RECESSED ELECTRICAL PANEL
- FLOOR RECEPTACLE
- MOTION DETECTOR
- DOOR CONTACT
- KEYPAD
- SMOKE DETECTOR
- FIRE ALARM SPEAKER
- FIRE ALARM PULL STATION
- WALL VIBRATION SENSOR
- ELECTRIC STRIKE
- MAGNETIC DOOR HOLDER
- CARD READER
- SOUND MASKING POWER HUB
- SOUND MASKING CLASS 2 POWER SUPPLY
- SOUND MASKING NETWORK CONTROL PANEL
- REQUEST TO EXIT DEVICE
- ADDRESSABLE INTERFACE MODULE
- EXISTING WALLS TO BE REMOVED

ANNOTATION LEGEND

- GTP DEVICE TO BE MOUNTED 150mm ABOVE COUNTERTOP
- GFCI GROUND FAULT CIRCUIT INTERRUPTER DEVICES
- AFF ABOVE FINISHED FLOOR
- RR REMOVE AND REINSTALL
- R REMOVE EQUIPMENT AND ALL ASSOCIATED WIRING BACK TO PANEL
- E EXISTING DEVICE (TO REMAIN)
- CLG DEVICE TO BE CEILING MOUNTED
- WS WORKSTATION
- MFD MULTI-FUNCTIONAL DEVICE
- RP REUSE EXISTING OUTLET BOX, REPLACE DEVICE, CIRCUIT AND COVERPLATE WITH NEW. (LIGHTING: REUSE EXISTING WIRING AND REPLACE LIGHT FIXTURE.)
- RL RELOCATE EXISTING DEVICE
- \* INTEGRAL TO FURNITURE
- # QUANTITY OF VOICE/DATA. THESE QUANTITIES ARE FOR SHARED SERVICES CANADA INFORMATION ONLY. CABLING IS NOT IN THIS CONTRACT

LIGHTING FIXTURE SCHEDULE					
TYPE	DESCRIPTION	MODEL No.	SOURCE	DRIVER	COLOUR TEMP. VOLTAGE
L1	EXISTING 508mm X 1524mm RECESSED TROFFER	N/A	FIXTURES TO BE REMOVED FROM EXISTING CEILING, STORED CAREFULLY, CLEANED AND REINSTALLED IN NEW CEILING WHERE INDICATED		347V
L2	150mm DIA. RECESSED DOWNLIGHT	GOTHAM ICO 40/20 BAR EZ1	2000lm LED ENGINE	0-10V DIMMABLE (1%)	4000K 347V
L3	2440mm SUSPENDED DIRECT/INDIRECT	CORELITE JAYLLUM J3-FL-1L40-1D-347-AC48-T9-B-STD	2991lm LED ENGINE	0-10V DIMMABLE (1%)	4000K 347V
L4	EXISTING 1220mm SURFACE MOUNTED WRAPAROUND	N/A	FIXTURES TO BE REMOVED FROM EXISTING CEILING, STORED CAREFULLY, CLEANED AND REINSTALLED IN NEW CEILING WHERE INDICATED		347V
L5	1220mm SUSPENDED DIRECT/INDIRECT	CORELITE JAYLLUM J3-FL-1L40-1D-347-AC48-T9-4-STD	2991lm LED ENGINE	0-10V DIMMABLE (1%)	4000K 347V
L6	EXISTING 1220mm SURFACE MOUNTED WRAP	N/A	FIXTURES TO BE REMOVED FROM EXISTING CEILING, STORED CAREFULLY, CLEANED AND REINSTALLED IN NEW CEILING WHERE INDICATED		347V
L7	DECORATIVE PENDANT FIXTURE	EUREKA BROADWAY 4211-TF	LED	0-10V DIMMABLE (1%)	4000K 347V
L8	DECORATIVE PENDANT FIXTURE	EUREKA SPIN 4236 LED 22.40	LED	0-10V DIMMABLE (1%)	4000K 347V
L9	DECORATIVE PENDANT FIXTURE	EUREKA OOB 4223-UGL	LED	0-10V DIMMABLE (1%)	4000K 347V
L10	DECORATIVE PENDANT FIXTURE	EUREKA BROADWAY 4211-GIS	LED	0-10V DIMMABLE (1%)	4000K 347V
L11	150mm DIA. RECESSED DOWNLIGHT (WALL WASH)	GOTHAM ICO 40/20 GAR WW	2000lm LED ENGINE	0-10V DIMMABLE (1%)	4000K 347V
L12	200mm DIA. POTLIGHT	TO BE DETERMINED	LED	0-10V DIMMABLE (1%)	4000K 347V
L13	150mm DIA. SURFACE MOUNT DOWNLIGHT	TO BE DETERMINED	LED	N/A	4000K 347V
L14	UNDER CABINET STRIP LIGHT c/w JUMPER CONNECTORS AND SPLICE BOXES	TECH LIGHTING 7000CF-LENGTH AS REQUIRED-9-5-W-LED	LED		3500K 120V
L15	EXISTING PENDANT FIXTURE	N/A	N/A	N/A	N/A
L16	EXISTING 150mm DIA. RECESSED DOWNLIGHT	N/A	N/A	N/A	N/A
L17	EXISTING 150mm DIA. SURFACE MOUNTED DOWNLIGHT	N/A	N/A	N/A	N/A
L18	EXISTING 2440mm X 305mm SURFACE MOUNTED WRAPAROUND	N/A	N/A	N/A	N/A
L19	EXISTING 610mm X 610mm RECESSED TROFFER	N/A	N/A	N/A	N/A
L20	EXISTING 152mm X 700mm SURFACE MOUNTED WRAPAROUND	N/A	N/A	N/A	N/A
EX1	GREEN EDGE-LIT RUNNING MAN PICTOGRAM SELF BATTERY UNIT, RECESSED IN CEILING. ARROWS AS INDICATED.	READY-LITE RDE-1 OR 2-W-F-SD	LED	LED	N/A 347V

EXISTING LIGHTING LAYOUT - 2ND FLOOR CSC 3

Public Works and Government Services Canada

Trouvaux Publics et Services gouvernementaux Canada

**FOWLER BAULD & MITCHELL**  
architecture

Fowler Bauld & Mitchell Ltd.  
PO Box 214, Suite 102  
1600 Steeles Street  
Markham, Ontario L3R 9V7  
Tel: 905 429 4100  
Fax: 905 429 3000  
info@fbm.ca  
www.fbm.ca

**CBCL LIMITED**  
Consulting Engineers

CBCL Proj. No. 163409.00

**PROFESSIONAL ENGINEER**  
CORRECTIONAL SERVICES CANADA 2ND FLOOR FIT-UP

1	ISSUED FOR TENDER	SEP 13 2018
revisions		date
project		project

designed TML  
drawn ARJ  
date  
approved  
date  
Tender  
PWSC Project Manager  
project number  
R.083937.002  
drawing no.  
no. du dessin

E3

E-PRM/GSD-E 544592