

September 26, 2016

ADDENDUM TO BID AND ACCEPTANCE DOCUMENT
FOR
MELFORT RESEARCH FARM
CONTRACT NO. 15 – OFFICE BUILDING EXTERIOR RENOVATIONS
CONTRACT #465-1-9-C14

Addendum No. 1

1. Q&A

Q1 – What type of Windows?

A1 – PVC

Q2 – As there is no window schedule, please clarify the quantity of windows that are awning style?

A2 - Awning style opening on all windows. No openings on door windows.

Q3 – Please clarify glazing: #2 references triple, #5 references safety glass (fire rated)?

A3 – Safety Glass only required for door windows. All other glass is triple pane.

Q4 – What type of insulation and strapping? Is AAFC extending the electrical when removing the siding?

A4 - 2" Styrofoam insulation and strapping will be 1x4. AAFC will extend the electrical boxes.

Q5 – Dark grey vinyl siding, please specify if the siding is standard or premium?

A5 – Standard

Q6 – Any tree removal?

A6 – Contractor to trim trees as needed

Q7 – Is there a laydown area:

A7 – Yes

Q8 – Are there washroom facilities to use?

A8 - Yes

2. There is no change to the September 29, 2016 date of opening tenders.

3. Instructions to Tenderers: The tenderer shall acknowledge receipt of this Addendum #1 in the space provided on the first page of the Tender Form.

Colby Collinge
A/Materiel Manager AAFC
Regina, Saskatchewan