



PANELBOARD DIRECTORY 'BH-P2C' FOR BIG HOUSE									
ITEM	LOAD (kW)	OCP	C	C	ITEM	LOAD (kW)	OCP		
ROOM AB-1 240V REC	1.5	20A, 2P	1	31	ROOM 18 240V REC	1.5	20A, 2P		
	1.5		2	32		1.5			
ROOM AB-1 240V REC	1.5	20A, 2P	3	33	ROOM 16 240V REC	1.5	20A, 2P		
	1.5		4	34		1.5			
ROOM LB-1 240V REC	1.5	20A, 2P	5	35	ROOM 19 240V REC	1.5	20A, 2P		
	1.5		6	36		1.5			
ROOM B-1 240V REC	1.5	20A, 2P	7	37					
	1.5		8	38					
ROOM B-1 240V REC	1.5	20A, 2P	9	39					
	1.5		10	40					
ROOM B-3 240V REC	1.5	20A, 2P	11	41					
	1.5		12	42					
ROOM A-12 240V REC	1.5	20A, 2P	13	43					
	1.5		14	44					
ROOM A-13 240V REC	1.5	20A, 2P	15	45					
	1.5		16	46					
ROOM A-14 240V REC	1.5	20A, 2P	17	47					
	1.5		18	48					
ROOM A-11 240V REC	1.5	20A, 2P	19	49					
	1.5		20	50					
ROOM A-15 240V REC	1.5	20A, 2P	21	51					
	1.5		22	52					
ROOM 13 240V REC	1.5	20A, 2P	23	53					
	1.5		24	54					
ROOM 17 240V REC	1.5	20A, 2P	25	55					
	1.5		26	56					
ROOM 14 240V REC	1.5	20A, 2P	27	57					
	1.5		28	58					
ROOM 15 240V REC	1.5	20A, 2P	29	59					
	1.5		30	60					
					MOUNTING: SURFACE RATING: SEE SINGLE LINE DISTRIBUTION DIAGRAM				

PANELBOARD DIRECTORY 'FL-P2B' FOR FURLOFT									
ITEM	LOAD (kW)	OCP	C	C	ITEM	LOAD (kW)	OCP		
240V HEATER BASEMENT	1.5	20A, 2P	1	31	240V HEATER MAIN FLOOR	1.5	20A, 2P		
	1.5		2	32		1.5			
240V HEATER BASEMENT	1.5	20A, 2P	3	33	240V HEATER MAIN FLOOR	1.5	20A, 2P		
	1.5		4	34		1.5			
240V HEATER BASEMENT	1.5	20A, 2P	5	35					
	1.5		6	36					
240V HEATER BASEMENT	1.5	20A, 2P	7	37					
	1.5		8	38					
240V HEATER BASEMENT	1.5	20A, 2P	9	39					
	1.5		10	40					
240V HEATER BASEMENT	1.5	20A, 2P	11	41					
	1.5		12	42					
240V HEATER MAIN FLOOR	1.5	20A, 2P	13	43					
	1.5		14	44					
240V HEATER MAIN FLOOR	1.5	20A, 2P	15	45					
	1.5		16	46					
240V HEATER MAIN FLOOR	1.5	20A, 2P	17	47					
	1.5		18	48					
240V HEATER MAIN FLOOR	1.5	20A, 2P	19	49					
	1.5		20	50					
240V HEATER MAIN FLOOR	1.5	20A, 2P	21	51					
	1.5		22	52					
240V HEATER MAIN FLOOR	1.5	20A, 2P	23	53					
	1.5		24	54					
240V HEATER MAIN FLOOR	1.5	20A, 2P	25	55					
	1.5		26	56					
240V HEATER MAIN FLOOR	1.5	20A, 2P	27	57					
	1.5		28	58					
240V HEATER MAIN FLOOR	1.5	20A, 2P	29	59					
	1.5		30	60					
					MOUNTING: SURFACE RATING: SEE SINGLE LINE DISTRIBUTION DIAGRAM				

PANELBOARD DIRECTORY 'FL-P2C' FOR FURLOFT									
ITEM	LOAD (kW)	OCP	C	C	ITEM	LOAD (kW)	OCP		
240 HEATER SECOND FLOOR	1.5	20A, 2P	1	31	240 HEATER ATTIC	1.5	20A, 2P		
	1.5		2	32		1.5			
240 HEATER SECOND FLOOR	1.5	20A, 2P	3	33	240 HEATER ATTIC	1.5	20A, 2P		
	1.5		4	34		1.5			
240 HEATER SECOND FLOOR	1.5	20A, 2P	5	35	240 HEATER ATTIC	1.5	20A, 2P		
	1.5		6	36		1.5			
240 HEATER SECOND FLOOR	1.5	20A, 2P	7	37	240 HEATER ATTIC	1.5	20A, 2P		
	1.5		8	38		1.5			
240 HEATER SECOND FLOOR	1.5	20A, 2P	9	39	240 HEATER ATTIC	1.5	20A, 2P		
	1.5		10	40		1.5			
240 HEATER SECOND FLOOR	1.5	20A, 2P	11	41	240 HEATER ATTIC	1.5	20A, 2P		
	1.5		12	42		1.5			
240 HEATER SECOND FLOOR	1.5	20A, 2P	13	43	240 HEATER ATTIC	1.5	20A, 2P		
	1.5		14	44		1.5			
240 HEATER SECOND FLOOR	1.5	20A, 2P	15	45	240 HEATER ATTIC	1.5	20A, 2P		
	1.5		16	46		1.5			
240 HEATER SECOND FLOOR	1.5	20A, 2P	17	47	240 HEATER ATTIC	1.5	20A, 2P		
	1.5		18	48		1.5			
240 HEATER SECOND FLOOR	1.5	20A, 2P	19	49	240 HEATER ATTIC	1.5	20A, 2P		
	1.5		20	50		1.5			
240 HEATER SECOND FLOOR	1.5	20A, 2P	21	51	240 HEATER ATTIC	1.5	20A, 2P		
	1.5		22	52		1.5			
240 HEATER SECOND FLOOR	1.5	20A, 2P	23	53	240 HEATER ATTIC	1.5	20A, 2P		
	1.5		24	54		1.5			
240 HEATER ATTIC	1.5	20A, 2P	25	55	240 HEATER ATTIC	1.5	20A, 2P		
	1.5		26	56		1.5			
240 HEATER ATTIC	1.5	20A, 2P	27	57					
	1.5		28	58					
240 HEATER ATTIC	1.5	20A, 2P	29	59					
	1.5		30	60					
					MOUNTING: SURFACE RATING: SEE SINGLE LINE DISTRIBUTION DIAGRAM				



Public Works and
Government Services
Canada



Travaux publics et
Services gouvernementaux
Canada

REAL PROPERTY SERVICES

Western Region


SERVICES IMMOBILIERS

Région de l'ouest

REPUBLIC ARCHITECTURE INC


374 Donald Street, First Floor
Winnipeg, MB R3B 2Z1
T 204 989 0102
F 204 989 0094
www.republicarchitecture.ca

HDK




HDK CONSULTING
INCORPORATED
2633 Portage Avenue
Winnipeg, Manitoba
Canada, R3J 0P7
T: 204.818.0390
T: 204.818.0388
www.hdkconsulting.com
info@hdkconsulting.com

Mechanical|Electrical|Communications|Security Engineering



PROVINCE OF MANITOBA
H.A.
CEA CANAS
Member
22882
SEP 12/17
REGISTERED PROFESSIONAL ENGINEER



Certificate of Authorization

HDK Consulting Incorporated

No. 5539 Date: 04/30/2017

0	ISSUED FOR TENDER	Sept. 12, 18
Revision/ Révision	Description/Description	Date/Date
Client/client		
<div>Public Works and Government Services Canada</div> <div>100 - 167 Lombard Avenue Winnipeg, Manitoba</div>		
Project title/Titre du projet Lower Fort Garry (LFG) National Historic Site, Manitoba		
HERITAGE BUILDING RECAPITALIZATION		
Approved by/Approuve par HCC		
Designed by/Concept par BC		
Drawn by/Dessine par RD		
PWGSC Project Manager/Administrateur de Projets TPSCG CHRISTINA KOVACS		
PWGSC, Architectural and Engineering Resources Manager/ Ressources Architectural et de Directeur d'ingénierie, TPSCG		
Client/client PARKS CANADA		
Drawing title/Titre du dessin		
PANELBOARD DIRECTORY-2		
Project No./No. du projet R.075212.001	Sheet/Feuille E24 OF 24	Revision no./ La Révision no. 0

