




GATE VALVE BOX DETAIL
N.T.S.




BUILDING SERVICES BURY DETAIL
N.T.S.




CONCRETE THRUST BLOCKS DETAIL
N.T.S.
FOR HORIZONTAL BENDS, TEES & DEAD END MAIN.



TAPPING SLEEVE AND VALVE DETAIL
N.T.S.



CONCRETE THRUST BLOCKS DETAIL
N.T.S.
FOR VERTICAL BENDS



MINIMUM DIMENSION WATER PRESSURE UP TO 1030 KPa

SIZE OF BENDS	A	B	C	D	E
100mm (Ø)	875mm (Ø)	225mm (Ø)	875mm (Ø)	800mm (Ø)	875mm (Ø)
150mm (Ø)	1275mm (Ø)	330mm (Ø)	1275mm (Ø)	1125mm (Ø)	1275mm (Ø)
200mm (Ø)	1675mm (Ø)	435mm (Ø)	1675mm (Ø)	1525mm (Ø)	1675mm (Ø)
250mm (Ø)	2075mm (Ø)	540mm (Ø)	2075mm (Ø)	1925mm (Ø)	2075mm (Ø)
300mm (Ø)	2475mm (Ø)	645mm (Ø)	2475mm (Ø)	2325mm (Ø)	2475mm (Ø)
350mm (Ø)	2875mm (Ø)	750mm (Ø)	2875mm (Ø)	2725mm (Ø)	2875mm (Ø)

CONCRETE THRUST BLOCKS DETAIL
N.T.S.
FOR VERTICAL BENDS

RADIANT CEILING PANEL SCHEDULE

TAG	ELECTRICAL REQUIREMENTS [V]	PANEL PHYSICAL DIMENSION				WEIGHT [lbs]	WATTS
		WIDTH [mm]	WIDTH [in]	LENGTH [mm]	LENGTH [ft]		
RP-1	208	458	18	2439	8	20.4	260
RP-2	208	458	18	2134	7	17.9	230
RP-3	208	458	18	915	3	7.7	95
RP-4	208	458	18	1829	6	15.3	195

DIFFUSER AND GRILLE SCHEDULE

TAG	MODEL	COLOUR	NOTES	REMARKS
S-1	AA GRILLES AAG 100	CONFIRM W/ ARCHITECTURAL	1, 2	REFER TO DRAWING FOR FACE SIZE
R-1	AA GRILLES AAG 100	CONFIRM W/ ARCHITECTURAL	1, 2	REFER TO DRAWING FOR FACE SIZE
E-1	EH PRICE SERIES 735Z LOUVERED FACE	CONFIRM W/ ARCHITECTURAL	3	REFER TO DRAWING FOR FACE SIZE

NOTES:

- APPROVED MANUFACTURERS: WATERLOO, JPR SERVICES
- PLASTER-IN GRILLES
- SURFACE MOUNT
- APPROVED MANUFACTURERS: WATERLOO AND JPR SERVICES

HEAT RECOVERY VENTILATORS

TAG	HRV-1
SERVICE	Big House
SUPPLY FAN	
AIR FLOW RATE (L/s / CFM)	378 / 800
E.S.P. (Pa / in.WC)	311 / 1.25
MOTOR SIZE (kW / HP)	0.75 / 1.00
RETURN FAN	
AIR FLOW RATE (L/s / CFM)	378 / 800
E.S.P. (Pa / in.WC)	311 / 1.25
MOTOR SIZE (kW / HP)	0.75 / 1.00
HEAT EXCHANGER (WINTER)	
SENSIBLE EFFECTIVENESS (%)	75.0
FILTERS SECTION	
FILTER DEPTH / TYPE	2", MERV 8
PHYSICAL DATA	
WEIGHT (kg / lbs)	154 / 340
LENGTH (m / ft.)	13.11 / 43
WIDTH (m / ft.)	10.52 / 35
HEIGHT (m / ft.)	15.24 / 50
ELECTRICAL DATA	
VOLTAGE/PHASE	120 V / 1 Ph

NOTES:

- Provide preheat and post heat electric coils. Refer to Electrical.
- Coordinate structural support with structural drawings.
- Indoor unit shall be condensate free with no mounting restrictions.
- Provide central controller c/w humidistat. Initiate high speed based on humidistat (>60% RH).
- Provide differential enthalpy control for free cooling.
- Unit shall operate without the need for condensate drainage.

FAN SCHEDULE

TAG	MANUFACTURER	TYPE	MODEL	RPM	AIR FLOW RATE (L/s) (CFM)	E.S.P. (Pa) (in.WC)	MOTOR (W) (HP)	SONES	ACCESSORIES
SF-1	GREENHECK	I	CSP-A900	950	396 / 840	31 / 0.13	335 / FRAC	1.4	TS, MD

FAN TYPES:

C	CENTRIFUGAL TA	R	ROOF TUBE AXIAL	I	IN-LINE	CE	CEILING EXHAUST	CU	CENTRIFUGAL UP BLAST
W	WALL	MF	MIXED FLOW	P	PROPELLER	CF	CEILING FAN		

ABBREVIATIONS:

BG	BELT GUARD	MT	MANUAL RESET TIMER	SD	SCROLL DRAIN
AS	ADJUSTABLE SHEAVES	NSW	NON-SPARKING WHEEL	FC	FACTORY CURB
SC	SOLID STATE SPEED CONTROL	SH	SPRING HANGERS	BS	BIRDSCREEN
IG	INLET GRILLE	VP	VIBRATION PADS	MC	MOUNTING COLLAR
BD	BACKDRAFT DAMPER	SM	SPRING MOUNT	WH	WEATHERPROOF HOUSING
F	FILTER	WC	WALL CAP	RC	ROOF CAP
E	EPOXY COATING	DS	DISCONNECT SWITCH	AD	ACCESS DOOR
IH	INLET HOOD	MDW	MOTION DETECTOR, WALL MTD.	GN	GOOSENECK
TS	THERMOSTAT	MD	MOTORIZED DAMPERS		

NOTES:

- INSTALL ALL UNITS ON VIBRATION ISOLATORS
- PROVIDE INSULATED MOTORIZED DAMPER FOR INTAKE AND RELIEF. PROVIDE NON INSULATED MOTORIZED DAMPPER ON RETURN
- PROVIDE CONTROLS FOR A MIXED AIR SYSTEM TO MAINTAIN ROOM TEMPERATURE. MIN MIXED AIR SUPPLY TEMP SHALL BE 13 C. IF ROOM TEMPERATURE DROPS BELOW 5C, CLOSE INTAKE AND RELIEF DAMPER AND GO TO FULL RECIRCULATION (LOW TEMP CUT OFF).
- APPROVED MANUFACTURERS: LOREN COOK, TWIN CITIES

DOMESTIC WATER HEATING EQUIPMENT SCHEDULE (Based on A. O. Smith)

TAG	LOCATION	MODEL	ENERGY TYPE	HEATER DATA				STORAGE VOLUME (Litres) (U.S. Gal.)	ASME	PHYSICAL CHARACTERISTICS				NOTES				
				Kw INPUT (kW)	TEMP. RISE (C)	RECOVERY (L/hr) (GPH)				WEIGHT (kg) (lbs.)	DIAMETER (mm) (in.)	HEIGHT (mm) (in.)						
DWH-1	BIG HOUSE	DRE-62-6	ELECTRIC	6.0	50.0	90	390	103	189	50	N/A	120	265	552	21.8	1,137	44.8	3 ELEMENTS

NOTES:

- APPROVED MANUFACTURER: RHEEM, BRADFORD WHITE
- PROVIDE RELIEF VALVE PIPED TO DRAIN.

PLUMBING FIXTURE SCHEDULE

LOCATION	PRODUCTS	DESCRIPTION	ACCESSORIES	SAN	VENT	TRAP	HW	CW	RO	APPROVED MANUFACTURER
FD-1	Drainage Specialty	Watts FD-100-C-7-L5-1 Floor Drain	Watts #-LS-1.	50	-	50	-	-	-	Wade, JR Smith
FD-2	Drainage Specialty	Watts FD-320-4-7 Floor Drain	Watts #-4.	75	-	75	-	-	-	Wade, JR Smith
HD-1	Drainage Specialty	Watts FD-100-DD Hub Drain	Watts #-4.	75	-	75	-	-	-	Wade, JR Smith
LAV-1	Wall hung basin	American Standard #0954.004EC/0059.020EC 'Murro with Everclean' Basin.	Single handle faucet, 1.9 LPM (0.5 GPM) pressure compensating non-aerating spray outlet, lever handle, adjustable hot limit safety stop. Open grid drain. Chrome plated polished brass faucet supplies. Provide p-trap. Basin carrier.	32	32	32	13	13	-	Toto, Kohler
LAV-2	Wall hung basin	DXV Solutions #D20125100 Basin	Single handle Faucet, chrome plated, center hole only, brass, washerless ceramic disc valve cartridges, 5.7 LPM (1.5 GPM) aerator outlet, 120 mm (4-3/4") projection reach, metal lever handle, less pop-up drain, integral hot water limit stop Open grid drain. Chrome plated polished brass faucet supplies. Provide p-trap. Fixture carrier	32	32	32	13	13	-	Toto, Kohler
WC-1	Toilet	American Standard #2467.016.020, 'Cadet Right Height Pressure-Assisted Elongated', 419 mm high Toilet, white Vitreous china, Floor Mounted, 6 L (1.6 US Gal) per flush, two (2) piece, elongated bowl.	Centoc #820STS.001, extra heavy duty Toilet Seat, white solid plastic, open front with cover. Provide all metal construction Toilet Supply. Provide Floor Flange, (same material as the connecting pipe drain), with all brass bolts and with rubber gasket.	75	-	-	-	13	-	Toto, Kohler
WC-2	Toilet	American Standard #2467.016.020, 'Cadet Right Height Pressure-Assisted Elongated', 419 mm high Toilet, white Vitreous china, Floor Mounted, 6 L (1.6 US Gal) per flush, two (2) piece, elongated bowl.	Centoc #500STS.001, extra heavy duty Toilet Seat, white solid plastic, open front with cover. Provide all metal construction Toilet Supply. Provide Floor Flange, (same material as the connecting pipe drain), with all brass bolts and with rubber gasket.	75	-	-	-	13	-	Toto, Kohler

Public Works and Government Services Canada / Travaux publics et Services gouvernementaux Canada

REAL PROPERTY SERVICES
Western Region
SERVICES IMMOBILIERS
Région de l'ouest

REPUBLIC ARCHITECTURE INC
374 Donald Street, First Floor
Winnipeg, MB R3B 2J2
T 204 989 0102
F 204 989 0094
www.republicarchitecture.ca

HDK CONSULTING INCORPORATED
2633 Portage Avenue
Winnipeg, Manitoba
Canada, R3J 0P7
T: 204.818.0390
T: 204.818.0388
www.hdkconsulting.com
info@hdkconsulting.com
Mechanical | Electrical | Communications | Security Engineering

PROVINCE OF MANITOBA
REGISTERED PROFESSIONAL ENGINEER
DA HO
Member
25705

APEGM
Certificate of Authorization
HDK Consulting Incorporated
No. 5539 Date: 04/30/2017

Public Works and Government Services Canada
100 - 167 Lombard Avenue
Winnipeg, Manitoba

Project title/Titre du projet
Lower Fort Garry (LFG) National Historic Site, Manitoba

HERITAGE BUILDING RECAPITALIZATION

Approved by/Approve par
DH

Designed by/Concept par
PA

Drawn by/Dessine par
IS

PWGSC Project Manager/Administrateur de Projets TFSGC
CK

PWGSC, Architectural and Engineering Resources Manager / Ressources Architectural et de Directeur d'ingénierie, TFSGC

Client/client
PARKS CANADA

Drawing title/Titre du dessin
MECHANICAL SCHEDULES

Project No./No. du projet
R.075212.001

Sheet/Feuille
M10

Revision no./La Révision no.
0

OF 14

15080 M10 - Schedules