


1 STOCKADE EXISTING PARTIAL SINGLE LINE DISTRIBUTION DIAGRAM
E16 NTS

NOTES:

- ELECTRICAL ITEMS SHOWN DASHED ARE EXISTING AND SHALL REMAIN OR BE RELOCATED AS NOTED. ITEMS MARKED WITH (D) SHALL BE DISCONNECTED AND REMOVED.
- ALL DEVICES IN RENOVATED AREAS THAT MUST BE ALTERED TO HAVE ASSOCIATED WIRE AND CONDUIT EXTENDED, RE-ROUTED AND RE-WIRED TO SUIT NEW INSTALLATION. CONFIRM EXISTING ON SITE.
- ELECTRICAL CONTRACTOR TO COORDINATE ALL POWER SHUTDOWNS WITH DEPARTMENTAL REPRESENTATIVE. PROVIDE MINIMUM 48 HOUR NOTICE PRIOR TO ANY SHUTDOWNS. COORDINATE ALL WORK TO MINIMIZE SERVICE INTERRUPTIONS. ALLOW FOR EVENING AND WEEKEND WORK AS REQUIRED.
- ALL SERVICE REPLACEMENT WORK TO BE FULL SATISFACTION OF THE UTILITY AND DEPARTMENTAL REPRESENTATIVE.
- COORDINATE SERVICE UPGRADE WORK WITH UTILITY.



0	ISSUED FOR TENDER	Sept. 12, 18
Revision/ Révision	Description/Description	Date/Date

Client/client

Public Works and Government Services Canada

100 - 167 Lombard Avenue
Winnipeg, Manitoba

Project title/Titre du projet
Lower Fort Garry (LFG)
National Historic Site, Manitoba

HERITAGE BUILDING
RECAPITALIZATION

Approved by/Approuvé par
HCC

Designed by/Concept par
PL

Drawn by/Dessiné par
RD

PWGS Project Manager/Administrateur de Projets TPSC
CHRISTINA KOVACS

PWGS Architectural and Engineering Resources Manager/
Ressources Architectural et de Directeur d'ingénierie, TPSC

Client/client
PARKS CANADA

Drawing title/Titre du dessin

STOCKADE EXISTING PARTIAL
SINGLE LINE DISTRIBUTION DIAGRAM

Project No./No. du projet	Sheet/Feuille	Revision no./La Révision no.
R.075212.001	E16 OF 24	0