



1 FUR LOFT-BASEMENT FIRE PROTECTION LAYOUT
M8.1 1:50



2 FUR LOFT-MAIN LEVEL FIRE PROTECTION LAYOUT
M8.1 1:50

- GENERAL NOTES:**
- DO NOT SCALE THIS DRAWING. CONTRACTOR SHALL VERIFY ALL DIMENSIONS PRIOR TO INSTALLATION AND REPORT ANY DISCREPANCY TO THE DEPARTMENTAL REPRESENTATIVE.
 - CONFORM TO SPECIFICATIONS AND MANUFACTURER GUIDES FOR MATERIALS AND UNITS' INSTALLATION DETAILS.
 - SPRINKLER LAYOUT SHALL BE USED FOR PRICING ONLY. PIPING MATERIALS AND APPEARANCE SHALL BE APPROVED BY PARKS CANADA. FINAL PIPING AND LAYOUT SHALL BE CONFIRMED WITH PARKS CANADA.
 - COORDINATE SPRINKLER LOCATION WITH OTHER DISCIPLINE.
 - PROVIDE SPRINKLER PROTECTION ALL THROUGH OUT THE BUILDING AS PER LATEST EDITION OF NFPA 13 AND THE AUTHORITIES HAVING JURISDICTION.
 - NEW OPENINGS IN STONE MUST BE DONE W/ HAND TOOLS ONLY. REFER TO SECTION 04 03 43 - HISTORIC STONE REMOVAL. ALTERNATIVE METHODS MUST BE APPROVED BY DEPARTMENTAL REPRESENTATIVE.
- DRAWING KEYNOTES:**
- NEW 150mm \varnothing FIRE PROTECTION WATER SERVICE UP FROM BELOW C/W FROST BOX.
 - NEW DOUBLE CHECK VALVE BACKFLOW PREVENTER. PIPE DRAIN INDIRECTLY TO HUB DRAIN PROVIDED BY DIVISION 22.
 - PROVIDE NORMALLY CLOSED VALVE AND CONNECT TO FIRE DEPARTMENT CONNECTION LINE UPSTREAM OF THE CHECK VALVE FOR FULL FORWARD FLOW TEST OF BACKFLOW PREVENTER.
 - NEW DRY PIPE VALVE C/W TRIM AND CONTROL VALVE WITH TAMPER SWITCH. DIVISION 26 TO PROVIDE WIRING TO PRESSURE SWITCHES AND AIR SUPERVISORY SWITCH.
 - NEW SKID-MOUNTED NITROGEN GENERATOR INTEGRATED WITH OIL-LESS AIR COMPRESSOR C/W AIR TANK, NITROGEN TANK, VALVE AND APPURTENANCES. PIPE TO DRY PIPE SPRINKLER SYSTEM ZONE WITH AIR MAINTENANCE DEVICE. PROVIDE 50mm THICK HOUSEKEEPING CONCRETE PAD. COORDINATE WIRING REQUIREMENTS WITH DIVISION 26.
 - DRY PIPE SPRINKLER MAIN UP TO MAIN FLOOR.
 - NEW INCOMING 150mm \varnothing DOMESTIC/FIRE PROTECTION WATER SERVICE.
 - 100mm \varnothing FIRE DEPARTMENT STORZ CONNECTION.
 - DRY PIPE SPRINKLER MAIN UP FROM BASEMENT.
 - DRY PIPE SPRINKLER MAIN UP TO SECOND FLOOR.
 - RUN DRY PIPE SPRINKLER MAIN TO U/S OF JOIST.
 - PIPE NIPPLE UP BETWEEN JOIST.
 - PROVIDE LOW TEMPERATURE ALARM CONNECTED TO INTRUSION ALARM SYSTEM.
 - OFFSET BRANCHLINE DOWN TO U/S OF JOIST.
 - SPRINKLER BRANCHLINE IN CEILING SPACE.
 - BASEMENT FLOOR DRY PIPE SPRINKLER SYSTEM ZONE TO BE LIGHT HAZARD OCCUPANCY CLASSIFICATION.
 - MAIN FLOOR DRY PIPE SPRINKLER SYSTEM ZONE TO BE LIGHT HAZARD OCCUPANCY CLASSIFICATION.
 - PIPE NEW 100 \varnothing HUB DRAIN TO EXISTING SUITABLE SANITARY DRAIN. PROVIDE TRENCHING TO RUN NEW DRAIN BY DIVISION 22. CONTRACTOR TO CONFIRM EXACT LOCATION ON SITE PRIOR TO INSTALLATION.
 - NEW 10 LBS. ABC TYPE FIRE EXTINGUISHER. TYPICAL. COORDINATE TYPE OF INSTALLATION WITH ARCHITECTURAL.
 - PENDENT TYPE SPRINKLER HEAD C/W WIRE GUARD. COORDINATE PIPE ROUTING ON SITE.



3 DRY PIPE SPRINKLER SYSTEM ZONE VALVE SCHEMATIC
M8.1 NTS

Public Works and Government Services Canada
Travaux publics et Services gouvernementaux Canada

REAL PROPERTY SERVICES
Western Region
SERVICES IMMOBILIERS
Région de l'ouest

REPUBLIC ARCHITECTURE INC.
374 Donald Street, First Floor
Winnipeg, MB R3B 2J2
T 204 989 0102
F 204 989 0094
www.republicarchitecture.ca

HDK CONSULTING INCORPORATED
2633 Portage Avenue
Winnipeg, Manitoba
Canada, R3J 0P7
T: 204.818.0390
T: 204.818.0388
www.hdkconsulting.com
info@hdkconsulting.com
Mechanical | Electrical | Communications | Security Engineering

PROVINCE OF MANITOBA
DA HO
Member
25705
REGISTERED PROFESSIONAL ENGINEER

APEGM
Certificate of Authorization
HDK Consulting Incorporated
No. 5539 Date: 04/30/2017

| | | |
|---|--|--|
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| 0 | ISSUED FOR TENDER | Sep. 12, 18 |
| Revision/ | Description/Description | Date/Date |
| Revision | | |
| Client/client | | |
| Public Works and Government Services Canada | | |
| 100 - 167 Lombard Avenue Winnipeg, Manitoba | | |
| Project title/Titre du projet Lower Fort Garry (LFG) National Historic Site, Manitoba | | |
| HERITAGE BUILDING RECAPITALIZATION | | |
| Approved by/Approuvé par DH | | |
| Designed by/Concept par PA | | |
| Drawn by/Dessiné par IS | | |
| PWGSC Project Manager/Administrateur de Projets TPSCG CHRISTINA KOVACS | | |
| PWGSC, Architectural and Engineering Resources Manager/ Ressources Architectural et de Directeur d'ingénierie, TPSCG | | |
| Client/client PARKS CANADA | | |
| Drawing title/Titre du dessin FUR LOFT - BASEMENT AND MAIN LEVEL FIRE PROTECTION LAYOUT | | |
| Project No./No. du projet R.075212.001 | Sheet/ Feuille M8.1 OF 13 | Revision no./ La Révision no. 0 |