

September 27, 2016

ADDENDUM TO BID AND ACCEPTANCE DOCUMENT
FOR
MELFORT RESEARCH FARM
CONTRACT NO. 15 – OFFICE BUILDING EXTERIOR RENOVATIONS
CONTRACT #465-1-9-C14

Addendum No. 2

Q1 - What type of siding is the existing siding? Is there any chance that this could be an Abestos product?

A1 - Siding will be removed by AAFC. It does contain asbestos.

Q2 - For the window install are vinyl inserts into the existing framing acceptable?

A2 - No. We would like windows and frames

Q3 - Are all wooden exposed frames and trims to be clad in aluminum?

A3 – Exposed frames and trim to be painted white

1. There is no change to the September 29, 2016 date of opening tenders.
2. Instructions to Tenderers: The tenderer shall acknowledge receipt of this Addendum #2 in the space provided on the first page of the Tender Form.

Colby Collinge
A/Materiel Manager AAFC
Regina, Saskatchewan