

**Part 1 GENERAL**

**1.1 REFERENCES**

- .1 Canadian Standards Association (CSA International)
  - .1 CSA C22.1-15, Canadian Electrical Code, Part 1, 23rd Edition.

**1.2 ACTION AND INFORMATIONAL SUBMITTALS**

- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
  - .1 Provide manufacturer's printed product literature, specifications and datasheet and include product characteristics, performance criteria, physical size, finish and limitations.
- .3 Provide shop drawings: in accordance with Section 01 33 00 - Submittal Procedures.
  - .1 Provide drawings stamped and signed by professional engineer registered or licensed in Province of Newfoundland and Labrador, Canada.

**1.3 DELIVERY, STORAGE AND HANDLING**

- .1 Waste Management and Disposal:
  - .1 Separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

**Part 2 PRODUCTS**

**2.1 JUNCTION AND PULL BOXES**

- .1 Construction:welded steel enclosure.
- .2 Covers Flush Mounted: 25 mm minimum extension all around.
- .3 Covers Surface Mounted: screw-on flat turned edge covers.

**Part 3 EXECUTION**

**3.1 JUNCTION, PULL BOXES AND CABINETS INSTALLATION**

- .1 Install pull boxes in inconspicuous but accessible locations.
- .2 Only main junction and pull boxes are indicated. Install additional pull boxes as required by CSA C22.1.

### **3.2 IDENTIFICATION**

- .1 Equipment Identification: to Section 26 05 00- Common Work Results for Electrical .

**END OF SECTION**