



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des
soumissions/Travaux publics et Services
gouvernementaux Canada
The Cambridge Building
3 Queen Street/3, rue Queen
Charlottetown
Prince Edward Island
C1A 4A2

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

All enquiries are to be submitted in writing to the Contracting Officer, Janine Donovan: Email - janine.donovan@pwgsc.gc.ca or Fax No. (902) 566-7514.

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Public Works and Government Services Canada
The Cambridge Building
3 Queen Street/3 rue, Queen
PO Box 1268/CP 1268
Charlottetown
Prince Ed
C1A 4A2

Title - Sujet Phase 2- Wood Island Ferry	
Solicitation No. - N° de l'invitation ED001-171447/A	Amendment No. - N° modif. 003
Client Reference No. - N° de référence du client R.071322.001	Date 2016-09-30
GETS Reference No. - N° de référence de SEAG PW-\$PWC-021-3963	
File No. - N° de dossier PWC-6-39096 (021)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2016-10-06	Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Donovan, Janine E.	Buyer Id - Id de l'acheteur pwc021
Telephone No. - N° de téléphone (506) 636-5347 ()	FAX No. - N° de FAX (902) 566-7514
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation

ED001-171447/A

Client Ref. No. - N° de réf. du client

R.071322.001

Amd. No. - N° de la modif.

003

File No. - N° du dossier

PWB-6-39096

Buyer ID - Id de l'acheteur

pwc021

CCC No./N° CCC - FMS No./N° VME

This Solicitation Amendment No. Three (3) is raised to include the following addendum no. 3.

The following addendum to the tender documents is effective immediately. This addendum shall form part of the contract documents.

All other terms and conditions remain the same.

Addendum 3.

1. QUESTION AND ANSWER

- Q1. Nelson Studs: What elevations do the Nelson studs go to? Should they be placed in the proposed pattern to harbor bottom or just 2 rows at the top of the existing Steel Sheet Piling?
- A1. Elevations for the steel nelson stud is a 1600mm grid from the harbour bottom up noted on Drawing S10 Detail 2/S09.

2. SPECIFICATION

Section 01 10 00, Paragraph 1.3.1:

REMOVE, "This project is to be completed by October 28, 2017." and **REPLACE WITH** "This project is to be completed by December 31, 2017."