



**Royal Canadian Mounted Police  
Gendarmerie royale du Canada**

**RETURN BIDS TO:  
RETOURNER LES SOUMISSIONS A:  
Bid Receiving/Réception des  
soumissions**

RCMP / GRC  
NWR Procurement & Contracting Services  
**c/o Commissionaires, D Division**  
1091 Portage Avenue  
Winnipeg, MB R3C 3K2

**SOLICITATION AMENDMENT  
MODIFICATION DE L'INVITATION**

**Proposal to: Royal Canadian Mounted Police**

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services and construction listed herein and on any attached sheets at the price(s) set out therefor.

**Proposition aux: Gendarmerie royale du Canada**

Nous offrons par la présente de vendre à Sa Majesté la Reine du chef du Canada, aux conditions énoncées ou incluses par référence dans la présente et aux annexes ci-jointes, les biens, services et construction énumérés ici sur toute feuille ci-annexée, au(x) prix indiqué(s).

**Comments – Commentaries**

**Vendor/Firm Name and Address  
Raison sociale et adresse du fournisseur/de  
l'entrepreneur**

**Telephone No. - no de téléphone:**

<b>Title-Sujet:</b> Building Envelope Upgrades in Fisher Branch, MB	
<b>Solicitation No. - No. de l'invitation</b> M5000-16-6761/A	<b>Date</b> 05 October 2016
Amendment No. – No modif : <b>003</b>	
<b>Solicitation Closes -L'invitation prend fin</b> at - à 2:00 PM Central Daylight Savings Time on - le 06 October 2016	
<b>F.O.B. - F.A.B.</b> Plant - Usine:                      Destination:√                      Other-Autre:	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Cathi Johannson, Senior Procurement Officer <a href="mailto:cathi.johannson@rcmp-grc.gc.ca">cathi.johannson@rcmp-grc.gc.ca</a>	
<b>Telephone No. - No de téléphone</b> 204-984-1836	<b>Fax No. - N° de FAX:</b> 204-984-4253
<b>Destination of Goods, Services, and Construction: Destinations des biens, services et construction:</b> Royal Canadian Mounted Police Fisher Branch RCMP Living Quarters As detailed herein Fisher Branch, MB R0C 0Z0	
<b>This document DOES contain a Personnel Security Requirement</b>	
<b>Delivery Required - Livraison exigée:</b> 03 February 2017	<b>Delivery Offered - Livraison proposée</b>
<b>Name and title of person authorized to sign on behalf of Vendor/Firm Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur</b>	
_____	
Name /Nom	Title/Titre
_____	
Signature /Signature	Date/Jour
(Please sign and return cover page with bid proposal./ Signez s'il vous plaît et la page de couverture de retour avec la proposition d'offre.)	



This Amendment is raised to respond to the following questions as submitted to the Contracting Authority:

**Question 1:**

The thickness of the PVC window Spec calls for 38mm, PVC windows are 35mm. Is this the absolute requirement or will slight deviation be acceptable?

**Response:**

A triple pane unit has an outside dimension of 1-3/8" (34.925mm). 35mm is acceptable.

**Question 2:**

Line on page 100 "**.8 Overall coefficient of heat transfer (U-factor): 0.68 W/(m<sup>2</sup>.K).**", I've been informed that this is not obtainable.

**Response:**

SHGC should read 0.68 and the U-Factor should read 0.24. According to the Basis of Design, a triple pane, argon filled unit will have a center of glass U-Value of 0.29 and an SHGC of 0.70.