



TENDER AMENDMENT

RETURN BIDS TO:

Parks Canada Agency
635 – 8 Avenue S.W., Suite 1300
Calgary, AB T2P 3M3
Bid Fax: (403) 292-4475

The referenced document is hereby amended: unless otherwise indicated, all other terms and conditions of the contract remain the same.

Issuing Office:

Parks Canada Agency
635 – 8 Avenue S.W., Suite 1300
Calgary, AB T2P 3M3

MODIFICATION D'APPEL D'OFFRES

RETOURNER LES SOUMISSIONS À :

Agence Parcs Canada
635 – 8 Avenue S.O., pièce 1300,
Calgary, AB T2P 3M3
N° de télécopieur pour soumissions : (403) 292-4475

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Bureau de distribution :

Agence Parcs Canada
635 – 8 Avenue S.O., pièce 1300
Calgary (AB) T2P 3M3

Title: Lens Snowshed Lighting Rehabilitation, Trans-Canada Highway, Glacier National Park		
Solicitation No.: / N° de l'invitation : 5P420-16-5226/A	Amendment No.: / N° de modification de l'invitation : 002	Date: October 7, 2016 Date : 7 octobre 2016
GETS Reference No.: / N° de référence de SEAG : PW-16-00748529		
Solicitation Closes: / L'invitation prend fin :		
At: 02:00 PM	On: October 12, 2016	Time Zone: Mountain Daylight Time (MDT)
À : 14h00	Le : 12 octobre 2016	Fuseau horaire : Heure avancée des Rocheuses (HAR)
Address Inquiries to: / Adresser toute demande de renseignements à : Nicole Levesque-Welch		
Telephone No.: / N° de téléphone : (403) 292-4691	Fax No.: / N° de télécopieur : (403) 292-4475	Email Address: / Courriel : nicole.levesque-welch@pc.gc.ca
TO BE COMPLETED BY THE BIDDER (type or print)		
Vendor/Firm Name – Nom du fournisseur/de l'entrepreneur		
Address - Adresse		
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur		
Title - Titre		
Signature		Date



AMENDMENT 002

This amendment is being raised to respond to questions submitted in response to solicitation 5P420-16-5226/A:

A. QUESTIONS AND ANSWERS

Q1. Drawing G2002R1 detail 1 and 2 Notes Conductors to be 3#6 and 3#8 respectively yet all other drawings and note indicate a 3 phase 4 wire system to be installed. Please clarify as to the correct number of wires?

A1. The conductor specifications on this drawing should read 4 No. 6 + 1 No. 8 BOND, and 4 No. 8 + 1 No. 10 BOND for details 1 and 2 respectively and will be reflected in the IFC Drawings.

All other terms and conditions remain the same.