

Clarification – ITT 201603038 - Exterior Lighting Upgrade - Phase 2 (Granville Island)

Clarification to Drawings and Specifications

1. Proponents are expected to remove and re-install bird netting inside the parkades in the course of the work. Include price for this in the tender. **CARE Pest Control** is the only sub-contractor approved for this portion of the work; please contact jim@carepest.com, 604-432-9422.
2. Please note that the drawings for the Phuzion fixture show the remote fixture but the “R” designation is missing. The correct model number should have the “R” as it designates a remote driver fixture, no other mounts will be accepted.