

Wharf Reconstruction
Seal Cove White Bay, NL

Page 1
2016-06-15

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

.1 Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

.1 Section Includes:
1. Moulded Case Circuit Breakers.

1.3 PRODUCT DATA

.1 Submit product data in accordance with Section 01 33 00 - Submittal Procedures.

.2 Include time-current characteristic curves for breakers with ampacity of 300 Amp and over with interrupting capacity of 10,000 A symmetrical (rms) and over at system voltage.

PART 2 - PRODUCTS

2.1 BREAKERS GENERAL

.1 Bolt-on moulded case circuit breaker: quick- make, quick-break type, for manual and automatic operation with temperature compensation for 40°C ambient.

.2 Common-trip breakers: with single handle for multi-pole applications.

.3 Magnetic instantaneous trip elements in circuit breakers to operate only when value of current reaches setting. Trip settings on breakers with adjustable trips to range from 3-8 times current rating.

.4 Circuit breakers with interchangeable trips as indicated.

.5 Interrupting capacity to be 18,000 Amps symmetrical (rms).

Wharf Reconstruction
Seal Cove White Bay, NL

Page 2
2016-06-15

2.2 THERMAL MAGNETIC
BREAKERS DESIGN A

.1 Moulded case circuit breaker to operate automatically by means of thermal and magnetic tripping devices to provide inverse time current tripping and instantaneous tripping for short circuit protection.

PART 3 - EXECUTION

3.1 INSTALLATION

.1 Install circuit breakers as indicated.