


GENERAL NOTES:


1. ALL WORK TO BE IN ACCORDANCE WITH THE LATEST REQUIREMENTS OF: THE NATIONAL BUILDING CODE OF CANADA, LATEST EDITION; CANADIAN ELECTRICAL CODE, CURRENT EDITION; ANY OTHER AUTHORITIES HAVING JURISDICTION.
2. ALL EXISTING ELECTRICAL EQUIPMENT REMOVED TO BE TURNED OVER TO OWNER. IF OWNER REFUSES THEN CONTRACTOR TO REMOVE FROM SITE AND DISPOSE.
3. CONTRACTOR TO PROVIDE ALL CUTTING, PATCHING AND PAINTING TO MATCH EXISTING. SEE SPECIFICATION FOR DETAILS. COORDINATE ON SITE.
4. CONTRACTOR MUST VERIFY ALL DIMENSIONS AND CONDITIONS ON SITE BEFORE PROCEEDING WITH ANY PORTION OF THIS WORK. DO NOT SCALE FROM DRAWINGS. CONTRACTOR TO ASSESS WORK AREA IN ADVANCE WITH OWNER REPRESENTATIVE FOR COORDINATION OF RELATED DAILY WORK SCHEDULES AND PARKING.
5. CONTRACTOR SHALL BE RESPONSIBLE FOR CLEAN UP AND DISPOSALS OF WORK AREA ON A DAILY BASIS. AFTER EACH WORKING SHIFT WORK AREA TO BE CLEANED AND FREE OF DEBRIS.
6. LABEL ALL EQUIPMENT WITH LAMACOID TAGS AS PER SPECIFICATION.
7. ALL WIRING TO BE INSTALLED IN CONDUIT AS INDICATED.
8. ACCESS TO FACILITY TO BE COORDINATED WITH OWNER REPRESENTATIVE.

ELECTRICAL LEGEND

- (B) LED LIGHTING FIXTURE. TO BE LITHONIA #TWP-20C-T3M-120-PE C/W PHOTOCELL OR APPROVED EQUAL. SEE SPEC.
- (A) LED LIGHTING FIXTURE. TO BE LITHONIA #VAPLED-4000LM-PCL-MD-120-35K OR APPROVED EQUAL. SEE SPEC.
- \$ SINGLE POLE TOGGLE SWITCH. 15 AMP, 120 VOLT, YELLOW, MARINE GRADE C/W PVC MARINE GRADE COVERPLATE. SEE SPEC. FOR MORE INFORMATION. MOUNT 1200mm ABOVE FINISHED FLOOR.
- (T) LINE VOLTAGE THERMOSTAT RATED 240 VOLT, 4500 WATTS, DPST, WHITE. MOUNT 1200mm AFF.
- SURFACE MOUNTED PANELBOARD
- ⚡ LIGHT POLE AND FIXTURES. SEE DETAIL ON DRAWING E3.
- (E) ELECTRICAL PEDESTAL. SEE DETAILS ON DRAWING E4.
- WP (D) DUPLEX U-GROUND RECEPTACLE. 120 VOLT, 15 AMP, MARINE GRADE. YELLOW & C/W PVC MARINE GRADE COVERPLATE. WALL MOUNT 400mm ABOVE FINISHED FLOOR. "WP" INDICATES WEATHERPROOF GASKET AND COVERPLATE.
- ⬜ TYPE DISCOUNT
- ⬜ ELECTRIC HEATER. SEE SPECIFICATION.
- JIB CRANE




SMALL CRAFT HARBOURS




NOTES:

1. DO NOT SCALE FROM DRAWING.
2. CONTRACTOR MUST VERIFY ALL DIMENSIONS AND CONDITIONS ON SITE PRIOR TO PROCEEDING WITH ANY PORTION OF THIS WORK.

Permit



Stamp



0	ISSUED FOR TENDER	SEPT.26 2016
A	ISSUED FOR REVIEW	JUNE.19 2016
revisions		date

project project
**WHARF
RECONSTRUCTION**
**SEAL COVE
WHITE BAY, NL**

drawing dessin
**NEW SITE PLAN AND
LEGEND**

designed K.N. conçu
date MAY 2016
drawn D.R. dessiné
date MAY 2016
approved approuvé
date
Tender Paul Curran Soumission
PWGSC Project Manager Administrateur de projets TPSGC
project number no. du projet
705642
drawing no. no. du dessin
E1