



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des
soumissions/Travaux publics et Services
gouvernementaux Canada
The Cambridge Building
3 Queen Street/3, rue Queen
Charlottetown
Prince Edward Island
C1A 4A2

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

All enquiries are to be submitted in writing to the Contracting Authority, Crystal Bysterveldt, either by facsimile or by e-mail at:
crystal.bysterveldt@pwgsc.gc.ca.

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Public Works and Government Services Canada
The Cambridge Building
3 Queen Street/3 rue, Queen
PO Box 1268/CP 1268
Charlottetown
Prince Ed
C1A 4A2

| | |
|---|---|
| Title - Sujet Wharf Construction-Machons Point,PE | |
| Solicitation No. - N° de l'invitation ED001-171688/A | Amendment No. - N° modif. 001 |
| Client Reference No. - N° de référence du client R.077232.001 | Date 2016-10-18 |
| GETS Reference No. - N° de référence de SEAG PW-\$PWC-024-3978 | |
| File No. - N° de dossier PWC-6-39119 (024) | CCC No./N° CCC - FMS No./N° VME |
| Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2016-10-21 | Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT |
| F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/> | |
| Address Enquiries to: - Adresser toutes questions à: Bysterveldt, Crystal | Buyer Id - Id de l'acheteur pwc024 |
| Telephone No. - N° de téléphone (902) 940-7122 () | FAX No. - N° de FAX (902) 566-7514 |
| Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: | |

Instructions: See Herein

Instructions: Voir aux présentes

| | |
|--|--|
| Delivery Required - Livraison exigée | Delivery Offered - Livraison proposée |
| Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur | |
| Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur | |
| Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie) | |
| Signature | Date |

THE FOLLOWING CHANGES IN THE TENDER DOCUMENTS ARE EFFECTIVE IMMEDIATELY. THIS ADDENDUM WILL FORM PART OF THE CONTRACT DOCUMENTS.

THIS ADDENDUM IS RAISED TO PROVIDE THE FOLLOWING ANSWERS TO QUESTIONS PROVIDED BY BIDDERS.

1. QUESTION

Can you please advise if the Tie Rods in Section 05 50 00 are to be galvanized or black steel.

ANSWER

The tie rods are not galvanized.

DRAWINGS

Drawing 1 of 7, Existing Conditions, Removals and Site Plan

Change the limits of removal of Pier 401 in accordance with the attached Sketch SK1 below.

