



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving - PWGSC / Réception des soumissions
- TPSGC

11 Laurier St./11 rue Laurier

Place du Portage, Phase III

Core 0B2 / Noyau 0B2

Gatineau, Québec K1A 0S5

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

THIS DOCUMENT CONTAINS A SECURITY
REQUIREMENT / DOCUMENT CONTIENT DES
EXIGENCES RELATIVES À LA SÉCURITÉ

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Construction Services Division/Division des services de
construction

11 Laurier St./11 Rue Laurier

3C2, Place du Portage

Phase III

Gatineau, Québec K1A 0S5

| | |
|--|--|
| Title - Sujet Build. Conv. Tunney's Pasture | |
| Solicitation No. - N° de l'invitation EP635-170974/A | Amendment No. - N° modif. 003 |
| Client Reference No. - N° de référence du client 20170974 | Date 2016-10-18 |
| GETS Reference No. - N° de référence de SEAG PW-\$\$\$FG-267-71570 | |
| File No. - N° de dossier fg267.EP635-170974 | CCC No./N° CCC - FMS No./N° VME |
| Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2016-10-26 | Time Zone Fuseau horaire Eastern Daylight Saving Time EDT |
| F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/> | |
| Address Enquiries to: - Adresser toutes questions à: Hoffman, Amanda | Buyer Id - Id de l'acheteur fg267 |
| Telephone No. - N° de téléphone (873) 469-4930 () | FAX No. - N° de FAX () - |
| Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: | |

Instructions: See Herein

Instructions: Voir aux présentes

| | |
|--|--|
| Delivery Required - Livraison exigée | Delivery Offered - Livraison proposée |
| Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur | |
| Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur | |
| Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie) | |
| Signature | Date |

| | | |
|---|--|---|
| Solicitation No. - N° de l'invitation EP635-170974/A | Amd. No. - N° de la modif 003 | Buyer ID - Id de l'acheteur FG 267 |
| Client Ref. No. - N° de réf. du client 20170974 | File No. - N° du dossier FG267 EP635-170974/A | Project No. - N° du projet R.082113.001 & R.082112.001 |

Amendment 003 is raised to issue Addendum 002 attached hereto.

ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME.

| | | |
|---|--|---|
| Solicitation No. - N° de l'invitation EP635-170974/A | Amd. No. - N° de la modif 003 | Buyer ID - Id de l'acheteur FG 267 |
| Client Ref. No. - N° de réf. du client 20170974 | File No. - N° du dossier FG267 EP635-170974/A | Project No. - N° du projet R.082113.001 & R.082112.001 |

ADDENDUM NO. 002 (4 pages)

The following changes in the bid documents are effective immediately. This addendum will form part of the contract documents.

DRAWINGS

1 DRAWING M-RC-101 – BASEMENT PLAN NEW ETS EQUIPMENT AND PIPING LAYOUT

.1 **DELETE** drawing:

Revision 0 – Issue for Tender – 16/05/09

And **REPLACE** with:

Revision 1 – Issue for Addendum 002 – 16/10/14

2 DRAWING M-RC-104 – RISER PIPING LAYOUT AND DETAILS

.1 Detail 6.0 – Typical Floor Level Pipe Chase: **DELETE** note:

“MAIL CONVEYOR ACCESS DOORS AND OPENINGS SHALL HAVE NEW FIRE RATED ACCESS DOORS AND OPENINGS SHALL BE COVERED WITH NEW FIRE RATED DRYWALL ON EACH LEVEL, FIRE RATING TO BE 1 ½ HOUR.”

and **REPLACE** with

“ACCESS TO MAIL CONVEYOR SHAFT THROUGH ACCESS DOOR IN CONCRETE WALL OF WASHROOM STALL. APPROXIMATE DIMENSIONS OF ACCESS DOOR: 600 x 600. CONTRACTOR TO CONFIRM DIMENSIONS ON SITE. REPLACE EXISTING ACCESS DOOR WITH NEW FIRE RATED ACCESS DOOR, FIRE RATING TO BE 1 ½ HOUR. MAIL CONVEYOR OPENINGS IN CONCRETE BLOCK WALL SEPARATING SHAFT FROM ADJACENT MAIL ROOM SHALL BE COVERED WITH NEW FIRE RATED DRYWALL ASSEMBLY ON EACH LEVEL, FIRE RATING TO BE 1 ½ HOUR.”

3 DRAWING SK-BC-101 – TYPICAL FLOOR ACCESS AND WORK AREAS

.1 **DELETE** note:

“ACCESS DOOR”

and **REPLACE** with

“ACCESS DOOR IN CONCRETE WALL. APPROXIMATE DIMENSIONS OF ACCESS DOOR: 600 x 600. CONTRACTOR TO CONFIRM DIMENSIONS ON SITE.”

4 DRAWING M-BC-002 – MECHANICAL ROOM #1 SCHEMATIC SHEET #2

.1 **DELETE** drawing:

| | | |
|---|--|---|
| Solicitation No. - N° de l'invitation EP635-170974/A | Amd. No. - N° de la modif 003 | Buyer ID - Id de l'acheteur FG 267 |
| Client Ref. No. - N° de réf. du client 20170974 | File No. - N° du dossier FG267 EP635-170974/A | Project No. - N° du projet R.082113.001 & R.082112.001 |

Revision 0 – Issue for Tender – 16/05/09

And **REPLACE** with

Revision 1 – Issue for Addendum 002 – 16/10/07

5 DRAWING M-BC-101 – MECHANICAL ROOM #1 PIPING PLAN

.1 **DELETE** drawing:

Revision 0 – Issue for Tender – 16/05/09

And **REPLACE** with

Revision 1 – Issue for Addendum 002 – 16/10/07

6 EXISTING CONDITION DRAWING 97014-A16 – CONVEYOR SYSTEM PLANS

.1 **REFER** to attached existing condition drawing A16 for further details regarding the mail conveyor system.

7 EXISTING CONDITION DRAWING 97014-A17 – CONVEYOR SYSTEM DETAILS

.1 **REFER** to attached existing condition drawing A17 for further details regarding the mail conveyor system.

| | | |
|---|--|---|
| Solicitation No. - N° de l'invitation EP635-170974/A | Amd. No. - N° de la modif 003 | Buyer ID - Id de l'acheteur FG 267 |
| Client Ref. No. - N° de réf. du client 20170974 | File No. - N° du dossier FG267 EP635-170974/A | Project No. - N° du projet R.082113.001 & R.082112.001 |

8 DRAWING M-BC-107 – EQUIPMENT SCHEDULES

.1 Heat Exchanger Schedule: **DELETE** “BC-HX-501” line, and **REPLACE** with:

| Tag No. | System Served | Location | Design Load (kW) | Design Pressure (kPag) | Primary Side | | | | | | Secondary Side | | | | Approx. Overall Size [LxWxH] (mm) | | | |
|-----------|---------------|----------|------------------|------------------------|--------------|------------|----------------------|------------------|-----------------|----------------------------------|----------------|------------|----------------------|-------------------|-----------------------------------|-----------------|----------------------------------|-----------------|
| | | | | | Fluid Type | Flow (L/S) | Connection Size (mm) | Connection Spec. | EWI/LWT (°C/°C) | Max. Pressure Differential (kPa) | Fluid Type | Flow (L/S) | Connection Size (mm) | Connecti on Spec. | | EWI/LWT (°C/°C) | Max. Pressure Differential (kPa) | |
| BC-HX-501 | DHW B-4 Floor | M.R. #1 | 300 | 1100 | Water | 1.8 | 50 | Threaded | 70 | 30 | Water | 1.7 | 50 | Threaded | 10 | 60 | 35 | 775 x 320 x 920 |

.2 Control Valve Schedule: **DELETE** “BC-FCV-205” and “BC-FCV-501” lines, and **REPLACE** with:

| Tag No. | System Served | Cv | dP Calculated (kPa) | Flow (L/s) | Size (mm) | Normal Valve Position | Comments |
|------------|---------------|----|---------------------|------------|-----------|-----------------------|----------|
| BC-FCV-205 | DHW | 16 | 22 | 1.8 | 32 | N.C. | |
| BC-FCV-501 | DHW | 16 | 20 | 1.7 | 32 | L.P. | |

| | | |
|---|--|---|
| Solicitation No. - N° de l'invitation EP635-170974/A | Amd. No. - N° de la modif 003 | Buyer ID - Id de l'acheteur FG 267 |
| Client Ref. No. - N° de réf. du client 20170974 | File No. - N° du dossier FG267 EP635-170974/A | Project No. - N° du projet R.082113.001 & R.082112.001 |

SPECIFICATIONS

1 SECTION 26 05 00 – COMMON WORK RESULTS FOR ELECTRICAL

.1 **DELETE** item 3.9.1 in its entirety, and **ADD** item 3.9.1 as follows:

“.1 The Electrical Contractor is to include in tender the cost to retain the services of a professional engineer, licensed and registered in the Province of Ontario, to perform a co-ordination study of electrical power distribution equipment installed under this contract. Ensure circuit protective devices such as overcurrent trips, relays and fuses are installed to required values and settings.”

2 SECTION 22 11 16 – DOMESTIC WATER PIPING

.1 **DELETE** item 2.2.5 in its entirety.

3 SECTION 23 20 13 – HIGH PRESSURE PIPING INSIDE BUILDINGS AND CHC PLANTS

.1 **DELETE** item 2.2.4.1 in its entirety, and **ADD** item 2.2.4.1 as follows:

“.1 NPS 1/2 to 2: Class 3000, 20 MPa, screwed ends, to ASTM A105. Dimensions per ANSI B16.11.”

.2 **DELETE** item 2.2.4.2 in its entirety.

.3 **DELETE** item 3.9.1.1 in its entirety, and **ADD** item 3.9.1.1 as follows:

“.1 Primary measuring elements on steam piping shall not be used. Refer to Section 25 30 02 – EMCS: Field Control Devices for energy meter installation on the secondary heating piping and primary cooling piping.”

END OF DOCUMENT