

ADDENDUM 2

Project:	Canadian Food Inspection Agency (CFIA) AHU-301 Replacement	Addendum No.:	2
Date:	2016-October-19		
ITT No.:	G 0412		

GENERAL

*This Addendum forms part of the Contract Documents for **Removal and Replacement of this Air Handling Unit 301 at CFIA Burnaby Laboratory Located at 3155 Willingdon Green, Burnaby, BC** and amends the original drawings and Specifications. The following revisions supersede the information contained in the original drawings and Specifications issued to the extent referenced and shall become part thereof. No adjustment to the Contract Price will be considered or allowed due to the Contractor or to any sub-contractor or supplier not being familiar with this Addendum.*

SPECIFICATIONS:

Section 01 11 00 1.5.1 CONTRACTOR USE OF PREMISES - Add the Following Change:

Work is restricted to penthouse mechanical room, roof and designated washroom.

Section 01 14 00 1.3 USE OF SITE AND FACILITIES – Add the Following Change:

For use of site and facilities, one day work is permitted for all preparation work.

Section 01 14 00 1.5.2 EXISTING SERVICES – Change 48 Hours to 72 Hours as Follows:

Where Work involves breaking into or connecting to existing services, give Departmental Representative **72** hours of notice for necessary interruption of mechanical or electrical service throughout course of work. Keep duration of interruptions minimum. Carry out interruptions after normal working hours of occupants, preferably on weekends.

Section 01 33 00 1.5 ALTERNATIVES – Add the Following:

Request for alternatives may be submitted during the tendering process up to 1 week before closing of tender by submitting a written request. Alternatives must conform to performance and sizing requirements. For consideration of proposal alternatives, submit the following for review and acceptance by the Engineer.

- Complete shop drawing submittal, including performance, wiring drawings, dimensional data
- Control submittal, including control interface points, control wiring drawings, and sequence of operation.
- Details on local service capability of supplier, including number of technicians on staff, proximity to jobsite, and years of experience of each technician.
- Marked copy of specification, with exceptions clearly highlighted and guarantee of compliance to specification where exceptions are not noted.
- Written guarantee to cover any additional site installation costs associated with the supply of the proposed alternative. If a different product is submitted, ALL mechanical, electrical, architectural and structural modifications which

ADDENDUM 2

are required shall be performed under the work of the mechanical section, by the mechanical contractor, under the original contract price.

Section 23 73 11 2.12 AIRFLOW MEASURING PROBES – Add the Following:

Standard of Acceptance: Haakon FreeFlo, Ebtron, Twin City

End of Addendum