

The following additions, deletions & revisions form part of the drawings and specifications for the above referenced project:

DRAWINGS

1. Reference Drawing M2:

- .1 Heating water piping to be 20ø Type L copper. Provide reducers on either side of control valves.

- END OF MECHANICAL ADDENDUM NO. M-2 -

Goodkey, Weedmark & Associates Limited

Issued by: Steve Hamilton, P.Eng. /md



Distribution:

Ran Zaig (KWC Architects Inc.)
Tomas Regli (GWA – Mechanical)
James Moffat (GWA – Electrical)
Thomas Hopkin (GWA – Electrical)