

The following additions, deletions & revisions form part of the drawings and specifications for the above referenced project:

SPECIFICATIONS

1. **Reference Section 10 44 16.19 – Fire Extinguishers and Safety Blankets:**

- .1 Add new Section 10 44 16.19 – Fire Extinguishers and Safety Blankets.

DRAWINGS

1. **Reference Drawing M2:**

- .1 Connect new vent piping to existing vent piping at base building washroom.

Enclosure: Section 10 44 16.19 – Fire Extinguishers and Safety Blankets – One (1) page

- END OF MECHANICAL ADDENDUM NO. M-3 -

Goodkey, Weedmark & Associates Limited

Issued by: Steve Hamilton, P.Eng. /md



Distribution:

Ran Zaig (KWC Architects Inc.)

Tomas Regli (GWA – Mechanical)

James Moffat (GWA – Electrical)

Thomas Hopkin (GWA – Electrical)

PART 1 - GENERAL

- | | | |
|--|----|---|
| <u>1.1 REFERENCES</u> | .1 | National Fire Protection Association (NFPA)
.1 NFPA (Fire) 10, Standard for Portable Fire Extinguishers, 2013 Edition. |
| <u>1.2 ACTION AND INFORMATIONAL SUBMITTALS</u> | .1 | Provide submittals in accordance with Section 01 33 00 - Submittal Procedures. |

PART 2 - PRODUCTS

- | | | |
|--|----|--|
| <u>2.1 Multi-Purpose Dry Chemical Extinguisher</u> | .1 | (FE) Stored pressure dry chemical type with heavy duty steel cylinder, positive on/off operation, waterproof stainless steel gauge, shut-off nozzle, ULC labelled for A, B and C class protection c/w wall mounting bracket. Size 2.25 kg, 3A-10BC rating. |
|--|----|--|

PART 3 - EXECUTION

- | | | |
|--|----|---|
| <u>3.1 MANUFACTURER'S INSTRUCTIONS</u> | .1 | Compliance: comply with manufacturer's written recommendations, including product technical bulletins, handling, storage and installation instructions, and datasheets. |
| <u>3.2 INSTALLATION</u> | .1 | Install or mount extinguishers in accordance with NFPA (Fire) 10. |

END OF SECTION