



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada -
Pacific Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Float Replacement	
Solicitation No. - N° de l'invitation F1700-165102/A	Amendment No. - N° modif. 005
Client Reference No. - N° de référence du client F1700-165102	Date 2016-10-25
GETS Reference No. - N° de référence de SEAG PW-\$PWY-019-7881	
File No. - N° de dossier PWY-6-39157 (019)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2016-11-03	
Time Zone Fuseau horaire Pacific Daylight Saving Time PDT	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Ngan, Ken (PWY)	Buyer Id - Id de l'acheteur pwy019
Telephone No. - N° de téléphone (604) 658-2755 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: DFO - Institute of Ocean Sciences - Sidney, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
F1700-165102/A
Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.
005
File No. - N° du dossier
pwy-6-39157

Buyer ID - Id de l'acheteur
pwy019
CCC No./N° CCC - FMS No/ N° VME

Les documents français seront disponibles sur demande.

This Solicitation Amendment 005 is raised to incorporate the Pre-Bid Interpretation No. 3 document associated with the Bid Depository requirement.

Please find following the Pre-Bid Interpretation No. 3 document.

All other terms and conditions remain unchanged.



British
Columbia
Construction
Association

British Columbia Construction Association
BidCentral Online Bidding for Subcontractors
401 – 655 Tyee Road Victoria, BC V9A 6X5
P: (250) 475-1077 F: (250) 475-1078
E: warrenp@bccassn.com
W: www.bccassn.com or www.bidcentral.ca

PRE-BID INTERPRETATION No. 3

Date: October 24, 2016
To: All Plan Holders
Project: Float Replacement – Institute of Ocean Sciences,
Sidney, BC

Bid Calling Authority: Public Works and Government Services Canada

As allowed under Rule 1. F. Pre-Bid Interpretations, we are hereby issuing the following clarification to all plan holders. Unless defined herein the Standard Exclusions will apply; *General Contractors are responsible to include all work that may be excluded from a BidCentral Online Bidding for Subcontractor's (BOBS) Bid as they deem necessary.* This document does not imply a requirement to include work not specified:

1. Electrical

1. This Bid shall include:
 1. Section 01 91 13 Commissioning, 1.6.2 – Electrical testing in accordance with the requirements in Division 26 Electrical.
 2. Section 01 91 41 Demonstration and Training, 1.7.5 – Demonstration and instruction for new power pedestals.
 3. As per Section 26 05 29 Hangers and Supports for Electrical Systems, 3.1.8 , the extended aluminum bracket (Drawing E502 Note 5) and the aluminum pedestal (Drawing E500, Detail 5) and similar.
2. Clarification: The Electrical Bid will not include the engagement of services for an independent inspection and testing laboratory as specified in Section 01 45 00 Quality Control, 1.3.4. The General Contractor will include for this work as they deem necessary. The Electrical Bidder shall include for the related work in the Electrical Bid and coordinate with the General Contractor to meet the requirements for the General Contractor's independent inspection and testing laboratory.
3. Clarification: The Electrical Bid will not include the commissioning as specified in Section 01 91 13 Commissioning, 1.2.1 other than as required to coordinate with General Contractors Commissioning Agent. The engagement of the commissioning agent shall be included by the General Contractor as they deem necessary.

END

BidCentral Online Bidding for Subcontractors per;

Warren E. Perks, Administrator

<p>All Plan Holders should insure that copies of this Pre-Bid Interpretation are forwarded to all those to whom they have issued copies of the project documents.</p>
--