


REFERENCES

GENERAL NOTES

- 1 ALL TRUNKING TO BE 14 GA. (GALV)
- 2 ALL TRUNK SIZES ARE INSIDE DIMENSIONS
- 3 SPLITTER VANES TO BE FITTED WHERE INDICATED TO REDUCE PRESSURE LOSSES
- 4 REGULATING DAMPERS TO BE FITTED WHERE INDICATED TO BALANCE THE SYSTEM OR SHUT OFF IF NOT REQUIRED
- 5 CONTROL ROOM VENTS NORMALLY SHUT OFF
- 6 FOR TRUNK AND HANGER DETAILS AND LISTS OF GRILLES, DIFFUSERS, COMINGS ETC. SEE SHEETS 7 AND 8
- 7 ALL TRUNKS TO BE INSULATED
- 8 TRUNK SIZE A X B
HORIZONTAL RUNS
VERTICAL RUNS




9. DUCT JOINTS: RECTANGULAR: 1/8" ANGLE FLANGES, 1/8" BOLTS. ROUND: 1/8" ANGLE FLANGES, 1/8" BOLTS. SLEEVES: 20 WIDE 1/8" THICK, 1/8" SLOPE WETS. HANGERS: SEE DETAIL 72-555 SHEET 8

no.	REVISION	by	date

Print issued to:

prints issued

CCGS ANN HARVEY
APRIL 1987
AS FITTED



Canadian
Coast Guard

Garde côtière
canadienne

PROJECT HULL No. 72 TYPE 1100 NAUDES TENDER / LIGHT ICEBREAKER


TITLE VENTILATION

PROPULSION GENERATOR ROOM

OWNER	APPR.	SENT	APPR.	SENT	DRAWN BY	CHECKED BY
15/1/85					J. Crowford	
DESIGN	DATE	12 March 1984	REVISION N°:			
1.25	Account no.	1215				

DRG. N°: 72 - 555 Sheet 1 of 12

NOTE: 1. CONTROL ROOM EXHAUST GRILLE SIZE 300 WIDE X 300 HIGH. 2. GRASS WIRE MESH SCREEN AND STEEL PLATE CLOSURE, BOTH SIDES. 3. UNIMOUNTED. REF. DET. NO. 72-555 SHEET 8.



PLAN BELOW MAIN DECK

SECTION BB
LOOKING FORWARD FROM FRAME 86

SECTION CC
LOOKING AFT FROM FRAME 79

SECTION DD
LOOKING FORWARD FROM FRAME 89

SECTION EE
LOOKING FORWARD FROM FRAME 82