

DEMOLITION NOTES:
D1) DEMOLISH EXHAUST AIR DUCT FROM EXISTING DIVIDER WALL TO EXHAUST LOUVRE.
D2) DEMOLISH EXISTING 200x150 mm AIR GRILLE.


NOTE THAT NOT ALL EXISTING DUCTWORK IS SHOWN.

1

M03

DEMO PLAN

SCALE: 1:25




NOTES:
1) PROVIDE NEW 200x150 mm CEILING MOUNTED RETURN AIR GRILLE AND CONNECT TO EXISTING DUCTWORK.

2

M03


NEW DUCTWORK PLAN

SCALE: 1:25



1	ISSUED FOR TENDER	2016/01/15
Revision		Date

Do not scale drawings.
Verify all dimensions and conditions on site and immediately
notify the Departmental Representative of all discrepancies.



project title
titre du projet
REPAIR SHOWERS IN LIVING
UNITS F-32S
COLLINS BAY INSTITUTION
FRONTENAC INSTITUTION
1455 BATH ROAD, KINGSTON, ONTARIO

drawing title
titre du dessin

HVAC DEMO AND PLANS

drawn by
dessiné par
KB

designed by
conç par
KB

approved by
approuvé par
KT/JE

bid
offre
project manager
administrateur
de projets

project date
date du projet
2015-06-25

project no.
no. du projet
R.073539.001

drawing no.
dessiné no.
M03