


**DORWARD  
ENGINEERING  
SERVICES LTD.**

CONSULTING ELECTRICAL ENGINEERS

- NOTES:
1. REMOVE ALL UN USED CONDUIT UNLESS APPROVAL IS RECEIVED FROM THE ENGINEER.
  2. ALL REMOVED FIRE ALARM DEVICES ARE TO BE REPLACED BY BLANK COVER PLATES.
  3. NEW WIRING OR EXTENSION OF WIRING TO BE RUN IN CONDUIT WHERE IN NON PUBLIC, STAFFHOUSE AREAS, AND INSTALLED IN WIRE MOLD IN PUBLIC AREAS. TYPICAL THROUGHOUT.



*Palace Grand Theatre Renovation*

**PERMIT TO PRACTICE**

Signature: *[Signature]*

Date: *Sept 1/2016*

**PERMIT NUMBER: PP001**

Association of Professional Engineers  
of Yukon

|                       |                         |             |
|-----------------------|-------------------------|-------------|
| 8                     | ISSUE FOR TENDER        | 31 AUG 2016 |
| 7                     | ISSUED FOR 90% REVIEW   | 5 AUG 2016  |
| Revision/<br>Revision | Description/Description | Date/Date   |

|   |  |   |
|---|--|---|
| A | détail number<br>numéro de détail              | A |
| B | source drawing no.<br>de dessin no.            | B |
| C | détail on drawing no.<br>détail sur dessin no. | C |

Client/client

**PARK CANADA AGENCY**

**WESTERN AND NORTHERN REGION**

Project title/Titre du projet

**DAWSON CITY  
YUKON TERRITORY**

**PALACE GRAND THEATRE  
FOUNDATION/ MECHANICAL  
/ELECTRICAL RENOVATION  
AND GENERAL UPGRADE**

Consultant Signature Only

Designed by/Concept par  
MS

Drawn by/Dessiné par  
MS


PWGSOC Project Manager/Administrateur de Projets TPSGC  
TOM DUNPHY

Regional Manager, Architectural and Engineering Services  
Gestionnaire régionale, Services d'architectural et de génie, TPSGC

Drawing title/Titre du dessin


**MAIN FLOOR AND SECOND FLOOR  
FIRE ALARM LAYOUTS**

|                              |               |                                     |
|------------------------------|---------------|-------------------------------------|
| Project No./No. du<br>projet | Sheet/Feuille | Revision no./<br>La Révision<br>no. |
| R.068835.001                 | E4 of 7       | 8                                   |



**1 MAIN FLOOR FIRE ALARM LAYOUTS**

SCALE: 1:100



**2 SECOND FLOOR FIRE ALARM LAYOUTS**

SCALE: 1:100