


Copyright Reserved

The Contractor shall verify and be responsible for all dimensions. DO NOT scale the drawing - any errors or omissions shall be reported to Stantec without delay.

The Copyrights to all designs and drawings are the property of Stantec. Reproduction or use for any purpose other than that authorized by Stantec is forbidden.

— LIGHT = EXIST
— DARK = NEW
////// AREA TO BE DEMOLISHED

- KEYNOTES**
1. INSTALL NEW FIRE DAMPER IN PROSCENIUM ARCH WALL.
 2. PROVIDE 13x13mm BIRDSCREEN OVER EXISTING OPENING
 3. RELOCATED 400# R/A BELL MOUTH C/W NEW 13x13mm BIRDSCREEN OVER OPENING
 4. DIFFUSER ON BOTTOM OF DUCT



PERMIT TO PRACTICE

Signature: *[Signature]*
Date: Aug. 31/16

PERMIT NUMBER: PP315
Association of Professional Engineers
of Yukon

Revision/	Description/Description	Date/Date
1	RE-ISSUED FOR TENDER	16/08/31
0	ISSUED FOR TENDER	16/04/05

Client/client

PARKS CANADA AGENCY

WESTERN AND NORTHERN REGION

Project title/Titre du projet
**DAWSON CITY
YUKON TERRITORY
PALACE GRAND THEATRE**

**FOUNDATION / MECHANICAL
/ ELECTRICAL RENOVATION
AND GENERAL UPGRADE**

Consultant Signature Only

Designed by/Concept par
L. FLEMMING / B. ZRUM

Drawn by/Dessiné par
B. ZRUM

PWGS Project Manager/Administrateur de Projets TPSGC
TOM DUNPHY

Regional Manager, Architectural and Engineering Services
Gestionnaire régionale, Services d'architectural et de génie, TPSGC

Drawing title/Titre du dessin
**MECHANICAL PLANS:
ATTIC VENTILATION**


Project No./No. du projet
R.068835.001

Sheet/Feuille
M104


Revision no./La Révision no.
1

144902132


5 OF 15



1 VENTILATION PLAN - ATTIC SPACE
SCALE: 1:100



3 SMOKE EXHAUST FAN SECTION
SCALE: 1:100



LOUVER
SMOKE EVAC
CUSTOM SIZE
SEE DETAILS

BELL
SEE NOTE
520

4# E-1
1200x450
2360

2# BELL
SEE NOTE
150

BELL
SEE NOTE
400