
PART 1 - GENERAL

- 1.1 RELATED REQUIREMENTS .1 Section 09 22 16 - Non-structural Metal Framing.
- 1.2 REFERENCES .1 American Society for Testing and Materials International (ASTM)
.1 ASTM C 553-02, Specification for Mineral Fibre Blanket Thermal Insulation for Commercial and Industrial Applications.
.2 ASTM E 90-09, Standard Test Method for Laboratory Measurement of Airborne Sound Transmission Loss of Building Partitions and Elements.
.3 ASTM C 665, Standard Specification for Mineral-Fiber Blanket Thermal Insulation for Light Frame Construction and Manufactured Housing.
- .2 Canadian Gas Association (CGA)
.1 CAN/CGA-B149.1-05, Natural Gas and Propane Installation Code Handbook.
.2 CAN/CGA-B149.2-[05], Propane Storage and Handling Code.
- .3 Canadian Standards Association (CSA International)
.1 CSA B111-[1974(R2003)], Wire Nails, Spikes and Staples.
- .4 Underwriters Laboratories of Canada (ULC)
.1 CAN/ULC-S604-M1991, Type A Chimneys.
.2 CAN/ULC-S702-1997, Standard for Mineral Fibre Insulation.
- 1.3 ACTION AND INFORMATIONAL SUBMITTALS .1 Product Data:
.1 Submit manufacturer's printed product literature, specifications and data sheet in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Manufacturer's Instructions:
.1 Submit manufacturer's installation instructions.
- 1.4 QUALITY ASSURANCE .1 Test Reports: certified test reports showing compliance with specified performance characteristics and physical properties.
- .2 Certificates: product certificates signed by manufacturer certifying materials comply with specified performance characteristics and criteria and physical requirements.
- .3 Health and Safety Requirements: do construction

occupational health and safety in accordance with Section 01 35 29.06 - Health and Safety Requirements.

- 1.5 WASTE MANAGEMENT AND DISPOSAL
- .1 Remove from site and dispose of packaging materials at appropriate recycling facilities.
 - .2 Collect and separate for disposal paper, plastic, polystyrene, corrugated cardboard packaging material for recycling in accordance with Waste Management Plan.

PART 2 - PRODUCTS

- 2.1 INSULATION
- .1 Sound attenuation blanket: to ASTM C665
 - .1 Type: 1.
 - .2 Thickness: as indicated.
 - .2 Mineral fibre: to CAN/ULC S702.
 - .1 Type: 1.
 - .2 Thickness: as indicated.
 - .3 Glass Fiber: CAN/ULC S702.
 - .1 Type: 1.
 - .2 Thickness: as indicated.

- 2.3 ACCESSORIES
- .1 Mechanical fasteners in accordance with insulation manufacturer's written recommendations.

PART 3 - EXECUTION

- 3.1 MANUFACTURER'S INSTRUCTIONS
- .1 Compliance: comply with manufacturer's written data, including product technical bulletins, product catalogue installation instructions, product carton installation instructions, and data sheets.
- 3.2 INSULATION INSTALLATION
- .1 Install insulation to maintain continuity of thermal protection to building elements and spaces.
 - .2 Install insulation with factory applied vapour barrier facing warm side of building spaces and vapour permeable membrane facing cold side. Lap ends and side flanges of membrane over framing members. Retain in position with insulation clips installed as recommended by manufacturer. Tape seal butt ends and lapped side flanges. Do not tear or cut vapour barrier.
 - .3 Fit insulation closely around electrical boxes, pipes, ducts, frames and other objects in or passing through insulation.
 - .4 Do not compress insulation to fit into spaces.
 - .5 Keep insulation minimum 75 mm from heat emitting devices such as recessed light fixtures.

- .6 Do not enclose insulation until it has been inspected and approved by Departmental Representative.

3.3 CLEANING

- .1 Upon completion of installation, remove surplus materials, rubbish, tools and equipment barriers.

PART 1 - GENERAL

- 1.1 RELATED REQUIREMENTS
- .1 Section 09 22 16 - Non-structural Metal Framing.
- 1.2 REFERENCES
- .1 Health Canada/Workplace Hazardous Materials Information System (WHMIS)
.1 Material Safety Data Sheets (MSDS).
- .2 Underwriter's Laboratories of Canada (ULC)
.1 ULC-S115-1995, Fire Tests of Fire stop Systems.
- .3 American Society for Testing and Materials
.1 ASTM E 119-12a Standard Test Methods for Fire Tests of Building Construction and Materials.
- 1.3 DEFINITIONS
- .1 Fire Stop Material: device intended to close off opening or penetration during fire or materials that fill openings in wall or floor assembly where penetration is by cables, cable trays, conduits, ducts and pipes and poke-through termination devices, including electrical outlet boxes along with their means of support through wall or floor openings.
- .2 Single Component Fire Stop System: fire stop material that has Listed Systems Design and is used individually without use of high temperature insulation or other materials to create fire stop system.
- .3 Multiple Component Fire Stop System: exact group of fire stop materials that are identified within Listed Systems Design to create on site fire stop system.
- .4 Tightly Fitted; (ref: NBC Part 3.1.9.1.1 and 9.10.9.6.1): penetrating items that are cast in place in buildings of noncombustible construction or have "0" annular space in buildings of combustible construction.
.1 Words "tightly fitted" should ensure that integrity of fire separation is such that it prevents passage of smoke and hot gases to unexposed side of fire separation.
- 1.4 ACTION AND INFORMATIONAL SUBMITTALS
- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
.1 Submit manufacturer's printed product literature, specifications and datasheet and include product characteristics, performance criteria,

physical size, finish and limitations.

.2 Submit two copies of WHMIS MSDS - Material Safety Data Sheets.

.3 Shop Drawings:

.1 Submit shop drawings to show location, proposed material, reinforcement, anchorage, fastenings and method of installation.

.2 Construction details should accurately reflect actual job conditions.

.4 Samples:

.1 Submit duplicate 300 x 300 mm samples showing actual fire stop material proposed for project.

.5 Quality assurance submittals:

.1 Test reports: in accordance with CAN-ULC-S101 for fire endurance and CAN-ULC-S102 for surface burning characteristics.

.1 Submit certified test reports from approved independent testing laboratories, indicating compliance of applied fire stopping with specifications for specified performance characteristics and physical properties.

.2 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.

.3 Manufacturer's Instructions: submit manufacturer's installation instructions and special handling criteria, installation sequence and cleaning procedures.

1.5 DELIVERY,
STORAGE AND
HANDLING

.1 Packing, shipping, handling and unloading:

.1 Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements.

.2 Deliver, store and handle materials in accordance with manufacturer's written instructions.

.3 Deliver materials to the site in undamaged condition and in original unopened containers, marked to indicate brand name, manufacturer, ULC markings.

.2 Storage and Protection:

.1 Store materials indoors in dry location and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.

.2 Replace defective or damaged materials with new.

PART 2 - PRODUCTS

2.1 MATERIALS

.1 Fire stopping and smoke seal systems: in accordance with CAN-ULC-S115.

.1 Asbestos-free materials and systems capable of

maintaining effective barrier against flame, smoke and gases in compliance with requirements of CAN- ULC-S115 and not to exceed opening sizes for which they are intended.

- .2 Service penetration assemblies: systems tested to CAN-ULC-S115.
- .3 Service penetration fire stop components: certified by test laboratory to CAN-ULC-S115.
- .4 Fire-resistance rating of installed fire stopping assembly in accordance with NBC.
- .5 Fire stopping and smoke seals at openings intended for ease of re-entry such as cables: elastomeric seal.
- .6 Fire stopping and smoke seals at openings around penetrations for pipes, ductwork and other mechanical items requiring sound and vibration control: elastomeric seal.
- .7 Primers: to manufacturer's recommendation for specific material, substrate, and end use.
- .8 Water (if applicable): potable, clean and free from injurious amounts of deleterious substances.
- .9 Damming and backup materials, supports and anchoring devices: to manufacturer's recommendations, and in accordance with tested assembly being installed as acceptable to authorities having jurisdiction.
- .10 Sealants for vertical joints: non-sagging.
- .11 Colour: all fire stopping to be blue.

PART 3 - EXECUTION

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheets.

3.2 PREPARATION

- .1 Examine sizes and conditions of voids to be filled to establish correct thicknesses and installation of materials.
 - .1 Ensure that substrates and surfaces are clean, dry and frost free.
- .2 Prepare surfaces in contact with fire stopping materials and smoke seals to manufacturer's instructions.

.3 Maintain insulation around pipes and ducts penetrating fire separation.

.4 Mask where necessary to avoid spillage and over coating onto adjoining surfaces; remove stains on adjacent surfaces.

3.3 INSTALLATION

.1 Install fire stopping and smoke seal material and components in accordance with manufacturer's certified tested system listing.

.2 Seal holes or voids made by through penetrations, poke-through termination devices, and unpenetrated openings or joints to ensure continuity and integrity of fire separation are maintained.

.3 Provide temporary forming as required and remove forming only after materials have gained sufficient strength and after initial curing.

.4 Tool or trowel exposed surfaces to neat finish.

.5 Remove excess compound promptly as work progresses and upon completion.

3.4 SEQUENCES OF OPERATION

.1 Proceed with installation only when submittals have been reviewed by Departmental Representative.

.2 Install floor fire stopping before interior partition erections.

.3 Metal deck bonding: fire stopping to precede spray applied fireproofing to ensure required bonding.

.4 Mechanical pipe insulation: certified fire stop system component.

.1 Ensure pipe insulation installation precedes fire stopping.

3.5 FIELD QUALITY CONTROL

.1 Inspections: notify Departmental Representative when ready for inspection and prior to concealing or enclosing fire stopping materials and service penetration assemblies.

3.6 CLEANING

.1 On completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

.2 Remove temporary dams after initial set of fire stopping and smoke seal materials.

3.7 SCHEDULE

.1 Fire stop and smoke seal at:

- .1 Penetrations through fire-resistance rated masonry, concrete, and gypsum board partitions and walls.
- .2 Edge of floor slabs at curtain wall and precast concrete panels.
- .3 Top of fire-resistance rated masonry and gypsum board partitions.
- .4 Intersection of fire-resistance rated masonry and gypsum board partitions.
- .5 Control and sway joints in fire-resistance rated masonry and gypsum board partitions and walls.
- .6 Penetrations through fire-resistance rated floor slabs, ceilings and roofs.
- .7 Openings and sleeves installed for future use through fire separations.
- .8 Around mechanical and electrical assemblies penetrating fire separations.
- .9 Rigid ducts: greater than 129 cm²: fire stopping to consist of bead of fire stopping material between retaining angle and fire separation and between retaining angle and duct, on each side of fire separation.

PART 1 - GENERAL

- 1.1 RELATED REQUIREMENTS .1 Section 09 21 16 - Gypsum Board Assemblies.
- 1.2 REFERENCES .1 ASTM International
.1 ASTM C 919-08, Standard Practice for Use of Sealants in Acoustical Applications.
.2 Canadian General Standards Board (CGSB)
.1 CGSB 19-GP-5M-1984, Sealing Compound, One Component, Acrylic Base, Solvent Curing (Issue of 1976 reaffirmed, incorporating Amendment No. 1).
.2 CAN/CGSB-19.13-M87, Sealing Compound, One-component, Elastomeric, Chemical Curing.
.3 CGSB 19-GP-14M-1984, Sealing Compound, One Component, Butyl-Polyisobutylene Polymer Base, Solvent Curing (Reaffirmation of April 1976).
.4 CAN/CGSB-19.17-M90, One-Component Acrylic Emulsion Base Sealing Compound.
.5 CAN/CGSB-19.24-M90, Multi-component, Chemical Curing Sealing Compound.
.3 General Services Administration (GSA) - Federal Specifications (FS)
.1 FS-SS-S-200-E(2)1993, Sealants, Joint, Two-Component, Jet-Blast-Resistant, Cold Applied, for Portland Cement Concrete Pavement.
.4 Health Canada/Workplace Hazardous Materials Information System (WHMIS)
.1 Material Safety Data Sheets (MSDS).
.5 South Coast Air Quality Management District (SCAQMD), California State, Regulation XI. Source Specific Standards
.1 SCAQMD Rule 1168-A2005, Adhesives and Sealants Applications.
- 1.3 ACTION AND INFORMATIONAL SUBMITTALS .1 Submit in accordance with Section 01 33 00 - Submittal Procedures.
.2 Product Data:
.1 Submit manufacturer's instructions, printed product literature and data sheets for joint sealants and include product characteristics, performance criteria, physical size, finish and limitations.
.2 Manufacturer's product to describe:
.1 Caulking compound.
.2 Primers.
.3 Sealing compound, each type, including compatibility when different sealants are in

contact with each other.

.3 Submit 2 copies of WHMIS MSDS in accordance with Section 01 35 29.06 - Health and Safety Requirements.

.3 Samples:

.1 Submit 2 samples of each type of material and colour.

.2 Cured samples of exposed sealants for each colour where required to match adjacent material.

.4 Manufacturer's Instructions:

.1 Submit instructions to include installation instructions for each product used.

1.4 CLOSEOUT SUBMITTALS

.1 Submit in accordance with Section 01 78 00 - Closeout Submittals.

.2 Operation and Maintenance Data: submit operation and maintenance data for incorporation into manual.

1.5 DELIVERY, STORAGE AND HANDLING

.1 Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements and with manufacturer's written instructions.

.2 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.

.3 Storage and Handling Requirements:

.1 Store materials indoors in dry location and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.

.2 Store and protect joint sealants from nicks, scratches, and blemishes.

.3 Replace defective or damaged materials with new.

1.6 SITE CONDITIONS

.1 Ambient Conditions:

.1 Proceed with installation of joint sealants only when:

.1 Ambient and substrate temperature conditions are within limits permitted by joint sealant manufacturer or are above 4.4 degrees C.

.2 Joint substrates are dry.

.3 Conform to manufacturer's recommended temperatures, relative humidity, and substrate moisture content for application and curing of sealants including special conditions governing use.

.2 Joint-Width Conditions:

.1 Proceed with installation of joint sealants only where joint widths are more than those allowed by joint sealant manufacturer for applications indicated.

.3 Joint-Substrate Conditions:

.1 Proceed with installation of joint sealants only after contaminants capable of interfering with adhesion are removed from joint substrates.

1.7 ENVIRONMENTAL REQUIREMENTS

.1 Comply with requirements of Workplace Hazardous Materials Information System (WHMIS) regarding use, handling, storage, and disposal of hazardous materials; and regarding labelling and provision of Material Safety Data Sheets (MSDS) acceptable to Health Canada.

.2 Departmental Representative will arrange for ventilation system to be operated on maximum outdoor air and exhaust during installation of caulking and sealants. Ventilate area of work as directed by Departmental Representative by use of approved portable supply and exhaust fans.

PART 2 - PRODUCTS

2.1 SEALANT MATERIALS

.1 Do not use caulking that emits strong odours, contains toxic chemicals or is not certified as mould resistant in air handling units.

.2 When low toxicity caulks are not possible, confine usage to areas which off gas to exterior, are contained behind air barriers, or are applied several months before occupancy to maximize off gas time.

.3 Where sealants are qualified with primers use only these primers.

2.2 SEALANT MATERIAL DESIGNATIONS

.1 Acrylic latex one part: to CAN/CGSB-19.17.

.2 Acoustical sealant: to ASTM C 919.

2.3 SEALANT SELECTION

.1 Perimeters of interior frames, as detailed and itemized: sealant type: acrylic latex.

.2 Exposed interior control joints in drywall: sealant type: acoustical sealant.

2.4 JOINT CLEANER

.1 Non-corrosive and non-staining type, compatible with joint forming materials and sealant in accordance with sealant manufacturer's written recommendations.

.2 Primer: in accordance with sealant manufacturer's written recommendations.

PART 3 - EXECUTION3.1 EXAMINATION

- .1 Verification of Conditions: verify that conditions of substrate previously installed under other Sections or Contracts are acceptable for joint sealants installation in accordance with manufacturer's written instructions.
 - .1 Visually inspect substrate in presence of Departmental Representative.
 - .2 Inform Departmental Representative of unacceptable conditions immediately upon discovery.
 - .3 Proceed with installation only after unacceptable conditions have been remedied and after receipt of written approval to proceed from Departmental Representative.

3.2 SURFACE PREPARATION

- .1 Examine joint sizes and conditions to establish correct depth to width relationship for installation of backup materials and sealants.
- .2 Clean bonding joint surfaces of harmful matter substances including dust, rust, oil grease, and other matter which may impair Work.
- .3 Do not apply sealants to joint surfaces treated with sealer, curing compound, water repellent, or other coatings unless tests have been performed to ensure compatibility of materials. Remove coatings as required.
- .4 Ensure joint surfaces are dry and frost free.
- .5 Prepare surfaces in accordance with manufacturer's directions.

3.3 PRIMING

- .1 Where necessary to prevent staining, mask adjacent surfaces prior to priming and caulking.
- .2 Prime sides of joints in accordance with sealant manufacturer's instructions immediately prior to caulking.

3.4 BACKUP MATERIAL

- .1 Apply bond breaker tape where required to manufacturer's instructions.
- .2 Install joint filler to achieve correct joint depth and shape, with approximately 30% compression.

3.5 MIXING

- .1 Mix materials in strict accordance with sealant manufacturer's instructions.

3.6 APPLICATION

- .1 Sealant:
 - .1 Apply sealant in accordance with manufacturer's written instructions.
 - .2 Mask edges of joint where irregular surface or

sensitive joint border exists to provide neat joint.

.3 Apply sealant in continuous beads.

.4 Apply sealant using gun with proper size nozzle.

.5 Use sufficient pressure to fill voids and joints solid.

.6 Form surface of sealant with full bead, smooth, free from ridges, wrinkles, sags, air pockets, embedded impurities.

.7 Tool exposed surfaces before skinning begins to give slightly concave shape.

.8 Remove excess compound promptly as work progresses and upon completion.

.2 Curing:

.1 Cure sealants in accordance with sealant manufacturer's instructions.

.2 Do not cover up sealants until proper curing has taken place.

3.7 CLEANING

.1 Progress Cleaning:

.1 Leave Work area clean at end of each day.

.2 Clean adjacent surfaces immediately.

.3 Remove excess and droppings, using recommended cleaners as work progresses.

.4 Remove masking tape after initial set of sealant.

.2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment.

3.8 PROTECTION

.1 Protect installed products and components from damage during construction.

.2 Repair damage to adjacent materials caused by joint sealants installation.