

---

PART 1 - GENERAL1.1 REFERENCES

- .1 Definitions:
  - .1 Electrical and electronic terms: unless otherwise specified or indicated, terms used in these specifications, and on drawings, are those defined by IEEE SP1122.
- .2 Reference Standards:
  - .1 CSA Group
    - .1 CSA C22.1-15, Canadian Electrical Code, Part 1 (23rd Edition), Safety Standard for Electrical Installations.
    - .2 CAN3-C235-83(R2010), Preferred Voltage Levels for AC Systems, 0 to 50,000 V.
  - .2 Institute of Electrical and Electronics (IEEE)/National Electrical Safety Code Product Line (NESC)
    - .1 IEEE SP1122-2000, The Authoritative Dictionary of IEEE Standards Terms, 7th Edition.

1.2 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submit in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
  - .1 Submit manufacturer's instructions, printed product literature and data sheets and include product characteristics, performance criteria, physical size, finish and limitations.
- .3 Shop drawings:
  - .1 Submit wiring diagrams and installation details of equipment indicating proposed location, layout and arrangement, control panels, accessories, piping, ductwork, and other items that must be shown to ensure co-ordinated installation.
  - .3 Identify on wiring diagrams circuit terminals and indicate internal wiring for each item of equipment and interconnection between each item of equipment.
  - .4 Indicate on drawings clearances for operation, maintenance, and replacement of operating equipment devices.
  - .5 Submit drawings and product data to authority having jurisdiction.
  - .6 If changes are required, notify Departmental Representative of these changes before they are made.

- 
- .4 Certificates:
    - .1 Provide CSA certified equipment and material.
    - .2 Where CSA certified equipment and material is not available, submit such equipment and material to authority having jurisdiction for approval before delivery to site.
    - .3 Submit test results of installed electrical systems and instrumentation.
    - .4 Permits and fees: in accordance with General Conditions of contract.
    - .5 Submit, upon completion of Work, load balance report as described in PART 3 - LOAD BALANCE.
    - .6 Submit certificate of acceptance from authority having jurisdiction upon completion of Work to Departmental Representative.
  
  - .5 Manufacturer's Field Reports: submit to Departmental Representative manufacturer's written report, within 3 days of review, verifying compliance of Work and electrical system and instrumentation testing, as described in PART 3 - FIELD QUALITY CONTROL.
  
  - .6 Sustainable Design Submittals:
    - .1 Construction Waste Management:
      - .1 Submit project Waste Management Plan highlighting recycling and salvage requirements.
    - .2 Recycled Content:
      - .1 Submit listing of recycled content products used, including details of required percentages or recycled content materials and products, showing their costs and percentages of post-consumer and post-industrial content, and total cost of materials for project.
  
  - 1.3 CLOSEOUT  
SUBMITTALS
    - .1 Submit in accordance with Section 01 78 00 - Closeout Submittals.
  
    - .2 Operation and Maintenance Data: submit operation and maintenance data for incorporation into manual.
      - .1 Provide for each system and principal item of equipment as specified in technical sections for use by operation and maintenance personnel.
      - .2 Manual to include the following:
        - .1 Wiring diagrams, control diagrams, and control sequence for each principal system and item of equipment.
        - .2 Start up, proper adjustment, operating, lubrication, and shutdown procedures.
        - .3 Safety precautions.
        - .4 Procedures to be followed in event of equipment failure.

- 
- .5 Other items of instruction as recommended by manufacturer of each system or item of equipment.
  - .6 Completed BGIS CMMS forms, per Equipment Identification section below.
  - .7 Reports (including start-up, testing, load balancing, verification, and Electrical Safety Authority reports).
  - .8 Emergency lighting letter signed by contractor that lighting is connected to emergency power as per plans and specifications.
  - .9 Seismic letter per below.
  - .10 Consultant reviewed shop drawings.
  - .11 Service and maintenance manual for new equipment.
  - .12 Signed letter of warranty.
  - .3 Print or engrave operating instructions and frame in laminated plastic.
  - .4 Post instructions where directed.
  - .5 For operating instructions exposed to weather, provide weather-resistant materials or weatherproof enclosures.
  - .6 Ensure operating instructions will not fade when exposed to sunlight and are secured to prevent easy removal or peeling.
- .3 Provide letter sealed and signed by structural engineer licensed in Ontario that all electrical systems have been installed with adequate support to withstand seismic forces in accordance with the National Building Code.
- 1.4 DELIVERY,  
STORAGE AND  
HANDLING
- 
- .1 Deliver, store and handle materials in accordance with manufacturer's written instructions.
  - .2 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.
  - .3 Storage and Handling Requirements:
    - .1 Store materials indoors and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.
    - .2 Store and protect from nicks, scratches, and blemishes.
    - .3 Replace defective or damaged materials with new.

- .4 Packaging Waste Management: remove for reuse of pallets, crates, padding, and packaging materials as specified in Construction Waste Management Plan.

## PART 2 - PRODUCTS

### 2.1 DESIGN REQUIREMENTS

- .1 Operating voltages: to CAN3-C235-83(R2010).
- .2 Motors, electric heating, control and distribution devices and equipment to operate satisfactorily at 60 Hz within normal operating limits established by above standard.
  - .1 Equipment to operate in extreme operating conditions established in above standard without damage to equipment.
- .3 Language operating requirements: provide identification nameplates and labels for control items in English and French.
- .4 Use one nameplate or label for each language.

### 2.2 MATERIALS AND EQUIPMENT

- .1 Factory assemble control panels and component assemblies.

### 2.3 ELECTRIC MOTORS, EQUIPMENT AND CONTROLS

- .1 Verify installation and co-ordination responsibilities related to motors, equipment and controls, as indicated.
- .2 Control wiring and conduit: Provide all except for conduit, wiring and connections below 50 V which are related to control systems specified in mechanical sections and as shown on mechanical drawings.

### 2.4 WARNING SIGNS

- .1 Warning Signs: in accordance with requirements of Departmental Representative.
- .2 Decal signs, minimum size 175 x 250 mm.

## 2.5 WIRING TERMINATIONS

- .1 Ensure lugs, terminals, screws used for termination of wiring are suitable for copper conductors.

## 2.6 EQUIPMENT IDENTIFICATION

- .1 Identify electrical equipment with nameplates as follows:
- .1 Nameplates: lamicaid 3mm melamine, matt white finish face (red for fire alarm and emergency systems), black core, lettering accurately aligned and engraved into core mechanically attached with self tapping screws.
- .2 Sizes as follows:

### NAMEPLATE SIZES

Size 1	10 x 50 mm	1 line	3 mm high letters
Size 2	12 x 70 mm	1 line	5 mm high letters
Size 3	12 x 70 mm	2 lines	3 mm high letters
Size 4	20 x 90 mm	1 line	8 mm high letters
Size 5	20 x 90 mm	2 lines	5 mm high letters
Size 6	25 x 100 mm	1 line	12 mm high letters
Size 7	25 x 100 mm	2 lines	6 mm high letters

- .2 Labels: embossed plastic labels with 6 mm high letters unless specified otherwise.
- .3 Wording on nameplates and labels to be approved by Departmental Representative prior to manufacture.
- .4 Allow for minimum of twenty-five (25) letters per nameplate and label.
- .5 Nameplates for terminal cabinets and junction boxes to indicate system and/or voltage characteristics.
- .6 Identify equipment with Size 3 labels engraved "ASSET INVENTORY NO." as directed by Departmental Representative.
- .7 Disconnects, starters and contactors: indicate equipment being controlled and voltage.
- .8 Terminal cabinets and pull boxes: indicate system and voltage.

- .9 Transformers: indicate capacity, primary and secondary voltages.
- .10 Receptacles, furniture connections, light switches and lighting sensors: provide labels on coverplates to indicate panel and circuit number used.
- .11 Contractor to complete and submit BGIS CMMS (Computerized Maintenance Management System) forms for new, removed and modified equipment - BGIS CMMS forms to be submitted prior to Substantial Completion. Contractor to provide at start of project list or all BGIS CMMS equipment for removal or de-commissioning. Include completed BGIS CMMS inventory sheets in the O&M manual.

## 2.7 WIRING IDENTIFICATION

- .1 Identify wiring with coloured plastic tapes on both ends of phase conductors of feeders and branch circuit wiring.
- .2 Maintain phase sequence and colour coding throughout.
- .3 Colour coding: to CSA C22.1.
- .4 Use colour coded wires in communication cables, matched throughout system.

## 2.8 CONDUIT AND CABLE IDENTIFICATION

- .1 Colour code conduits, boxes and metallic sheathed cables.
- .2 Code with plastic tape or paint at points where conduit or cable enters wall, ceiling, or floor, and at 15 m intervals.
- .3 Colours: 25 mm wide prime colour and 20 mm wide auxiliary colour.

	Prime	Auxiliary
up to 250 V	Yellow	
up to 600 V	Yellow	Green
up to 5 kV	Yellow	Blue
up to 15 kV	Yellow	Red
Telephone	Green	
Other	Green	Blue

Communication Systems			
Fire Alarm	Red		
Emergency Voice	Red	Blue	
Other Security Systems	Red	Yellow	

2.9 FINISHES

- .1 Shop finish metal enclosure surfaces by application of rust resistant primer inside and outside, and at least two coats of finish enamel.
- .1 Paint outdoor electrical equipment "equipment green" finish.
- .2 Paint indoor switchgear and distribution enclosures light gray.

PART 3 - EXECUTION3.1 INSTALLATION

- .1 Do complete installation in accordance with CSA C22.1 except where specified otherwise.
- .2 Do overhead and underground systems in accordance with CAN/CSA-C22.3 No.1 except where specified otherwise.

3.2 NAMEPLATES AND LABELS

- .1 Ensure manufacturer's nameplates, CSA labels and identification nameplates are visible and legible after equipment is installed.

3.3 CONDUIT AND CABLE INSTALLATION

- .1 Install conduit and sleeves prior to pouring of concrete.
- .1 Sleeves through concrete: plastic, sized for free passage of conduit, and protruding 50 mm.
- .2 If plastic sleeves are used in fire rated walls or floors, remove before conduit installation.
- .3 Install cables, conduits and fittings embedded or plastered over, close to building structure so furring can be kept to minimum.

### 3.4 LOCATION OF OUTLETS

- .1 Locate outlets in accordance with Section 26 05 32 - Outlet Boxes, Conduit Boxes and Fittings.
- .2 Do not install outlets back-to-back in wall; allow minimum 150 mm horizontal clearance between boxes.
- .3 Change location of outlets at no extra cost or credit, providing distance does not exceed 3000 mm, and information is given before installation.
- .4 Locate light switches on latch side of doors.
  - .1 Locate disconnect devices in service rooms on latch side of door.

### 3.5 MOUNTING HEIGHTS

- .1 Mounting height of equipment is from finished floor to centreline of equipment unless specified or indicated otherwise.
- .2 If mounting height of equipment is not specified or indicated, verify before proceeding with installation.
- .3 Install electrical equipment at following heights unless indicated otherwise.
  - .1 Local switches: 1100 mm.
  - .2 Wall receptacles:
    - .1 General: 400 mm.
    - .2 Above top of continuous baseboard heater: 200 mm.
    - .3 Above top of counters or counter splash backs: 175 mm.
    - .4 In mechanical rooms: 1100 mm.
  - .3 Panelboards: as required by Code or as indicated.
  - .4 Telephone and interphone outlets: 400 mm.
  - .5 Wall mounted telephone and interphone outlets: 1100 mm.
  - .6 Fire alarm stations: 1200 mm.
  - .7 Fire alarm bells: 2300 mm, and 150 mm from top of device to ceiling.
  - .8 Television outlets: 400 mm.
  - .9 Wall mounted speakers: 2100 mm.
  - .10 Clocks: 2100 mm.
  - .11 Door bell pushbuttons: 1100 mm.

### 3.6 CO-ORDINATION OF PROTECTIVE DEVICES

- .1 Ensure circuit protective devices such as overcurrent trips, relays and fuses are installed to required values and settings.

### 3.7 FIELD QUALITY CONTROL

- .1 Load Balance:
  - .1 Measure phase current to panelboards with normal loads operating at time of acceptance; adjust branch circuit connections as required to obtain best balance of current between phases and record changes.
  - .2 Measure phase voltages at loads and adjust transformer taps to within 2% of rated voltage of equipment.
  - .3 Provide upon completion of work, load balance report as directed in PART 1 - ACTION AND INFORMATIONAL SUBMITTALS, phase and neutral currents on panelboards, dry-core transformers and motor control centres, operating under normal load, as well as hour and date on which each load was measured, and voltage at time of test.
- .2 Conduct following tests:
  - .1 Power distribution system including phasing, voltage, grounding and load balancing.
  - .2 Circuits originating from branch distribution panels.
  - .3 Lighting and its control.
  - .4 Motors, heaters and associated control equipment including sequenced operation of systems where applicable.
  - .5 Systems: fire alarm.
  - .6 Insulation resistance testing:
    - .1 Megger circuits, feeders and equipment up to 350 V with a 500 V instrument.
    - .2 Megger 350-600 V circuits, feeders and equipment with a 1000 V instrument.
    - .3 Check resistance to ground before energizing.
- .3 Carry out tests in presence of Departmental Representative.
- .4 Provide instruments, meters, equipment and personnel required to conduct tests during and at conclusion of project.
- .5 Manufacturer's Field Services:
  - .1 Obtain written report from manufacturer verifying compliance of Work, in handling, installing, applying, protecting and cleaning of product and submit Manufacturer's Field Reports as described in PART 1 - ACTION AND INFORMATIONAL SUBMITTALS.
  - .2 Provide manufacturer's field services consisting of product use recommendations and periodic site visits for inspection of product installation in accordance with manufacturer's instructions.

3.8 SYSTEM STARTUP

- .1 Instruct Departmental Representative and operating personnel in operation, care and maintenance of systems, system equipment and components.
- .2 Arrange and pay for services of manufacturer's factory service engineer to supervise start-up of installation, check, adjust, balance and calibrate components and instruct operating personnel.
- .3 Provide these services for such period, and for as many visits as necessary to put equipment in operation, and ensure that operating personnel are conversant with aspects of its care and operation.

3.9 CLEANING

- .1 Progress Cleaning:
  - .1 Leave Work area clean at end of each day.
- .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment.
- .3 Waste Management: separate waste materials for reuse and recycling.
  - .1 Remove recycling containers and bins from site and dispose of materials at appropriate facility.

END OF SECTION

---

PART 1 - GENERAL1.1 GENERAL  
REQUIREMENTS

- .1 Conform with requirements of front end Sections 00 and 01 as they apply to the work of this discipline.

1.2 GENERAL

- .1 This project shall be commissioned prior to substantial completion. A Commissioning Authority shall be present on behalf of the Departmental Representative and shall determine the commissioning requirements. A Commissioning Agent retained by the Contractor shall perform the commissioning activities, with assistance as required from this sub-contractor, and shall submit the results of these activities to the Commissioning Authority for review and acceptance.
- .2 The sub-contractor shall provide all required labour and materials to assist the Commissioning Agent in the completion of the commissioning activities and requirements.

PART 2 - PRODUCTS2.1 PRODUCTS

- .1 Not applicable.

PART 3 - EXECUTION3.1 Execution

- .1 Coordinate demonstration and verification of electrical systems with the Commissioning Agent. Invite Cx Departmental Representatives to participate in all commissioning activities.
- .2 Attend meetings with the Commissioning Agent as required to establish requirements for commissioning process throughout construction.
- .3 Perform the following key activities:
- .1 Submittals - submit shop drawings and product data sheets.
  - .2 Manufacturer's factory tests - submit results.
  - .3 Equipment start-up tests - perform and submit results.

- .4 Manufacturer's start-up tests - perform and submit results.
  - .5 Verify operation and performance of systems.
  - .6 Adjust and recommission systems as necessary to achieve specified performance.
  - .7 Load Balancing - complete and submit results.
  - .8 Maintenance and Operations Manual - prepare and submit.
  - .9 Instruction of operating staff - provide as necessary.
- .4 Refer to Commissioning Specifications Sections 01 91 13, 01 91 33, and 01 91 41 for a complete list of required activities.

END OF SECTION

---

PART 1 - GENERAL1.0 DEMOLITION

- .1 Full extent of demolition is not illustrated on drawings. Disconnect and remove all equipment located on existing ceilings and walls to be demolished. All services under equipment which have become redundant under the contract shall be removed. All items removed during demolition and which are not to be re-used shall be removed from site.
- .2 Contractor to relocate any electrical items which interfere with the new construction and may not appear on drawings.
- .3 All existing circuits no longer in use are to be removed, including all associated conduit and wire, back to source panel board.
- .4 Contractor is responsible for the reconnection of any services which are to remain and which have been disconnected during the course of demolition or construction.
- .5 All equipment to be re-used is to be cleaned of paint, plastic, etc. to the satisfaction of the Departmental Representative.
- .6 Contractor is responsible for reconnecting any existing loads which do not appear on panel details and which are to be re-used.
- .7 Where existing materials are to be re-used, the contractor is responsible for their removal, storage, cleaning and reinstallation.
- .8 Turn over to the Departmental Representative any redundant existing material or equipment designated by the Departmental Representative or specified on drawings.
- .9 Where some existing materials or equipment are to be retained in place or reconnected, it is the responsibility of the contractor to identify and protect the materials or equipment prior to the commencement of demolition.
- .10 Maintain adequate structural support for equipment and material during demolition process.
- .11 It is the responsibility of the Contractor to maintain electrical services and systems at all times to areas beyond the construction area.

- .12 Reinststate immediately any existing services disrupted during demolition not intended to be removed as part of this contract.
- .13 Retain continuity of service of the fire alarm system to all occupied areas of the building.

END OF SECTION

---

PART 1 - GENERAL1.1 REFERENCES

- .1 CSA International
  - .1 CAN/CSA-C22.2 No.18.1-13, Metallic Outlet Boxes.
  - .2 CAN/CSA-C22.2 No.65-13 Wire Connectors.
- .2 Electrical and Electronic Manufacturers' Association of Canada (EEMAC)
  - .1 EEMAC 1Y-2-1961, Bushing Stud Connectors and Aluminum Adapters (1200 Ampere Maximum Rating).
- .3 National Electrical Manufacturers Association (NEMA)

1.2 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submit in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
  - .1 Submit manufacturer's instructions, printed product literature and data sheets for wire and box connectors and include product characteristics, performance criteria, physical size, finish and limitations.

1.3 CLOSEOUT SUBMITTALS

- .1 Submit in accordance with Section 01 78 00 - Closeout Submittals.
- .2 Operation and Maintenance Data: submit operation and maintenance data for wire and box connectors for incorporation into manual.

PART 2 - PRODUCTS2.1 MATERIALS

- .1 Pressure type wire connectors to: CAN/CSA-C22.2 No.65, with current carrying parts of copper sized to fit copper conductors as required.
- .2 Fixture type splicing connectors to: CAN/CSA-C22.2 No.65, with current carrying parts of copper sized to fit copper conductors 10 AWG or less.
- .3 Bushing stud connectors: to EEMAC 1Y-2 to consist of:
  - .1 Connector body and stud clamp for copper conductors.

- .2 Clamp for copper conductors.
  - .3 Stud clamp bolts.
  - .4 Bolts for copper conductors.
  - .5 Sized for conductors as indicated.
- .4 Clamps or connectors for armoured cable, TECK cable flexible conduit, as required to: CAN/CSA-C22.2 No.18.

### PART 3 - EXECUTION

#### 3.1 INSTALLATION

- .1 Remove insulation carefully from ends of conductors and cables and:
- .1 Install mechanical pressure type connectors and tighten screws with appropriate compression tool recommended by manufacturer. Installation shall meet secureness tests in accordance with CAN/CSA-C22.2 No.65.
  - .2 Install fixture type connectors and tighten to CAN/CSA-C22.2 No.65. Replace insulating cap.
  - .3 Install bushing stud connectors in accordance with EEMAC 1Y-2.

END OF SECTION

---

PART 1 - GENERAL

- 1.1 PRODUCT DATA .1 Provide product data in accordance with Section 01 33 00 - Submittal Procedures.

PART 2 - PRODUCTS

- 2.1 BUILDING WIRES .1 Conductors shall be copper, stranded for 10 AWG and larger. Minimum size: 12 AWG.
- .2 Size as indicated, with 600 V insulation of cross-linked thermosetting polyethylene material rated RW90 XLPE or RWU90 XLPE, Non Jacketted.
- 2.2 TECK 90 CABLE .1 Cable: in accordance with Section 26 05 00 - Common Work Results for Electrical.
- .2 Conductors:  
.1 Grounding conductor: copper.  
.2 Circuit conductors: copper, size as indicated.
- .3 Insulation:  
.1 Cross-linked polyethylene XLPE.  
.2 Rating: 600 V.
- .4 Inner jacket: polyvinyl chloride material.
- .5 Armour: flat interlocking aluminum.
- .6 Overall covering: thermoplastic polyvinyl chloride.
- .7 Fastenings:  
.1 One hole steel straps to secure surface cables 50 mm and smaller. Two hole steel straps for cables larger than 50 mm.  
.2 Channel type supports for two or more cables.  
.3 Threaded rods: 6 mm diameter to support suspended channels.
- .8 Connectors:  
.1 Watertight, approved for TECK cable.

- 
- 2.3 ARMoured CABLES
- .1 Conductors: insulated, copper, size as indicated.
  - .2 Type: AC90.
  - .3 Armour: interlocking type fabricated from aluminum strip.
  - .4 Connectors: anti short connectors.
- 2.4 CONTROL CABLES
- .1 Type: LVT: 2 soft annealed copper conductors, sized as indicated:
    - .1 Insulation: thermoplastic.
    - .2 Sheath : thermoplastic jacket, FT-6 rated.
  - .2 Fire Alarm and signal cables: Type FAS105, 300V.
  - .3 Type: 600 V stranded copper conductors, minimum size 16AWG.
    - .1 Insulation: RW90 (x-link).
- PART 3 - EXECUTION
- 3.1 FIELD QUALITY CONTROL
- .1 Perform tests in accordance with Section 26 05 00 - Common Work Results for Electrical.
  - .2 Perform tests using method appropriate to site conditions and to approval of Departmental Representative and local authority having jurisdiction over installation.
  - .3 Perform tests before energizing electrical system.
- 3.2 GENERAL CABLE INSTALLATION
- .1 Terminate cables in accordance with Section 26 05 20 - Wire and Box Connectors - (0-1000 V).
  - .2 Cable Colour Coding: to Section 26 05 00 - Common Work Results for Electrical.
  - .3 Conductor length for parallel feeders to be identical.
  - .4 Lace or clip groups of feeder cables at distribution centres, pull boxes, and termination points.
  - .5 Wiring in walls: typically drop or loop vertically from above to better facilitate future renovations. Generally wiring from below and horizontal wiring in walls to be avoided unless indicated.

- 
- .6 Branch circuit wiring for surge suppression receptacles and permanently wired computer and electronic equipment, dimmed lighting and dedicated circuits to be 2-wire circuits only, i.e. common neutrals not permitted.
- .7 Provide numbered wire collars for control wiring. Numbers to correspond to control shop drawing legend. Obtain wiring diagram for control wiring.
- 3.3 INSTALLATION OF BUILDING WIRES
- .1 Install wiring as follows:
- .1 In conduit systems in accordance with Section 26 05 34 - Conduits, Conduit Fastenings and Conduit Fittings.
- 3.4 INSTALLATION OF TECK90 CABLE (0 -1000 V)
- .1 Group cables wherever possible on channels.
- .2 Install cable, securely supported by straps.
- 3.5 INSTALLATION OF ARMOURED CABLES
- .1 Group cables wherever possible on channels.
- .2 Use only above ceiling for interconnection from light fixture to light fixture, 3 meter maximum length.
- 3.6 INSTALLATION OF CONTROL CABLES
- .1 Install control cables in conduit.
- .2 Ground control cable shield.

END OF SECTION

---

PART 1 - GENERAL

- 1.1 REFERENCES .1 American National Standards Institute /Institute of Electrical and Electronics Engineers ( ANSI/IEEE )  
.1 ANSI/IEEE 837-02, IEEE Standard for Qualifying Permanent Connections Used in Substation Grounding.
- 1.2 ACTION AND INFORMATIONAL SUBMITTALS .1 Submit in accordance with Section 01 33 00 - Submittal Procedures.  
.2 Product Data:  
.1 Submit manufacturer's instructions, printed product literature and data sheets for grounding equipment and include product characteristics, performance criteria, physical size, finish and limitations.
- 1.3 CLOSEOUT SUBMITTALS .1 Submit in accordance with Section 01 78 00 - Closeout Submittals.  
.2 Operation and Maintenance Data: submit operation and maintenance data for grounding equipment for incorporation into manual.

PART 2 - PRODUCTS

- 2.1 EQUIPMENT .1 Clamps for grounding of conductor: size as required.  
.2 Grounding conductors: bare stranded copper, soft annealed, size as indicated.  
.3 Insulated grounding conductors: green, copper conductors, size as indicated.  
.4 Ground bus: copper, size as indicated, complete with insulated supports, fastenings, connectors.  
.5 Non-corroding accessories necessary for grounding system, type, size, material as indicated, including but not necessarily limited to:  
.1 Grounding and bonding bushings.  
.2 Protective type clamps.  
.3 Bolted type conductor connectors.  
.4 Thermit welded type conductor connectors.

- .5 Bonding jumpers, straps.
- .6 Pressure wire connectors.

### PART 3 - EXECUTION

#### 3.1 INSTALLATION GENERAL

- .1 Install complete permanent, continuous grounding system including conductors, connectors and accessories. Install insulated ground wire in all conduit.
- .2 Install connectors in accordance with manufacturer's instructions.
- .3 Protect exposed grounding conductors from mechanical injury.
- .4 Use mechanical connectors for grounding connections to equipment provided with lugs.
- .5 Soldered joints not permitted.
- .6 Install bonding wire for flexible conduit, connected at both ends to grounding bushing, solderless lug, clamp or cup washer and screw. Neatly cleat bonding wire to exterior of flexible conduit.
- .7 Install flexible ground straps for bus duct enclosure joints, where such bonding is not inherently provided with equipment.
- .8 Make grounding connections in radial configuration only, with connections terminating at single grounding point. Avoid loop connections.

#### 3.2 SYSTEM AND CIRCUIT GROUNDING

- .1 Install system and circuit grounding connections to neutral of secondary system.

#### 3.3 EQUIPMENT GROUNDING

- .1 Install grounding connections as required and as shown.

#### 3.4 GROUNDING BUS

- .1 Install copper grounding bus mounted on insulated supports on wall of electrical room and communication equipment room.

- .2 Ground items of electrical equipment in electrical room and IT equipment in communication equipment room to ground bus with individual bare stranded copper connections size 2/0AWG.

3.5 FIELD QUALITY CONTROL

- .1 Perform tests in accordance with Section 26 05 00 - Common Work Results for Electrical.
- .2 Perform ground continuity and resistance tests using method appropriate to site conditions and to approval of Departmental Representative and local authority having jurisdiction over installation.
- .3 Perform tests before energizing electrical system.
- .4 Disconnect ground fault indicator during tests.

END OF SECTION

PART 1 - GENERAL

- 1.1 RELATED REQUIREMENTS .1 Section 26 05 00 - Common Work Results for Electrical.

PART 2 - PRODUCTS

- 2.1 SUPPORT CHANNELS .1 U shape, size 41 x 41 mm, 2.5 mm thick, surface Mounted.

PART 3 - EXECUTION

- 3.1 INSTALLATION .1 Secure equipment to masonry, tile and plaster surfaces with nylon shields.
- .2 Secure equipment to poured concrete with expandable inserts.
- .3 Secure equipment to hollow masonry walls or suspended ceilings with toggle bolts.
- .4 Secure surface mounted equipment with twist clip fasteners to inverted T bar ceilings. Ensure that T bars are adequately supported to carry weight of equipment specified before installation.
- .5 Support equipment, conduit or cables using clips, spring loaded bolts, cable clamps designed as accessories to basic channel members.
- .6 Fasten exposed conduit or cables to building construction or support system using straps.
- .1 One-hole steel straps to secure surface conduits and cables 50 mm and smaller.
- .2 Two-hole steel straps for conduits and cables larger than 50 mm.
- .3 Beam clamps to secure conduit to exposed steel work.
- .7 Suspended support systems.
- .1 Support individual cable or conduit runs with 6 mm dia threaded rods and spring clips.
- .2 Support 2 or more cables or conduits on channels supported by 6 mm dia threaded rod hangers where direct fastening to building construction is impractical.

- 
- .8 Provide metal brackets, frames, hangers, clamps and related types of support structures where indicated or as required to support conduit and cable runs.
  - .9 Ensure adequate support for raceways and cables dropped vertically to equipment where there is no wall support.
  - .10 Do not use wire lashing or perforated strap to support or secure raceways or cables.
  - .11 Do not use supports or equipment installed for other trades for conduit or cable support.
  - .12 Install fastenings and supports as required for each type of equipment cables and conduits, and in accordance with manufacturer's installation recommendations.

END OF SECTION

PART 1 - GENERAL

- 1.1 ACTION AND INFORMATIONAL SUBMITTALS .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.

PART 2 - PRODUCTS

- 2.1 SPLITTERS .1 Construction: sheet metal enclosure, welded corners and formed hinged cover suitable for locking in closed position.
- .2 Terminations: main and branch lugs to match required size and number of incoming and outgoing conductors as indicated.
- .3 Spare Terminals: minimum three spare terminals or lugs on each connection or lug block sized less than 400 A.
- 2.2 JUNCTION AND PULL BOXES .1 Construction:welded steel enclosure.
- .2 Covers Flush Mounted: 25 mm minimum extension all around.
- .3 Covers Surface Mounted: screw-on flat covers.
- 2.3 CABINETS .1 Construction: welded sheet steel hinged door, latch lock 2 keys and catch
- .2 Type E Empty: surface return flange mounting as indicated.
- .3 Type T Terminal: surface return flange mounting as indicated containing 19 mm G1S plywood backboard.

PART 3 - EXECUTION3.1 SPLITTER  
INSTALLATION

- .1 Mount plumb, true and square to building lines.
- .2 Extend splitters full length of equipment arrangement except where indicated otherwise.

3.2 JUNCTION, PULL  
BOXES AND CABINETS  
INSTALLATION

- .1 Install pull boxes in inconspicuous but accessible locations.
- .2 Mount cabinets with top not higher than 2 m above finished floor except where indicated otherwise.
- .3 Install terminal block in Type T cabinets.
- .4 Only main junction and pull boxes are indicated. Install additional pull boxes as required by CSA C22.1.

3.3 IDENTIFICATION

- .1 Equipment Identification: to Section 26 05 00- Common Work Results for Electrical .
- .2 Identification Labels: size 2 indicating voltage and phase or as indicated.

END OF SECTION

PART 1 - GENERAL

1.1 ACTION AND INFORMATIONAL SUBMITTALS .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.

PART 2 - PRODUCTS

2.1 OUTLET AND CONDUIT BOXES GENERAL .1 Size boxes in accordance with CSA C22.1.  
.2 102 mm square or larger outlet boxes as required.  
.3 Gang boxes where wiring devices are grouped.  
.4 Blank cover plates for boxes without wiring devices.  
.5 347 V outlet boxes for 347 V switching devices.  
.6 Combination boxes with barriers where outlets for more than one system are grouped.

2.2 MASONRY BOXES .1 Electro-galvanized steel masonry single and multi gang boxes for devices flush mounted in exposed block walls.

2.3 CONCRETE BOXES .1 Electro-galvanized sheet steel concrete type boxes for flush mount in concrete with matching extension and plaster rings as required.

2.4 FLOOR BOXES .1 Fire rated poke through with devices as indicated, flush mounted.

2.5 CONDUIT BOXES .1 Cast FS boxes with factory-threaded hubs and mounting feet for surface wiring of devices.

2.6 FITTINGS - GENERAL .1 Bushing and connectors with nylon insulated throats.  
.2 Knock-out fillers to prevent entry of debris.

- .3 Conduit outlet bodies for conduit up to 35mm and pull boxes for larger conduits.
- .4 Double locknuts and insulated bushings on sheet metal boxes.

### PART 3 - EXECUTION

#### 3.1 INSTALLATION

- .1 Support boxes independently of connecting conduits.
- .2 Fill boxes with paper, sponges or foam or similar approved material to prevent entry of debris during construction. Remove upon completion of work.
- .3 For flush installations mount outlets flush with finished wall using plaster rings to permit wall finish to come within 6 mm of opening.
- .4 Provide correct size of openings in boxes for conduit, mineral insulated and armoured cable connections. Do not install reducing washers.
- .5 Vacuum clean interior of outlet boxes before installation of wiring devices.
- .6 Identify systems for outlet boxes as required.

END OF SECTION

PART 1 - GENERAL1.1 REFERENCES

- .1 Canadian Standards Association (CSA International)
  - .1 CAN/CSA C22.2 No. 18.1-13, Metallic Outlet Boxes.
  - .2 CSA C22.2 No. 45-07(R2012), Rigid Metal Conduit.
  - .3 CSA C22.2 No. 56-13, Flexible Metal Conduit and Liquid-Tight Flexible Metal Conduit.
  - .4 CSA C22.2 No. 83-M1985(R2013), Electrical Metallic Tubing.
  - .5 CSA C22.2 No. 211.2-06(R2011), Rigid PVC (Unplasticized) Conduit.

1.2 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.

PART 2 - PRODUCTS2.1 CABLES AND REELS

- .1 Provide cables on reels or coils.
  - .1 Mark or tag each cable and outside of each reel or coil, to indicate cable length, voltage rating, conductor size, and manufacturer's lot number and reel number.
- .2 Each coil or reel of cable to contain only one continuous cable without splices.
- .3 Identify cables for exclusively dc applications.

2.2 CONDUITS

- .1 Rigid metal conduit: to CSA C22.2 No. 45, hot dipped galvanized steel threaded.
- .2 Epoxy coated conduit: to CSA C22.2 No. 45, with zinc coating and corrosion resistant epoxy finish inside and outside.
- .3 Electrical metallic tubing (EMT): to CSA C22.2 No. 83, with couplings.
- .4 Rigid pvc conduit: to CSA C22.2 No. 211.2.
- .5 Flexible metal conduit: to CSA C22.2 No. 56, liquid-tight flexible metal.

---

.6 Flexible pvc conduit: to CAN/CSA-C22.2 No. 227.3.

### 2.3 CONDUIT FASTENINGS

- .1 One hole steel straps to secure surface conduits 50 mm and smaller.  
.1 Two hole steel straps for conduits larger than 50 mm.
- .2 Beam clamps to secure conduits to exposed steel work.
- .3 Channel type supports for two or more conduits.
- .4 Threaded rods, 6 mm diameter, to support suspended channels.

### 2.4 CONDUIT FITTINGS

- .1 Fittings: to CAN/CSA C22.2 No. 18, manufactured for use with conduit specified. Coating: same as conduit.
- .2 Ensure factory "ells" where 90 degrees bends for 25 mm and larger conduits.
- .3 Set-screw connectors and couplings for EMT.

### 2.5 EXPANSION FITTINGS FOR RIGID CONDUIT

- .1 Weatherproof expansion fittings with internal bonding assembly suitable for 100 mm linear expansion.
- .2 Watertight expansion fittings with integral bonding jumper suitable for linear expansion and 19 mm deflection.
- .3 Weatherproof expansion fittings for linear expansion at entry to panel.

### 2.6 FISH CORD

- .1 Polypropylene.

---

PART 3 - EXECUTION3.1 MANUFACTURER'S  
INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheets.

3.2 INSTALLATION

- .1 Install conduits to conserve headroom in exposed locations and cause minimum interference in spaces through which they pass.
- .2 Conceal conduits except in mechanical and electrical service rooms and in unfinished areas.
- .3 Surface mount conduits except within partitions.
- .4 Use rigid hot dipped galvanized steel threaded conduit where subject to mechanical injury.
- .5 Use electrical metallic tubing (EMT) except in cast concrete above 2.4 m not subject to mechanical injury.
- .6 Use rigid pvc conduit underground and in corrosive areas.
- .7 Use flexible metal conduit for connection to motors in dry areas, to surface or recessed fluorescent fixtures, and for vertical drops from slab box to fire alarm audible devices.
- .8 Use liquid tight flexible metal conduit for connection to motors or vibrating equipment in damp, wet or corrosive locations.
- .9 Use explosion proof flexible connection for connection to explosion proof motors.
- .10 Install conduit sealing fittings in hazardous areas.
  - .1 Fill with compound.
- .11 Minimum conduit size for lighting and power circuits shall be 21mm, and 27mm for communications.
- .12 Bend conduit cold:
  - .1 Replace conduit if kinked or flattened more than 1/10th of its original diameter.
- .13 Mechanically bend steel conduit over 19 mm diameter.

- .14 Field threads on rigid conduit must be of sufficient length to draw conduits up tight.
- .15 Install fish cord in empty conduits.
- .16 Run 2- 25 mm spare conduits up to ceiling space from each flush panel.
  - .1 Terminate these conduits in 152 x 152 x 102 mm junction boxes in ceiling space or in case of an exposed concrete slab, terminate each conduit in surface type box.
- .17 Remove and replace blocked conduit sections.
  - .1 Do not use liquids to clean out conduits.
- .18 Dry conduits out before installing wire.

### 3.3 SURFACE CONDUITS

- .1 Run parallel or perpendicular to building lines.
- .2 Locate conduits behind infrared or gas fired heaters with 1.5 m clearance.
- .3 Run conduits in flanged portion of structural steel.
- .4 Group conduits wherever possible on channels.
- .5 Do not pass conduits through structural members except as indicated.
- .6 Do not locate conduits less than 75 mm parallel to steam or hot water lines with minimum of 25 mm at crossovers.

### 3.4 CONCEALED CONDUITS

- .1 Run parallel or perpendicular to building lines.
- .2 Do not install horizontal runs in masonry walls.
- .3 Do not install conduits in terrazzo or concrete toppings.

### 3.5 CONDUITS UNDERGROUND

- .1 Slope conduits to provide drainage.
- .2 Waterproof joints (pvc excepted) with heavy coat of bituminous paint.

END OF SECTION

PART 1 - GENERAL1.1 REFERENCES

- .1 Canadian Standards Association (CSA International)  
.1 CSA C22.2 No.184.1-96(R2011), Solid-State Dimming Controls.

1.2 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.

PART 2 - PRODUCTS2.1 FULL RANGE DIMMER

- .1 Line voltage dimmer : for incandescent and LED sources, to CSA C22.2 No.184.1, designed to produce 0% to 100% brightness control by means of single dial and to provide smooth and continuous square law dimming curve, and:
- .1 Fit single-gang standard switch box.
  - .2 Gangable without removing side sections or derating capacity.
  - .3 Advanced solid-state circuitry providing symmetrical ac wave form to input of low voltage magnetic and electronic transformers, when used.
  - .4 Two moving parts:
    - .1 Single pole or Three way switch.
    - .2 Long life potentiometer.
  - .5 Push to turn ON or OFF without disturbing preselected brightness setting.
  - .6 Rated: 1000 W at 120 V, ac.
  - .7 Voltage regulated to maintain plus or minus 5% light output variation with plus or minus 10% line voltage variation.
  - .8 No perceptible flicker in dimming range and no perceptible humming.
  - .9 Audio/Radio/TV interference filter.
  - .10 Operate at ambient temperature of 0 to 40 degrees C.
- .2 0-10 volt dimmers: performance to match line voltage dimmers, to suit 0-10 V LED dimming drivers and fluorescent dimming ballasts.

---

PART 3 - EXECUTION3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheets.

3.2 INSTALLATION

- .1 Install dimmers in accordance with manufacturer's instructions.
- .2 Connect lamp circuits to dimmer.
- .3 Provide appropriate dimmer type to match load to be dimmed, confirm dimmed load type prior to ordering dimmers.

3.3 FIELD QUALITY CONTROL

- .1 Perform tests in accordance with Section 26 05 00 - Common Work Results for Electrical.
- .2 Demonstrate that dimming systems are installed as indicated.
- .3 Demonstrate that dimming systems:
  - .1 Operate as intended.
  - .2 That there are no problems in starting lamps, nor in keeping them lit.
  - .3 That they flicker-free at any setting of dimming intensity control.
- .4 Demonstrate that no audio, radio or TV interference is carried by system.

END OF SECTION

---

PART 1 - GENERAL

- 1.1 REFERENCES .1 CSA International  
.1 CSA C22.2 No.29-11, Panelboards and Enclosed Panelboards.
- 1.2 ACTION AND INFORMATIONAL SUBMITTALS .1 Submit in accordance with Section 01 33 00 - Submittal Procedures.  
.2 Shop Drawings:  
.1 Include on drawings:  
.1 Electrical detail of panel, branch breaker type, quantity, ampacity and enclosure dimension.
- 1.3 CLOSEOUT SUBMITTALS .1 Submit in accordance with Section 01 78 00 - Closeout Submittals.  
.2 Operation and Maintenance Data: submit operation and maintenance data for panelboards for incorporation into manual.
- 1.4 DELIVERY, STORAGE AND HANDLING .1 Deliver, store and handle materials in accordance with manufacturer's written instructions.

PART 2 - PRODUCTS

- 2.1 PANELBOARDS .1 Panelboards: to CSA C22.2 No.29 and product of one manufacturer.  
.1 Install circuit breakers in panelboards before shipment.  
.2 In addition to CSA requirements manufacturer's nameplate must show fault current that panel including breakers has been built to withstand.
- .2 250 V panelboards: bus and breakers rated for 10,000 A (symmetrical) interrupting capacity or as indicated.
- .3 600 V panelboards: bus and breakers rated for 14,000 A (symmetrical) interrupting capacity or as indicated.

- .4 Sequence phase bussing with odd numbered breakers on left and even on right, with each breaker identified by permanent number identification as to circuit number and phase.
- .5 Panelboards: mains, number of circuits, and number and size of branch circuit breakers as indicated.
- .6 Minimum of 2 flush locks for each panel board.
- .7 Two keys for each panelboard and key panelboards alike.
- .8 Copper bus with neutral of same ampere rating of mains.
- .9 Mains: suitable for bolt-on breakers.
- .10 Trim with concealed front bolts and hinges.
- .11 Trim and door finish: baked enamel.
- .12 CSA Type 1 enclosure in non-sprinklered buildings, CSA Type 2 enclosure in sprinklered buildings.

## 2.2 BREAKERS

- .1 Breakers: to Section 26 28 16.02 - Moulded Case Circuit Breakers.
- .2 Breakers with thermal and magnetic tripping in panelboards except as indicated otherwise.
- .3 Main breaker: separately mounted on top or bottom of panel to suit cable entry. When mounted vertically, down position should open breaker.
- .4 Lock-on devices for fire alarm, exit and emergency light circuits.

## 2.3 EQUIPMENT IDENTIFICATION

- .1 Provide equipment identification in accordance with Section 26 05 00 - Common Work Results for Electrical.
- .2 Nameplate for each panelboard size 4 engraved as indicated.
- .3 Nameplate for each circuit in distribution panelboards size 2 engraved as indicated.

- 
- .4 Complete circuit directory with typewritten legend showing location and load of each circuit, mounted in plastic envelope at inside of panel door.

### PART 3 - EXECUTION

#### 3.1 INSTALLATION

- .1 Locate panelboards as indicated and mount securely, plumb, true and square, to adjoining surfaces.
- .2 Install surface mounted panelboards on plywood backboards. Where practical, group panelboards on common backboard.
- .3 Mount panelboards to height specified in Section 26 05 00 - Common Work Results for Electrical or as indicated.
- .4 Connect loads to circuits.
- .5 Connect neutral conductors to common neutral bus with respective neutral identified.

#### 3.2 PROTECTION

- .1 Protect installed products and components from damage during construction.
- .2 Repair damage to adjacent materials caused by panelboards installation.

END OF SECTION

---

PART 1 - GENERAL1.1 REFERENCES

- .1 ASTM International
  - .1 ASTM B 317/B 317M-07, Standard Specification for Aluminum-Alloy Extruded Bar, Rod, Tube, Pipe, Structural Profiles and Profiles for Electrical Purposes (Bus Conductor).

1.2 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submit in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
  - .1 Submit manufacturer's instructions, printed product literature and data sheets for indoor service poles and include product characteristics, performance criteria, physical size, finish and limitations.

1.3 CLOSEOUT SUBMITTALS

- .1 Submit in accordance with Section 01 78 00 - Closeout Submittals.
- .2 Operation and Maintenance Data: submit operation and maintenance data for indoor service poles for incorporation into manual.

PART 2 - PRODUCTS2.1 INDOOR SERVICE POLES

- .1 Indoor service poles: extruded aluminum sections to ASTM B 317/B 317M anodized finish.
- .2 Nominal length of poles: to suit floor to ceiling, with plus or minus 50 mm adjustment. Total adjustment: 100 mm.
- .3 Service poles approximately 50 mm square with snap-on covers to provide access to wiring without removing unit. Barrier to isolate power from communication systems.
- .4 Include fastening accessories at top of pole to secure to inverted T-Bar ceiling using set screws to permit relocation.
  - .1 Flange at ceiling to conceal wiring.

- 
- .5 Sleeve at bottom of pole to conceal vertical adjustment.
    - .1 Include grip-tight devices for carpet and tile floors to prevent movement of poles.
  - .6 Service poles with two prewired duplex receptacles, four knockout holes for communication jacks.
    - .1 No.12 AWG leads terminating in utility box with cover, mounted at top of pole, for hard-wired connections (no molded plug connections).

### PART 3 - EXECUTION

#### 3.1 INSTALLATION

- .1 Install service poles in accordance with manufacturer's recommendations. Secure to ceiling and to finished floor.
  - .1 Adjust length as required.
  - .2 Make power connections in utility box at top of pole.
- .2 Re-adjust service poles as required after communication cables are installed.

#### 3.2 PROTECTION

- .1 Protect installed products and components from damage during construction.
- .2 Repair damage to adjacent materials caused by indoor service poles installation.

END OF SECTION

---

PART 1 - GENERAL1.1 REFERENCES

- .1 CSA International
  - .1 CSA C22.2 No.42-10, General Use Receptacles, Attachment Plugs and Similar Devices.
  - .2 CAN/CSA C22.2 No.42.1-13 Cover Plates for Flush-Mounted Wiring Devices (Bi-national standard, with UL 514D).
  - .3 CSA C22.2 No.111-10, General-Use Snap Switches (Bi-national standard, with UL 20).

1.2 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submit in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
  - .1 Submit manufacturer's instructions, printed product literature and data sheets for wiring devices and include product characteristics, performance criteria, physical size, finish and limitations.

1.3 CLOSEOUT SUBMITTALS

- .1 Submit in accordance with Section 01 78 00 - Closeout Submittals.
- .2 Operation and Maintenance Data: submit operation and maintenance data for wiring devices for incorporation into manual.

PART 2 - PRODUCTS2.1 SWITCHES

- .1 20 A, 120 V and 347 V, single pole, three-way, switches to: CSA C22.2 No.55 and CSA C22.2 No.111.
- .2 Manually-operated general purpose AC switches with following features:
  - .1 Terminal holes approved for No. 10 AWG wire.
  - .2 Silver alloy contacts.
  - .3 Urea or melamine moulding for parts subject to carbon tracking.
  - .4 Suitable for back and side wiring.
  - .5 Ivory toggle.
- .3 Toggle operated fully rated for tungsten filament and fluorescent lamps, and up to 80% of rated capacity of motor loads or heating loads.

---

.4 Switches of one manufacturer throughout project.

## 2.2 OCCUPANCY SENSORS

- .1 Sensors of one manufacturer throughout project.
- .2 Dual technology infra-red and ultrasonic wall switch sensors, with manual 'off' override. Colour to match wiring devices colour.
- .3 Dual technology infrared and ultrasonic ceiling mounted sensors, colour to match wiring devices.
- .4 Complete with power and auxiliary relay packs unless otherwise indicated.
- .5 Occupancy sensor to have 0 to 30 minute adjustable time delay, set to 20 minutes default.

## 2.3 RECEPTACLES

- .1 Duplex receptacles, CSA type 5-15 R, 125 V, 15 A, U ground, to: CSA C22.2 No.42 with following features:
- .1 Ivory urea moulded housing except black for house keeping.
  - .2 Suitable for No. 10 AWG for back and side wiring.
  - .3 Break-off links for use as split receptacles.
  - .4 Eight back wired entrances, four side wiring screws.
  - .5 Triple wipe contacts and rivetted grounding contacts.
- .2 Single receptacles CSA type 5-15 R, 125 V, 15 A, U ground with following features:
- .1 Ivory urea moulded housing.
  - .2 Suitable for No. 10 AWG for back and side wiring.
  - .3 Four back wired entrances, 2 side wiring screws.
- .3 Other receptacles with ampacity and voltage as indicated.
- .4 Receptacles of one manufacturer throughout project.

## 2.4 SPECIAL WIRING DEVICES

- .1 Special wiring devices:
- .1 Clock hanger outlets, 15 A, 125 V, 3 wire, grounding type, suitable for No. 10 AWG for installation in flush outlet box.
  - .2 Pilot lights as indicated, with neon type 0.04 W, 125 V lamp and red plastic jewel flush type.

.3 Low voltage switches of same appearance and design as existing building standard, compatible with existing relay control system.

## 2.5 COVER PLATES

- .1 Cover plates for wiring devices to: CSA C22.2 No.42.1.
- .2 Sheet steel utility box cover for wiring devices installed in surface-mounted utility boxes.
- .3 Stainless steel, vertically brushed, 1 mm thick cover plates for wiring devices mounted in flush-mounted outlet box.
- .4 Sheet metal cover plates for wiring devices mounted in surface-mounted FS or FD type conduit boxes.
- .5 Weatherproof double lift spring-loaded cast aluminum cover plates, complete with gaskets for duplex receptacles as indicated.
- .6 Weatherproof spring-loaded cast aluminum cover plates complete with gaskets for single receptacles or switches.

## 2.6 SOURCE QUALITY CONTROL

- .1 Cover plates from one manufacturer throughout project.

## PART 3 - EXECUTION

### 3.1 INSTALLATION

- .1 Switches:
  - .1 Install single throw switches with handle in "UP" position when switch closed.
  - .2 Install switches in gang type outlet box when more than one switch is required in one location.
  - .3 Mount toggle switches at height in accordance with Section 26 05 00 - Common Work Results for Electrical or as indicated.
- .2 Receptacles:
  - .1 Install receptacles in gang type outlet box when more than one receptacle is required in one location.
  - .2 Mount receptacles at height in accordance with Section 26 05 00 - Common Work Results for Electrical or as indicated.

.3 Where split receptacle has one portion switched, mount vertically and switch upper portion.

.4 Install GFI type receptacles as indicated.

.3 Occupancy Sensors:

.1 Coordinate with other trades so that wall switch sensors are not located below thermostats or temperature sensors.

.4 Cover plates:

.1 Install suitable common cover plates where wiring devices are grouped.

.2 Do not use cover plates meant for flush outlet boxes on surface-mounted boxes.

### 3.2 PROTECTION

.1 Protect installed products and components from damage during construction.

.2 Protect stainless steel cover plate finish with paper or plastic film until painting and other work is finished.

.3 Repair damage to adjacent materials caused by wiring device installation.

END OF SECTION

---

PART 1 - GENERAL

- 1.1 ACTION AND INFORMATIONAL SUBMITTALS
- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
  - .2 Product Data:
    - .1 Provide fuse performance data characteristics for each fuse type and size above 100 A. Performance data to include: average melting time-current characteristics.
- 1.2 DELIVERY, STORAGE AND HANDLING
- .1 Ship fuses in original containers.
  - .2 Do not ship fuses installed in switchboard.
  - .3 Store fuses in original containers in moisture free location.
- 1.3 EXTRA MATERIALS
- .1 Provide maintenance materials in accordance with Section 01 78 00 - Closeout Submittals.
  - .2 Three spare fuses of each type and size installed above 600 A.
  - .3 Six spare fuses of each type and size installed up to and including 600 A.

PART 2 - PRODUCTS

- 2.1 FUSES - GENERAL
- .1 Fuse type references L1, L2, J1, R1, etc. have been adopted for use in this specification.
  - .2 Fuses: product of one manufacturer.
- 2.2 FUSE TYPES
- .1 Class L fuses: use for fuses over 600A.
    - .1 Type L1, time delay, capable of carrying 500% of its rated current for 10 s minimum.
    - .2 Type L2, fast acting.

- 
- .2 Class J fuses: use for fuses 600A and below.
    - .1 Type J1, time delay, capable of carrying 500% of its rated current for 10 s minimum.

### PART 3 - EXECUTION

#### 3.1 INSTALLATION

- .1 Install fuses in mounting devices immediately before energizing circuit.
- .2 Ensure correct fuses fitted to physically matched mounting devices.
- .3 Ensure correct fuses fitted to assigned electrical circuit.
- .4 Install spare fuses in fuse storage cabinet.

END OF SECTION

---

PART 1 - GENERAL1.1 REFERENCES

- .1 CSA International
  - .1 CSA C22.2 No. 5-13, Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures (Tri-national standard with UL 489, and NMX-J-266-ANCE-2010).

1.2 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submit in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
  - .1 Submit manufacturer's instructions, printed product literature and data sheets for circuit breakers and include product characteristics, performance criteria, physical size, finish and limitations.
- .3 Include time-current characteristic curves for breakers with ampacity of 100 A and over or with interrupting capacity of 22,000 A symmetrical (rms) and over at system voltage.
- .4 Certificates:
  - .1 Prior to installation of circuit breakers in either new or existing installation, Contractor must submit 3 copies of a production certificate of origin from the manufacturer. Production certificate of origin must be duly signed by factory and local manufacturer's representative certifying that circuit breakers come from this manufacturer and are new and meet standards and regulations.
    - .1 Production certificate of origin must be submitted to Departmental Representative for approval.
    - .2 Delay in submitting production of certificate of origin will not justify any extension of contract and additional compensation.
    - .3 Any work of manufacturing, assembly or installation to begin only after acceptance of production certificate of origin by Departmental Representative. Unless complying with this requirement, Departmental Representative reserves the right to mandate manufacturer listed on circuit breakers to authenticate new circuit breakers under the contract, and to Contractor's expense.
  - .4 Production certificate of origin must contain:
    - .1 Manufacturer's name and address and person responsible for authentication. Person responsible must sign and date certificate.

- .2 Licensed dealer's name and address and person of distributor responsible for Contractor's account.
- .3 Contractor's name and address and person responsible for project.
- .4 Local manufacturer's representative name and address. Local manufacturer's representative must sign and date certificate.
- .5 Name and address of building where circuit breakers will be installed:
  - .1 Project title
  - .2 End user's reference number.
  - .3 List of circuit breakers.

## PART 2 - PRODUCTS

### 2.1 BREAKERS GENERAL

- .1 Moulded-case circuit breakers and ground-fault circuit-interrupters: to CSA C22.2 No. 5
- .2 Bolt-on moulded case circuit breaker: quick- make, quick-break type, for manual and automatic operation with temperature compensation for 40 degrees C ambient.
- .3 Common-trip breakers: with single handle for multi-pole applications.
- .4 Magnetic instantaneous trip elements in circuit breakers to operate only when value of current reaches setting.
  - .1 Trip settings on breakers with adjustable trips to range from 3-8 times current rating.
- .5 Circuit breakers with interchangeable trips.
- .6 Circuit breakers to have minimum symmetrical rms interrupting capacity rating to match panels in which they are to be installed.

### 2.2 THERMAL MAGNETIC BREAKERS

- .1 Moulded case circuit breaker to operate automatically by means of thermal and magnetic tripping devices to provide inverse time current tripping and instantaneous tripping for short circuit protection.

2.3 OPTIONAL  
FEATURES

- .1 Include:
  - .1 Shunt trip.
  - .2 On-off locking device.

PART 3 - EXECUTION3.1 INSTALLATION

- .1 Install circuit breakers as indicated.

END OF SECTION

PART 1 - GENERAL1.1 REFERENCES

- .1 CSA Group
  - .1 CAN/CSA-C22.2 No.4-04(R2009), Enclosed and Dead-Front Switches (Tri-National Standard, with ANCE NMX-J-162-2004 and UL 98).
  - .2 CSA C22.2 No.39-13, Fuseholder Assemblies.

1.2 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submit in accordance with Section 01 33 00 - Submittal procedures.
- .2 Product Data:
  - .1 Submit manufacturer`s instructions, printed product literature and data sheets for disconnect switches - fused and non-fused and include product characteristics, performance criteria, physical size, finish and limitations.

PART 2 - PRODUCTS2.1 DISCONNECT SWITCHES

- .1 Fusible, Non-fusible, Horsepower rated disconnect switch in CSA enclosure 2, to CAN/CSA-C22.2 No.4 size as indicated.
- .2 Provision for padlocking in on-off switch position by 3 locks.
- .3 Mechanically interlocked door to prevent opening when handle in ON position.
- .4 Fuses: size as indicated, in accordance with Section 26 28 13.01 - Fuses - Low Voltage.
- .5 Fuseholders: to CSA C22.2 No.39relocatable and suitable without adaptors, for type and size of fuse indicated.
- .6 Quick-make, quick-break action.
- .7 ON-OFF switch position indication on switch enclosure cover.

2.2 EQUIPMENT  
IDENTIFICATION

- .1 Provide equipment identification in accordance with Section 26 05 00 - Common Work Results for Electrical.
- .2 Indicate name of load controlled on size 4 nameplate.

PART 3 - EXECUTION

3.1 INSTALLATION

- .1 Install disconnect switches complete with fuses if applicable.

END OF SECTION

---

PART 1 - GENERAL

- 1.1 ACTION AND INFORMATIONAL SUBMITTALS
- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
  - .2 Product Data:
    - .1 Provide manufacturer's printed product literature, specifications and datasheet and include product characteristics, performance criteria, physical size, finish and limitations.
    - .3 Shop Drawings:
      - .1 Provide shop drawings for each type of starter to indicate:
        - .1 Mounting method and dimensions.
        - .2 Starter size and type.
        - .3 Layout and components.
        - .4 Enclosure types.
        - .5 Wiring diagram.
        - .6 Interconnection diagrams.
- 1.2 CLOSEOUT SUBMITTALS
- .1 Provide maintenance materials in accordance with Section 01 78 00 - Closeout Submittals.
  - .2 Submit operation and maintenance data for each type and style of motorstarter for incorporation into maintenance manual.

PART 2 - PRODUCTS

- 2.1 MANUAL MOTOR STARTERS
- .1 Single or Three phase manual motor starters of size, type, rating, and enclosure type as indicated, with components as follows:
    - .1 Switching mechanism, quick make and break.
    - .2 Overload heaters, manual reset, trip indicating handle.
  - .2 Accessories:
    - .1 Toggle switch: heavy duty oil tight labelled as indicated.
    - .2 Indicating light: heavy duty oil tight type and colour as indicated.
    - .3 Locking tab to permit padlocking in "ON" or "OFF" position.

---

## 2.2 FULL VOLTAGE MAGNETIC STARTERS

- .1 Magnetic and combination magnetic starters of size, type, rating and enclosure type as indicated with components as follows:
  - .1 Contactor solenoid operated, rapid action type.
  - .2 Motor overload protective device in each phase, manually reset from outside enclosure.
  - .3 Wiring and schematic diagram inside starter enclosure in visible location.
  - .4 Identify each wire and terminal for external connections, within starter, with permanent number marking identical to diagram.
- .2 Combination type starters to include fused disconnect switch with operating lever on outside of enclosure to control disconnect, and provision for:
  - .1 Locking in "OFF" position with up to 3 padlocks.
  - .2 Independent locking of enclosure door.
  - .3 Provision for preventing switching to "ON" position while enclosure door open.
- .3 Accessories:
  - .1 Selector switches: heavy duty oil tight labelled as indicated.
  - .2 Indicating lights: heavy duty oil tight type and color as indicated.
  - .3 1-N/O and 1-N/C spare auxiliary contacts unless otherwise indicated.

---

## 2.3 CONTROL TRANSFORMER

- .1 Single phase, dry type, control transformer with primary voltage as indicated and 120 V secondary, complete with secondary fuse, installed in with starter as indicated.
- .2 Size control transformer for control circuit load plus 20% spare capacity.

---

## 2.4 ACCESSORIES

- .1 Pushbutton: heavy duty, oil tight as required.
- .2 Selector switches: heavy duty, oil tight as required.
- .3 Indicating lights: heavy duty, oil tight, type and colour as indicated.

---

## 2.5 FINISHES

- .1 Apply finishes to enclosure in accordance with Section 26 05 00 - Common Work Results for Electrical.

---

2.6 EQUIPMENT  
IDENTIFICATION

- .1 Provide equipment identification in accordance with Section 26 05 00 - Common Work Results for Electrical.
- .2 Manual starter designation label, white plate, black letters, size 1, engraved as indicated.
- .3 Magnetic starter designation label, white plate, black letters, size 1 engraved as indicated.

PART 3 - EXECUTION3.1 INSTALLATION

- .1 Install starters and control devices in accordance with manufacturer's instructions.
- .2 Install and wire starters and controls as indicated.
- .3 Ensure correct fuses installed.
- .4 Confirm motor nameplate and adjust overload device to suit.

3.2 FIELD QUALITY  
CONTROL

- .1 Perform tests in accordance with Section 26 05 00 - Common Work Results for Electrical and manufacturer's instructions.
- .2 Operate switches and contactors to verify correct functioning.
- .3 Perform starting and stopping sequences of contactors and relays.
- .4 Check that sequence controls, interlocking with other separate related starters, equipment, control devices, operate as indicated.

END OF SECTION

---

PART 1 - GENERAL1.1 REFERENCES

- .1 American National Standards Institute (ANSI)
  - .1 ANSI C82.1-04, Lamp Ballasts-Line Frequency Fluorescent Lamp Ballast.
  - .2 ANSI C82.4-02(R2007), Ballasts for High-Intensity-Discharge and Low-Pressure Sodium Lamps Multi Supply Type.
- .2 American National Standards Institute/Institute of Electrical and Electronics Engineers ( ANSI/IEEE )
  - .1 ANSI/IEEE C62.41-1991, Recommended Practice for Surge Voltages in Low-Voltage AC Power Circuits.
- .3 Light Emitting Diode (LED) fixtures: to CSA C22.2 No. 250.13.

1.2 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
  - .1 Provide manufacturer's printed product literature, specifications and datasheet and include product characteristics, performance criteria, physical size, finish and limitations.
  - .2 Provide complete photometric data prepared by independent testing laboratory for luminaires where specified, for review by Departmental Representative.
  - .3 Photometric data to include: VCP Table where applicable and spacing criterion.
- .3 Quality assurance submittals: provide the following:
  - .1 Manufacturer's instructions: provide manufacturer's written installation instructions and special handling criteria, installation sequence, and cleaning procedures.

1.3 DELIVERY, STORAGE AND HANDLING

- .1 Disposal and recycling of fluorescent lamps as per local regulations.
- .2 Disposal of old PCB filled ballasts.

---

PART 2 - PRODUCTS2.1 LAMPS

- .1 Fluorescent lamps to be - T8, 32 Watt, medium bi-pin, rapid-start, 4100 K, 36,000 hour lamp life, 2950 initial lumens, CRI 85; or as indicated.
- .2 Compact fluorescent lamps to be - 12,000 hour lamp life, 4100 K, CRI 85; or as indicated. Colour temperature to match T8 lamps.
- .3 LED lamps shall provide the minimum delivered lumens indicated on light fixture schedule and shall maintain 70% of initial lumens after 50,000 hours of operation. Colour rendering index and colour temperature to match T8 lamps unless otherwise noted.

2.2 BALLASTS

- .1 Fluorescent ballast: CBM and CSA certified, programmed rapid start, energy efficient type, IC electronic.
  - .1 Rating: 60 Hz voltage as indicated, for use with 2-32W, rapid start lamps or other wattages as indicated.
  - .2 Totally encased and designed for 40 degrees Celsius ambient temperature.
  - .3 Power factor: minimum 95 % with 95% of rated lamp lumens.
  - .4 Current crest factor: 1.7 maximum.
  - .5 Harmonics: 12% maximum THD.
  - .6 Operating frequency of electronic ballast: 20 kHz minimum.
  - .7 Total circuit power: 58 Watts.
  - .8 Ballast factor: 0.87.
  - .9 Sound rated: Class A.
  - .10 Mounting: integral with luminaire.

2.3 LED DRIVERS

- .1 Each LED fixture to be complete with integral, modular, replaceable drivers.
  - .1 Minimum efficiency: 85%
  - .2 Maximum THD: 20%
  - .3 Discrete driver, heat sink, circuit board and housing components.

2.4 FINISHES

- .1 Light fixture finish and construction to meet ULC listings and CSA certifications related to intended installation.

---

2.5 OPTICAL CONTROL DEVICES

- .1 As indicated in luminaire schedule.

---

2.6 LUMINAIRES

- .1 As indicated in luminaire schedule.
- .2 Fixtures and lamps shall be Energy Star approved and on the Design Lights Consortium List.

---

PART 3 - EXECUTION

---

3.1 INSTALLATION

- .1 Locate and install luminaires as indicated.
- .2 Provide adequate support to suit ceiling system.

---

3.2 WIRING

- .1 Connect luminaires to lighting circuits:  
.1 Install flexible or rigid conduit for luminaires as indicated.

---

3.3 LUMINAIRE SUPPORTS

- .1 For suspended ceiling installations support luminaires independently of ceiling.

---

3.4 LUMINAIRE ALIGNMENT

- .1 Align luminaires mounted in continuous rows to form straight uninterrupted line.
- .2 Align luminaires mounted individually parallel or perpendicular to building grid lines.

END OF SECTION

---

PART 1 - GENERAL

- 1.1 REFERENCES .1 Canadian Standards Association (CSA International)  
.1 CSA C22.2 No.141-10, Unit Equipment for  
Emergency Lighting.  
.2 CSA C860-11, Performance of Internally-Lighted  
Exit Signs.
- 1.2 ACTION AND  
INFORMATIONAL  
SUBMITTALS .1 Provide submittals in accordance with Section 01 33 00  
- Submittal Procedures.  
.2 Product Data:  
.1 Submit manufacturer's printed product  
literature, specifications and datasheet and include  
product characteristics, performance criteria,  
physical size, finish and limitations.

PART 2 - PRODUCTS

- 2.1 STANDARD UNITS .1 Housing: cold rolled steel minimum 1.0 mm thick, white  
finish, suitable for wall, end, or ceiling mount.  
.2 Faceplates: clear poly-carbonate.  
.3 Lamps: white LED, universal 2-wire AC input voltage  
of 120 to 347V at less than 2.5 Watts for single and  
double face signs.  
.4 Operation: designed for 50,000 hours of continuous  
operation without relamping.  
.5 Pictogram: green Running Man type with directional  
arrow indicators as shown on plans.

PART 3 - EXECUTION

- 3.1 MANUFACTURER'S  
INSTRUCTIONS .1 Compliance: comply with manufacturer's written  
recommendations or specifications, including product  
technical bulletins, handling, storage and  
installation instructions, and datasheets.

3.2 INSTALLATION

- .1 Install exit lights to manufacturer's recommendations, listing requirements, NFPA standard and local regulatory requirements.
- .2 Connect fixtures to exit light circuits.
- .3 Connect emergency lamp sockets to emergency circuits.
- .4 Ensure that exit light circuit breaker is locked in on position.

END OF SECTION