



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT

MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada -
Pacific Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet North Apron Remediation	
Solicitation No. - N° de l'invitation EZ897-171552/A	Amendment No. - N° modif. 005
Client Reference No. - N° de référence du client	Date 2016-10-27
GETS Reference No. - N° de référence de SEAG PW-\$PWY-031-7882	
File No. - N° de dossier PWY-6-39177 (031)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2016-11-02	Time Zone Fuseau horaire Pacific Daylight Saving Time PDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Leung, Janie	Buyer Id - Id de l'acheteur pwy031
Telephone No. - N° de téléphone (604) 666-8228 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: TC - Whitehorse Airport - Whitehorse, YT	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
EZ897-171552/A
Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.
005
File No. - N° du dossier
PWY-6-39177

Buyer ID - Id de l'acheteur
PWY031
CCC No./N° CCC - FMS No./N°VME

This Solicitation Amendment 005 is raised to address questions and to incorporate the revised drawings.

Questions and Answers

Q1. If we are screening a glacial gravel deposit, where no newly exposed aggregate surfaces exist, do we still require ARD/ML testing for this material?

A1. The Specifications do not require screened gravel to be tested.

As per 026100.02-2.1.3.3, only cobble-sized or larger (>64mm) material needs to be tested for ARD. The intent is if the import material was substantially cobble sized or larger (eg to be used for rip rap) then ARD testing would be required. If the material is substantially smaller than cobble sized then ARD testing is not required.

Q2. The latest Q&A A7 (under Amendment 4) states that the propane tank is to remain. The drawings released today (drawing 6) still state the propane tank is to be remove. Please clarify.

A2. The propane tank is NOT to be removed. Please see revised drawings.

All other terms and conditions remain unchanged.