



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 405
Saint John
New Brunswick
E2L 2B9

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

All enquiries are to be submitted in writing to the Contracting Officer, Janine Donovan: Email - janine.donovan@pwgsc.gc.ca or Fax No. (506) 636-4376.

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 405
Saint John
New Bruns
E2L 2B9

Title - Sujet Exterior Wall Cladding - NDB, NB	
Solicitation No. - N° de l'invitation EC015-171535/A	Amendment No. - N° modif. 003
Client Reference No. - N° de référence du client R.051357.001	Date 2016-10-27
GETS Reference No. - N° de référence de SEAG PW-\$PWB-020-3969	
File No. - N° de dossier PWB-6-39100 (020)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2016-11-16	Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Donovan, Janine PWB	Buyer Id - Id de l'acheteur pwb020
Telephone No. - N° de téléphone (506) 636-5347 ()	FAX No. - N° de FAX (506) 636-4376
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

This Solicitation Amendment No. Three (3) is raised to include the following addendum no. 2.

The following addendum to the tender documents is effective immediately. This addendum shall form part of the contract documents.

All other terms and conditions remain the same.

Addendum 3.

This addendum consists of:

15 drawings: S2, S3, S4, S5, S6, S10, S11, S12, S21, S24, S25, S26, S27 and S28 (re-issued) and new structural drawing S31.

1. **QUESTIONS AND CLARIFICATIONS**

1. We noted on the plans that there is some roofing work but I haven't found the specs for it. It's where we demolish the walls at the low roof intersection. The roofing work must be done by a licensed contractor with a warranty. Can this be clarified in an addendum?

Answer: A specification section for roofing work will be issued by a separate addendum.

2. **SPECIFICATIONS**

1. **SECTION 00 00 10 – SPECIFICATIONS AND DRAWING LIST**

- .1 Add to list of Architectural Drawings, new drawing A3.11 – Demolition: Shelf Angle Assemblies.
- .2 Add to list of Structural Drawings, new drawing S31 – New Steel Framing Details – 8.

2. **SECTION 08 51 13 – ALUMINUM WINDOWS**

- .1 Paragraph 2.3 – COMPONENTS, Clause .1, Mullion Profile, Sentence .1:
Revise sentence to read as follows:
“.1 Vertical members 63.5 x 178 mm nominal dimension”.
- .2 Paragraph 2.3 – COMPONENTS, Clause .1, Mullion Profile, Sentence .2:
Revise sentence to read as follows:
“.2 Horizontal members 63.5 x 178 mm nominal dimension”.

3. **DRAWINGS**

COVER SHEET

.1 **DRAWING LIST:**

- Add to list of Architectural Drawings, new drawing A3.11 – Demolition: Shelf Angle Assemblies.
- Add to list of Structural Drawings, new drawing S31 – New Steel Framing Details – 8.

STRUCTURAL DRAWINGS:

.1 **Drawing S2 (Reissued)**

- See “clouded” items indicated on drawing.

.2 Drawing S3 (Reissued)

- See “clouded” items indicated on drawing.

.3 Drawing S4 (Reissued)

- See “clouded” items indicated on drawing.

.4 Drawing S5 (Reissued)

- See “clouded” items indicated on drawing.

.5 Drawing S6 (Reissued)

- See “clouded” items indicated on plan.
- Details 28G and 28H (revised per “clouded” items) relocated from drawing S28.

.6 Drawing S7

- PARTIAL NORTH ELEVATION 7C
 - Existing column at F-7 starts at Penthouse Floor (it does not continue down below to next lower level.
- PARTIAL SOUTH ELEVATION 7D
 - Existing column at E-7 starts at Penthouse Floor (it does not continue down below to next lower level.
- SOUTH ELEVATION 7B
 - “LOADING DOCK” indicated between grids 2 & 3 at main floor level.

.7 Drawing S8

- ELEVATION 8G
 - Existing south canopy steel indicated.

.8 Drawing S9

- ELEVATION 9A
 - Existing north canopy steel indicated.

.9 Drawing S10 (Reissued)

- Corner framing steel and window opening framing steel clarified.
- See “clouded” items indicated on Elevations.

.10 Drawing S11 (Reissued)

- Corner framing steel and window opening framing steel clarified.
- See “clouded” items indicated on Elevations.

.11 Drawing S12 (Reissued)

- Corner framing steel and window opening framing steel clarified.
- See “clouded” items indicated on Elevations.

.12 Drawing S16

- Added note 2. “2. Verify orientation and location of WT’s with details shown on drawing S28 and S31.”
- Added note 3. “3. See plans for continuation or termination of new steel framing at corners and window openings.”

Drawing S16 (continued)

- ELEVATION 16A
 - At WT from each grid line, "SEE NOTE 2." Indicated.
- ELEVATION 16B
 - At WT from each grid line, "SEE NOTE 2." Indicated.

.13 Drawing S17

- Added note 2. "2. Verify orientation and location of WT's with details shown on drawing S28 and S31."
- Added note 3. "3. See plans for continuation or termination of new steel framing at corners and window openings."

- ELEVATION 17A
 - At WT from each grid line, "SEE NOTE 2." Indicated.
- ELEVATION 17B
 - At WT from each grid line, "SEE NOTE 2." Indicated.

.14 Drawing S18

- Added note 2. "2. Verify orientation and location of WT's with details shown on drawing S28 and S31."
- Added note 3. "3. See plans for continuation or termination of new steel framing at corners and window openings."

- ELEVATION 18A
 - At WT from each grid line, "SEE NOTE 2." Indicated.
- ELEVATION 18B
 - At WT from each grid line, "SEE NOTE 2." Indicated.
- ELEVATION 18C
 - At WT from each grid line, "SEE NOTE 2." Indicated.
- ELEVATION 18D
 - At WT from each grid line, "SEE NOTE 2." Indicated.

.15 Drawing S19

- Added note 2. "2. Verify orientation and location of WT's with details shown on drawing S28 and S31."
- Added note 3. "3. See plans for continuation or termination of new steel framing at corners and window openings."

- ELEVATION 19A
 - At WT from each grid line, "SEE NOTE 2." Indicated.

.16 Drawing S20

- Added note 2. "2. Verify orientation and location of WT's with details shown on drawing S28 and S31."

- Added note 3. "3. See plans for continuation or termination of new steel framing at corners and window openings."

Drawing S20 (continued)

- ELEVATION 20A
 - At WT from each grid line, "SEE NOTE 2." Indicated.
- ELEVATION 20B
 - At WT from each grid line, "SEE NOTE 2." Indicated.

.17 Drawing S21 (Reissued)

- See "clouded" items indicated on drawing.

.18 Drawing S22

- Added note 2. "2. Verify orientation and location of WT's with details shown on drawing S28 and S31."
- Added note 3. "3. See plans for continuation or termination of new steel framing at corners and window openings."
- ELEVATION 22B
 - At WT from each grid line, "SEE NOTE 2." Indicated.

.19 Drawing S23

- Added note 2. "2. Verify orientation and location of WT's with details shown on drawing S28 and S31."
- Added note 3. "3. See plans for continuation or termination of new steel framing at corners and window openings."
- ELEVATION 23A
 - At WT from each grid line, "SEE NOTE 2." Indicated.
- ELEVATION 23B
 - At WT from each grid line, "SEE NOTE 2." Indicated.

.20 Drawing S24 (Reissued)

- See "clouded" items indicated on drawing.

.21 Drawing S25 (Reissued)

- See "clouded" items indicated on drawing.

.22 Drawing S26 (Reissued)

- See "clouded" items indicated on drawing.

.23 Drawing S27 (Reissued)

- See "clouded" items indicated on drawing.

.24 Drawing S28 (Reissued)

- See "clouded" items indicated on drawing.
- Details 28G and 28H moved to drawing S6.
- Details 28J, 28K, 28L, 28N, 28P and 28Q moved to new drawing S31.

- New Detail 28R added to drawing.

.25 **Drawing S29**

- ELEVATION 29A
 - Added "+ Bent PL6 continuous deck support" to new HSS102x102's at T/S 9.953 (at 2-Locations).
- ROOF PLAN 29B
 - Added "+ Bent PL6 continuous deck support" to new HSS102x102's 445 mm south of grid A (at 2-Locations).

.26 **Drawing S30**

- SECTION 30A
 - Added "+ Bent PL6 continuous deck support" to new HSS102x102 at T/S 9.953.
- DETAIL 30B
 - Revise "New VSC each side of new col c/w 2-12.7 mm Ø bolts (finger tightened) to "New VSC each side of new col c/w 2-**19 mm Ø A325** bolts (finger tightened)".

.27 **Drawing S31 (New drawing issued)**