



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

**Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada**
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada -
Pacific Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Float Replacement	
Solicitation No. - N° de l'invitation F1700-165102/A	Amendment No. - N° modif. 007
Client Reference No. - N° de référence du client F1700-165102	Date 2016-10-28
GETS Reference No. - N° de référence de SEAG PW-\$PWY-019-7881	
File No. - N° de dossier PWY-6-39157 (019)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2016-11-07	Time Zone Fuseau horaire Pacific Daylight Saving Time PDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Ngan, Ken (PWY)	Buyer Id - Id de l'acheteur pwy019
Telephone No. - N° de téléphone (604) 658-2755 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: DFO - Institute of Ocean Sciences - Sidney, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
F1700-165102/A
Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.
007
File No. - N° du dossier
pwy-6-39157

Buyer ID - Id de l'acheteur
pwy019
CCC No./N° CCC - FMS No/ N° VME

This Solicitation Amendment 007 is raised to extend the bid closing date, and to incorporate a response to a question received.

All other terms and conditions remain unchanged.

Extension of Time

**Float Replacement
– Institute of Ocean Sciences, Sidney, BC**

Solicitation No: F1700-165102/A

Notice is hereby given that the time for reception of tenders previously due at
2:00 p.m. P.D.T. on November 3, 2016 is hereby extended to
2:00 p.m. P.S.T. on November 7, 2016.

NOTE TO BIDDERS: Use the mailing label below and affix it securely to the outside of the envelope or package containing your bid. For revisions to bids submitted by facsimile (fax # (604) 775-9381), use this sheet as the cover sheet. Always ensure your company name, return address, tender number and closing date appear legibly on the outside of your bid submission.

**REAL PROPERTY CONTRACTING
Public Works & Government Services Canada
Room 219 - 800 Burrard Street
Vancouver, B.C. V6Z 0B9**

Requisition No.: F1700-165102/A
Tender Closing Date & Time: November 7th, 2016 @ 1400 P.S.T.
Project Description: Float Replacement
– Institute of Ocean Sciences, Sidney, BC

KN

Q65: Further to our earlier questions and the subsequent addendum, the scope for painting and galvanizing is still not clear. I see that some pile wells note that they are galvanized, while others don't have that note which would indicate they are painted. This seems like it may be an oversight. Can you clarify?

A65: All pile wells are galvanized including the pile guides on Float B1. This note should have been included on Drawing No. 9R306-2-206_Rev0.

End of Solicitation Amendment 007.