



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada -
Pacific Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet HVAC Rehabilitation	
Solicitation No. - N° de l'invitation EZ899-171613/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client	Date 2016-11-02
GETS Reference No. - N° de référence de SEAG PW-\$PWY-033-7886	
File No. - N° de dossier PWY-6-39173 (033)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2016-11-08	Time Zone Fuseau horaire Pacific Standard Time PST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Siopongco, Philip PWY	Buyer Id - Id de l'acheteur pwy033
Telephone No. - N° de téléphone (604) 351-6139 ()	FAX No. - N° de FAX () -
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: TC - Combined Services Building - Sandspit Airport - Sandspit, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
EZ897-171613/A
Client Ref. No. - N° de réf. du client
EZ897-171613

Amd. No. - N° de la modif.
Amendment 002
File No. - N° du dossier
PWY-6-39173

Buyer ID - Id de l'acheteur
PWY033
CCC No./N° CCC - FMS No./N°VME

This solicitation amendment 002 is raised to incorporate Addendum 1, and to confirm the bid closing date.

Extension of Time

**HVAC Rehabilitation
Sandspit Airport,
Sandpit, British Columbia**

Solicitation No: EZ899-171613/A

Notice is hereby given that the time for reception of tenders originally due at
2:00 p.m. on October 31, 2016, local time is hereby extended to
2:00 p.m. on November 8, 2016, local time.

For clarifications, see attached Addendum 1

All other terms and conditions remain the same.

**Sandspit Airport CSB
MECHANICAL ADDENDUM NO. M1**

**FILE: 1525.00
31 October 2016**

To: Transport Canada

Cc:

- ☐ Design Meeting Minutes
- ☐ Design Correspondence
- ☒ Addenda
- ☐ Approvals
- ☐ Shop Drawings
- ☐ Change Notices
- ☐ Change Orders
- ☐ Change Directives
- ☐ Supplemental Instructions
- ☐ Construction Meeting Minutes
- ☐ Construction Correspondence
- ☐ Progress Claims
- ☐ Construction Review Reports
- ☐ Temporary

From: Skai Edwards, EIT
Greg Pinder, P.Eng, P.E.

THIS ADDENDUM FORMS PART OF THE CONTRACT DOCUMENTS AND IS TO BE READ, INTERPRETED AND COORDINATED WITH ALL OTHER PARTS. INCLUDE COST OF ALL WORK CONTAINED HEREIN IN THE CONTRACT PRICE. THE FOLLOWING REVISIONS SUPERSEDE INFORMATION CONTAINED IN THE ORIGINAL DRAWINGS AND SPECIFICATIONS ISSUED OF THE ABOVE NAMED PROJECT TO THE EXTENT REFERENCED AND BECOME PART THEREOF. PLEASE ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE FORM OF TENDER.

1. Specification section 01 11 55.
 - a. Add clause 1.21.1.2 to read as follows: "A reroofing project is currently underway at this facility. The mechanical contractor shall allow coordination with the roofing contractor for all existing and new mechanical roof penetrations and related work."
 - b. Add clause 1.24.9 to read as follows: "Contractor is to review the existing HazMAT report (provided in appendix B of this specification). If additional testing/sampling/abatement is required, the contractor is to cover the associated costs. The contractor is to provide a written certified "clearance letter" to the departmental representative upon completion of asbestos abatement work."
2. Specification section 01 14 00.
 - a. Remove clause 1.1. Insert new clause 1.1 to read as follows: "No work on the site can begin until contract award date. The contractor will have access to the Combined Services Building in unrestricted areas on normal work days during normal work hours (8 hours per day). Typical work hours are 800-1600. Before or after these hours, the contractors shall have no site access permissions."
 - b. Remove clause 1.5.2.
3. Specification Section 01 32 19.
 - a. Remove clause 1.3.3.
 - b. Remove clause 1.7.1. Insert new clause to read as follows: "Ensure that access to restricted areas is in the presence of the Departmental Representative."
4. Specification section 01 91 00.
 - a. Add clause 1.7.5 to read as follows: "The contractor is to submit a written commissioning report, including the energy savings of the new mechanical HVAC work and greenhouse gas emission reduction."

End of Mechanical Addendum M1