



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT

MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada -
Pacific Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

| | |
|---|--|
| Title - Sujet Float Replacement | |
| Solicitation No. - N° de l'invitation F1700-165102/A | Amendment No. - N° modif. 011 |
| Client Reference No. - N° de référence du client F1700-165102 | Date 2016-11-04 |
| GETS Reference No. - N° de référence de SEAG PW-\$PWY-019-7881 | |
| File No. - N° de dossier PWY-6-39157 (019) | CCC No./N° CCC - FMS No./N° VME |
| Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2016-11-07 | |
| Time Zone Fuseau horaire Pacific Daylight Saving Time PDT | |
| F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/> | |
| Address Enquiries to: - Adresser toutes questions à: Ngan, Ken (PWY) | Buyer Id - Id de l'acheteur pwy019 |
| Telephone No. - N° de téléphone (604) 658-2755 () | FAX No. - N° de FAX (604) 775-6633 |
| Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: DFO - Institute of Ocean Sciences - Sidney, BC | |

Instructions: See Herein

Instructions: Voir aux présentes

| | |
|--|--|
| Delivery Required - Livraison exigée | Delivery Offered - Livraison proposée |
| Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur | |
| Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur | |
| Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie) | |
| Signature | Date |

This Solicitation Amendment 011 is raised to provide further clarifications on responses posted in previous Solicitation Amendments.

Q75: There are not Anti Siphon valves shown in the contract bubbles on any of the drawings or in the spec provided. Can you please provide the location, size and spec for the Anti Siphon Valves?

A75: The unit price table calls it "Anti Siphon Value" but the drawing shows it as "Reduced Pressure Backflow Prevention (RPBP) Valves. The locations where the Anti Siphon Value/ RPBP are as follow:

- Drawing C-004: Just at the entrance/platform for gangway platform for access to Float D
- Drawing C-006: At Float B. See Detail A of Drawing C006
- Drawing C-006: Just at the entrance/platform for gangway for access to Float C

Q66: Can you please provide a breakdown clarifying each line for the mechanical tender form? For example: The pipe is specified HDPE in the documents and the tender form calls for PVC. In the tender form it states "flexible hose all floats - 150 m". That is a huge quantity compared to what is shown on the drawings especially when drawing C-002 detail 3 states "remove flexible hose c/w salvage and protect hose for re-use". Can you please provide clarification?

A66: The reason why the quantity is shown as 150m is that flexible hose is required at each ramp as shown on Drawing C-007 Detail 2. Allow for adequate slack for each section of the flexible hose for the gangway's travel from low to the high tide. Contractors are to provide a bid based on the 150m length.

Q71: A71 refers us to the drawing C004 Rev 4 for the water provision work to fix wharf. I can't find on drawing C004 where there can be 40 meters of 150 mm of pipe to be installed. Can you please clarify? Is the quantity correct?

A71: Contractors are to provide a bid based on the 40m length as this amount will allow for the final locations and paths of both pipes to be determined on site. The quantities may vary in the field as Contractor needs to field locate the exact location of the recessed hydrant.

Q69: A69 states that "The contractor shall estimate the required time for their sub-trade to perform the work within the building areas and allow for Commissionaire escort service to cover that period." As states in question 79 the Commissionaires will not give us pricing. Can you please state how this is to be dealt with in the tender? Is there a separate line item that should be included in the tender for hours? What happens if you go over the hours provided in the tender? Is working inside the wharf to be supervised by the Commissionaires?

A69: The Commissionaires' not giving you a pricing is not considered circumstances beyond contractor's control. See answer to Question 73 for where to include the costs for the commissionaire. It is up to Contractors to figure out how many hours of Commissionaire services are required. Working inside any building or substations requires Commissionaire services. Working inside the service corridor on the wharf does not require the commissionaire services.

The answers below have not be answered:

The addendum #1 Q 17 states to install as per detail 2 on drawing C005, but, on the drawings it is not in the contract bubble. What is to be included as part of the contract?

A17: Drawing C-004 – Rev 4 show two locations for the recessed fire hydrants. The notes on this then refers to Drawing C-005 for further detail 2 of Drawing C-005. Thus, Detail 2 of Drawing C-005 is to be included in the work as well.

All other terms and conditions remain unchanged.