

- 10605
- NOTES:
- DISCONNECT AND RELOCATE EXISTING LUMINAIRES AS REQUIRED TO ACCOMMODATE NEW LOCKER ROOM 236.
 - PROVIDE NEW REMOTE EMERGENCY LIGHT CONNECTED TO EXISTING BATTERY BANK.
 - DISCONNECT AND REMOVE EXISTING LUMINAIRE FROM CHAIN HUNG ROW AND MAKE GOOD LAST RETAINED LUMINAIRE.
 - PROVIDE NEW LUMINAIRE CONNECTED TO EXISTING CIRCUIT COMPLETE WITH VACANCY SENSOR TO TURN LUMINAIRE OFF ON NO VACANCY.
 - PROVIDE VOLTAGE SENSING RELAY CONNECTED TO BATTERY UNIT P5 SO UPON POWER OUTAGE P5 IS ENERGIZED.



APEM
Certificate of Authorization
MCW/AGE Consulting Professional Engineers
No. 589 Expiry: April 30, 2017

DO NOT SCALE DRAWINGS

Revision/Revisión	Description/Description	Date/Date
0	ISSUED FOR CONSTRUCTION	2016/11/02

Client/client
PUBLIC WORKS AND GOVERNMENT SERVICES AGENCY


Project title/Titre du projet
EMERSON, MANITOBA HIGHWAY 75, UNITED STATES BORDER
EXPANSION AND REDEVELOPMENT OF THE EMERSON PORT OF ENTRY

Approved by/Approuvé par
KEI
Designed by/Concept par
GD
Drawn by/Dessiné par
GA
PWGSC Project Manager/Administrateur de Projets TPSCC
JAMES HUTCHINGS
PWGSC Architectural and Engineering Resources Manager/Ressources Architectural et de Directeur d'Ingénierie, TPSCC


Drawing title/Titre du dessin
EXISTING WAREHOUSE & NEW TERTIARY GARAGE ADDITION - LIGHTING LAYOUT

Project No./No. du projet	Sheet/Feuille	Revision no./La Révision no.
R.068431.001	EL2.2	0


OF 26



2 EXISTING WAREHOUSE - LIGHTING LAYOUT
EL2.2 SCALE: 1:100



3 TERTIARY GARAGE BUILDING - LIGHTING LAYOUT
EL2.2 SCALE: 1:100



1 KEY PLAN
EL2.2 SCALE: N.T.S.

REFER TO DRAWING EL2.1

REFER TO DRAWING EL2.1