

NOTES:

1. DISCONNECT & REMOVE EXISTING LUMINAIRE & REPLACE WITH NEW TYPE '2'.
2. DISCONNECT & REMOVE EXISTING LUMINAIRE & OUTLET BOX. REMOVE CONDUIT & WIRING INTO EXISTING WAREHOUSE TO ACCESSIBLE LOCATION & EXTEND TO NEW LOCATIONS.
3. INSTALL LUMINAIRES IN POURED CONCRETE 2'-0" AFF.
4. PROVIDE VERSA LIGHT MODEL #H-3399 LED OR EQUAL DOCK LIGHT.
5. PROVIDE LUMINAIRES WITH DIMMING.
6. PROVIDE BATTERY UNIT WITH 2 HOUR RUN TIME C/W TVSS.
7. PROVIDE REQUIRED LIGHTING CONTACTORS CONNECTED TO VACANCY SENSORS AND LIGHTING CIRCUITS FOR NORMAL & EMERGENCY POWER. LIGHTS SHALL TURN OFF AFTER 5 MINUTE TIME OUT AND TURN ON UPON SENSING MOTION WHEN SWITCH IS IN ON POSITION.
8. INSTALL LUMINAIRES IN ACT. CEILING. COORDINATE AS REQUIRED WITH ARCHITECTURAL.



Certificate of Authorization  
MCW/AGE Consulting  
Professional Engineers  
No. 589 Expiry: April 30, 2017

DO NOT SCALE DRAWINGS

Revision/Revision	Description/Description	Date/Date
0	ISSUED FOR CONSTRUCTION	2016/11/02

Client/client

PUBLIC WORKS  
AND GOVERNMENT  
SERVICES AGENCY

Project title/Titre du projet  
**EMERSON, MANITOBA  
HIGHWAY 75, UNITED STATES BORDER**  
**EXPANSION AND  
REDEVELOPMENT OF THE  
EMERSON PORT OF ENTRY**

Approved by/Approuvé par  
**KEI**

Designed by/Concept par  
**GD**

Drawn by/Dessiné par  
**GA**

PWGSC Project Manager/Administrateur de Projets TPSCG  
**JAMES HUTCHINGS**

PWGSC Architectural and Engineering Resources Manager/  
Ressources Architectural et de Directeur d'ingénierie, TPSCG

Client/client

Drawing title/Titre du dessin  
**WAREHOUSE AREA ADDITION -  
LIGHTING LAYOUT**

Project No./No. du projet  
**R.068431.001**

Sheet/Feuille  
**EL2.1**  
of 26

Revision no./  
La Révision  
no.  
**0**

