Print Report Page 1 of 3



Canada

Report

Tank System Information

Tank System Description

EC #: 00009782 Internal Number

Description: Aklavik, NT - 1250L Gas

Contact Information

Owner

Royal Canadian Mounted Police 73 Leikin Dr M1-4 Mailstop #18 Ottawa Ontario K1A 0R2 Tel: (613) 843-5516

Fax: (613) 825-7518 **Tank Operator**GNWT
Stuart Hodgson Building
Box 1320
Yellowknife
Northwest Territories

Contact

X1A 2L9

Rod Savard 11140-109 Street Edmonton Alberta Tel: (780) 670-8580

Contact

Dennis Pascal Bag Service #1 106 Vetran's Way Inuvik Northwest Territories X0E 0T0

Tel: (867) 777-7152

Land Owner

Months of service

January February March April Print Report Page 2 of 3

May June July August September October November December

System Location

Tank System Location

34 Tornow Avenue Aklavik Northwest Territories X0E 0A0

System Record Location

34 Tornow Avenue Aklavik Northwest Territories X0E 0A0

Emergency Plan Location

34 Tornow Avenue Aklavik Northwest Territories X0E 0A0 Details:

Miscellaneous Information

Tank Use:

Name of Tank Manufacturer:

Year of Manufacture:

Certification # of System Installer:

Certification # of System Remover:

Tank 1 of 1

Tank Information

Tank Description:

Tank Internal Number:

Type of Tank:
Aboveground
ULC or API Standard Number:
ULC-C142.18 (withdrawn and superseded by S601)
Year of installation:
Unknown
Material of construction:
Steel

Print Report Page 3 of 3

Overfill Protection:

• Overfill ball float valve

Type of pump:

No pump

Spill Containment:

Spill box at fill point (aboveground tank)

Product Stored:

Gasoline

Tank Capacity:

1250 L

Transfer area:

Drain Pans and S.O.P.

Tank Leak Detection:

None

Corrosion Protection:

Painted

Secondary Containment:

• Double Walled

Piping for tank 1

Type of Piping:

None