

Amendment #2 raised to provide answers to bidder questions

Q3: This description states CHARPY tested material however neither the material A570 nor A1011 is available as CHARY tested material. To acquire CHARPY tested material then the end user would need steel plate that is CSA G40.21 350WT.

A3: The minimum average impact energy for the requested plate to ASTM A1011/A1011M is waived.