

ATT.10

Question and Answer

Q1. Could you please clarify the height between the roof to the underside of the new gooseneck exhaust on Mechanical 'Gooseneck Installation Detail' drawing 8/M-420

A1. In reference to the height between the roof to the underside of the new gooseneck exhaust on Mechanical 'Gooseneck Installation Detail' drawing 8/M-420, the note 'Height to suit site condition' to be revised to '457mm to 610mm height required above roof to underside of gooseneck exhaust'.

Refer to drawing ATT. 12.