

ATT. 11

Addendum #2

1. Acoustic Tile Ceilings Section 09 51 23

Part 2 – Products

Materials 2.1.2.3.3 New tiles, gypsum backed:

- (the above-noted added spec section that is highlighted in yellow, is attached and noted in the document bolded).
2. In reference to the height between the roof to the underside of the new gooseneck exhaust on Mechanical 'Gooseneck Installation Detail' drawing 8/M-420, the note 'Height to suit site condition' to be revised to '457mm to 610mm height required above roof to underside of gooseneck exhaust'.