



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 405
Saint John
New Brunswick
E2L 2B9
Bid Fax: (506) 636-4376

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

All questions are to be submitted in writing to the Contracting Officer, Gisèle Doucet - Email: gisele.doucet@pwgsc.gc.ca or Fax no. (506) 636-4376.

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 405
Saint John
New Bruns
E2L 2B9

Title - Sujet Campground Svc. (Bldgs.)-Pt. Wolfe	
Solicitation No. - N° de l'invitation EC373-171767/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client R.075852.001	Date 2016-11-24
GETS Reference No. - N° de référence de SEAG PW-\$PWB-004-3994	
File No. - N° de dossier PWB-6-39133 (004)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2016-12-01	
Time Zone Fuseau horaire Atlantic Standard Time AST	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Doucet, Gisele PWB	Buyer Id - Id de l'acheteur pwb004
Telephone No. - N° de téléphone (506) 636-4541 ()	FAX No. - N° de FAX (506) 636-4376
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

This Solicitation Amendment No. two (2) is raised to include the following addendum no. 2.

The following addendum to the tender documents is effective immediately. This addendum shall form part of the contract documents.

All other terms and conditions remain the same.

Addendum No. 2.

1. SPECIFICATIONS

Reference: Specification Section 07 61 00 - Sheet Metal Roofing

- .1 Item 2.1.1, replace 0.60 mm thickness with 0.50 mm

Reference: Specification Section 26 27 26 – Wiring Devices

1. Add new item no. 1.8 "TOGGLE TYPE MOTOR STARTERS" as follows and revise existing items 1.8 and 1.9 to 1.9 and 1.10 respectively.

1.8 TOGGLE TYPE MOTOR STARTERS

- .1 Single-phase manual motor starters of size, type and rating required for the connected load with components and accessories as follows:

- .1 Switching mechanism, quick make, quick break
- .2 All phase conductors to have overload heaters, manual reset, trip indicating handle
- .3 Toggle switch: Heavy duty labelled as indicated
- .4 Indicating light: LED

2. DRAWINGS

Reference: Drawing A10, Detail 6 - Roof Types

- .1 Replace "New Metal Roofing Profile (28ga.)" with "New Metal Roofing Profile (26ga.)"

.Reference Drawing E2 – Electrical Revised Floor Plans

1. Add one (1) light switch at entrance to storage room 101 in laundry Building
2. Add toggle type motor starter symbol to the legend. The symbol is indicated on the plan as a toggle type light switch with a "MSS" annotation.