

APPROXIMATE EDGE OF CONCRETE DECK

EXISTING WHARF

START OF EXISTING PVC CONDUIT SLEEVES

EXISTING 103mm PVC CONDUIT SLEEVES

REMOVAL NOTE 5.

CONCRETE RETAINING WALL/CURB

EXISTING 103mm PVC SLEEVE THROUGH CONCRETE WHEEL GUARD TO ACCOMMODATE TECK CABLES.

EXISTING:

- 3/C #3 TECK CABLE
- 3/C #8 TECK CABLE
- 3/C #10 TECK CABLE

STRAPPED TO FACE OF EXISTING CONCRETE WHEEL GUARD. REMOVAL NOTE 1.

REMOVAL NOTES 3 & 4.

P4

EXISTING TECK CABLES:

- 3/C #3 TO POLES P4 & P5,
- 3/C #8 TO POLE P5,
- 3/C #10 TO POLE P4

EMBEDDED IN CONCRETE DECK.

PARTIAL SITE

SCALE : 1:50

0m 1m 2m 3m 4m 5m

NOTE: ALL DIMENSIONS ARE IN MILLIMETERS.

1
E1

1. REMOVE EXISTING CONCRETE WHEELGUARD AND DECK FROM THIS AREA.
2. ELECTRICAL CONTRACTOR TO HAND EXCAVATE FOR EXISTING CONDUITS AND SHALL REPAIR ANY DAMAGES.
3. ELECTRICAL CONTRACTOR TO IDENTIFY ALL CONDUITS AND FEEDERS.

1. CUT EXISTING TECK CABLES. LEAVE 10 METERS OF EACH CABLE FOR RECONNECTION IN NEW GRADE LEVEL PULL-PIT.
2. COIL AND PROTECT EXISTING COILED CABLES FOR FUTURE USE.
3. COMPLETELY REMOVE REMAINING EXPOSED CABLES.
4. CAREFULLY EXCAVATE CONDUITS AND DIRECT BURIED CABLES IN THE EXCAVATION AREA AT POLE #2 AND VICINITY.
5. INSTALL GRADE LEVEL PULL-PIT. LINE NEW CONDUITS WITH EXISTING CONDUITS.
6. INSTALL DIRECT BURIED RIGID PVC CONDUITS.
7. INSTALL ABOVE GRADE JUNCTION BOX AND SURFACE MOUNTED RGS CONDUIT.
8. SUPPLY AND INSTALL NEW RECEPTACLES AND WIRE.
9. RE-WIRE EXISTING LIGHTS.

1. ALL WORK SHALL BE DONE IN ACCORDANCE WITH THE LATEST EDITION OF THE CANADIAN ELECTRICAL CODE AND/OR LOCAL INSPECTION AUTHORITIES. THE ELECTRICAL CONTRACTOR SHALL OBTAIN ALL PERMITS AND INSPECTIONS REQUIRED BY LAWS, ORDINANCES, RULES AND REGULATIONS OF PUBLIC AUTHORITIES HAVING JURISDICTION OF THIS DISTRICT AND SHALL OBTAIN CERTIFICATES ON SUCH INSPECTIONS AND SUBMIT SAME AND PAY ALL CHARGES IN CONNECTION THEREWITH.
2. ELECTRICAL CONTRACTOR TO COORDINATE ALL WORK WITH THE ARISAIG HARBOUR AUTHORITY PRIOR TO STARTING WORK.
3. CONTRACTOR SHALL VISIT SITE PRIOR TO TENDER TO ASSESS EXISTING CONDITIONS, OBSTRUCTIONS, MATERIALS, ETC.
4. ON COMPLETION, ALL EQUIPMENT SHALL BE THOROUGHLY CLEANED. ALL WORK CHECKED OVER AND LEFT IN WORKING ORDER.
5. ALL RUBBISH, UNUSED MATERIALS ETC., SHALL BE REMOVED AND THE PREMISES LEFT CLEAN.
6. CONTRACTOR SHALL SUPPLY AND INSTALL ALL CONDUIT, JUNCTION BOXES, WIRING/CABLES, ETC. FOR A COMPLETE AND FINISHED JOB AS DETAILED.
7. EQUIPMENT AND MATERIAL TO BE CSA CERTIFIED.
8. ALL EXISTING POLE MOUNTED LIGHT FIXTURES TO REMAIN.

1. EXISTING 3/C #3 TECK CABLE, 3/C #8 TECK CABLE AND 3/C #10 TECK CABLE FROM POLE P2 TO POLE P4 TO BE DISCONNECTED AND REMOVED.
2. LEAVE 10M OF EACH CABLE FOR RECONNECTION TO NEW SYSTEM. COIL AND PROTECT CABLE DURING EXCAVATION FOR NEW WHARF EXTENSION.
3. EXISTING POLES P4 & P5: DISCONNECT AND REMOVE 15 AMP RECEPTACLES, JUNCTION BOXES AND ALL ASSOCIATED TECK CABLES TO RECEPTACLES AND EXISTING FLOODLIGHTS. FLOOD LIGHTS AND POLES TO REMAIN
4. TECK CABLE BETWEEN EXISTING POLES P4 & P5 TO BE ABANDONED. CUT CABLES AT BASE OF POLES. SEAL CUT ENDS. IDENTIFY AND TAG CABLES AS ABANDONED.
5. CUT EXISTING TECK CABLES AT PVC SLEEVES. SEAL CUT ENDS. IDENTIFY AND TAG CABLES AS ABANDONED.

WHARF RECONSTRUCTION

ARISAIG HARBOUR
ANTIGONISH COUNTY, NS

ELECTRICAL - EXISTING
SITE PLAN, PLAN-VIEW
AND SEQUENCE OF
INSTALLATION NOTES

designed G. BOWSER con

date OCTOBER 2016

drawn K. WOLFE dessi

date OCTOBER 2016.

approved _____ approved _____

date 16 Nov 2016 10

Tender	Soumission
--------	------------

PWCSC Project Manager Administrateur de projets TRS

project number	no. du projet
----------------	---------------

R 076164 001

R.070104.001

drawing no. no. du dessin

51

E1