

# Addendum/Addenda

No./N° 1
-------------

Project Description / Description de projet  M-4 PSO Office Renovation		
Solicitation No./ N° de sollicitation  16-22098	Project No./N° de projet  5251	W.O. No./N° d'ordre de travail  A1-009405-01
Departmental Representative / Représentant Ministériel  Allan Smith	Date  November 30, 2016	
<b>Notice:</b>  This addendum shall form part of the tender documents and all conditions shall apply and be read in conjunction with the original plans and specifications.		<b>Nota:</b>  Cet addenda fait partie intégrale des dossiers d'appel d'offres; toutes les conditions énoncées doivent être lues et appliquées en conjonction avec les plans et les devis originaux.

1.1 Refer to Sheet 5251-A04:

- 1.1.1 Clarification: Detail 1/A04 "Partial Floor Plan – Furniture Layout" missing note #9 for 'D' shaped collaboration table. The table is shown as rectangular on plan. The table is to be per specification Section 12 50 00 Article 2.4.
- 1.1.2 Clarification: Within the open printer area there is a requirement for overhead shelves. The symbol below that shelf is a printer/copier that is N.I.C.
- 1.1.3 Revision: Detail 3/A04 "Typical Workstation" The panel width for the run along the major spine of the workstations is to be revised from three panels: 610mm, 1220mm, 610mm to two panels: 1220mm, 1220mm with the overhead cabinet mounted on the first 1220mm panel of the run.
- 1.2 Refer to Specification Section 23 33 01 "Air Distribution" :
  - 1.2.1 Refer to Article 2.4 "Grilles, Registers & Diffusers" item 2.4.4, ADD Metalaire as an Acceptable manufacturer.

End of Addendum 1.

