

NEW PANEL '5W3'									
	LOAD (W)	OCB	C	C	ITEM		LOAD (W)	OCB	
	116W	15A-1P	1	2	TF-2		116W	15A-1P	
	116W	15A-1P	3	4	TF-4		116W	15A-1P	
	116W	15A-1P	5	6	EF-1 & KITCHEN LIGHTING		150W	15A-1P	
	FRAC	15A-1P	7	8	SPARE			15A-1P	
AREA & LAN ROOM)	FRAC	15A-1P	9	10	PRINTER RECEPTACLE			20A-1P	
		20A-1P	11	12	EXAM ROOM RECEPTABLES			20A-1P	
		15A-1P	13	14	EXAM ROOM RECEPTACLE			15A-1P	
		15A-1P	15	16	RECEPTABLES CORRIDOR			15A-1P	
		15A-1P	17	18	INTRUSION ALARM			15A-1P	
ROOM		15A-1P	19	20	WALL MOUNT TV RECEPTACLE			15A-1P	
		15A-1P	21	22	KITCHEN SINK			15A-1P	
		15A-1P	23	24	RECEPTACLE WORKSTATION			15A-1P	
		15A-1P	25	26	RECEPTACLE WORKSTATION			15A-1P	
		15A-1P	27	28	RECEPTACLE WORKSTATION			15A-1P	
		15A-1P	29	30	RECEPTACLE WORKSTATION			15A-1P	
		15A-1P	31	32	SPARE			15A-1P	
		15A-1P	33	34	LIGHTING CORRIDOR			15A-1P	
		15A-1P	35	36	SPARE			15A-1P	
		15A-1P	37	38	SPARE			15A-1P	
		15A-1P	39	40	SPARE			15A-1P	
		15A-1P	41	42	SPARE			15A-1P	
POWER REQUIREMENT WITH MECHANICAL CONTRACTOR BEFORE VOLTAGE DEVICES AND WIRING. SUPPLY AND INSTALL BY E.C.					MOUNT: RATING:				
					- 200A, 120/208V/3ø/4W				

EMERGENCY LIGHTING BATTERY BANK SCHEDULE						
TYPE	MANUFACTURER	CATALOGUE NUMBER	WATTAGE	CIRCUIT NUMBER	LOCATION	LAMPS
EB-1	LUMACELL	6LERLMCEU-2-LD9-120V C/W RED EXIT SIGN	36W	PANEL -CCT#5W3-9	COMMON AREA	2X5W, LED
EB-2	LUMACELL	6LERLMCEU-2-LD9-120V	36W	PANEL -CCT#5W3-9	BOARD ROOM AND LAN ROOM	2X5W, LED
EB-3	LUMACELL	RG12S-100-2-LD9	100W	PANEL -CCT#5W3-15	CORRIDOR	2X5W, LED
EL-1	LUMACELL	MQM-2-LD9 (MR16)	2x5W	-	CORRIDOR	2X5W, LED MR16

NOTES:

- ALL WIRING TO BE IN EMT CONDUIT 21mm CONDUIT C/W MINIMUM #12 AWG Cu WIRING. CONFIRM WIRE SIZES WITH DISTANCES PER MANUFACTURER'S RECOMMENDATIONS.
- ADJUST LIGHTING HEADS TO PROPERLY ILLUMINATE EGRESS ROUTE.
- ALL REMOTE HEADS TO BE MANUFACTURED BY LUMACELL CAT NO. MQM-2-LD7

