



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT

MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada -
Pacific Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet SAR Station Building Construction	
Solicitation No. - N° de l'invitation F1700-165108/A	Amendment No. - N° modif. 004
Client Reference No. - N° de référence du client F1700-165108	Date 2016-12-05
GETS Reference No. - N° de référence de SEAG PW-\$PWY-028-7909	
File No. - N° de dossier PWY-6-39207 (028)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2016-12-13	
Time Zone Fuseau horaire Pacific Standard Time PST	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Lam (PWY), Tian	Buyer Id - Id de l'acheteur pwy028
Telephone No. - N° de téléphone (604) 775-9382 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: DFO - Prince Rupert SAR Station Building Construction - Prince Rupert, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
F1700-165108/A

Amd. No. - N° de la modif.
004

Buyer ID - Id de l'acheteur
PWY028

Client Ref. No. - N° de réf. du client

File No. - N° du dossier
PWY-6-39207

CCC No./N° CCC - FMS No./N°
VME

Amendment 004

Amendment 004 is raised to

- 1) Incorporate Addendum #2
- 2) Extend the bid closing date.

- 1) Please see attached Addendum #2
- 2) Extension of Time

Extension of Time for Tenderers

SAR Building Construction Fairview
Harbour, Prince Rupert, B.C
Solicitation No: F1700-165108/A

Notice is hereby given that the time for reception of tenders previously due at 2:00 p.m. P.S.T. on December 9, 2016 is hereby extended to **2:00 p.m. P.S.T. on December 13, 2016.**

All other terms and conditions remain unchanged.

***The following changes in the Tender Documents are effective IMMEDIATELY.
This addendum will form part of the Contract Documents***

Amend/revise the Standard Contract Documents as follows:

Clarifications & General Information

1. See attached the following revised drawings, instructions and documents referenced in addendum 1, but not posted to the web site with addendum 1:
1/A7.01, 4/A7.01, 5/701, 6/701, 7/A7.02, A-M01, SOW.

Contractor Questions

Question:

On the last page of addendum, page 8, you have a new detail of exterior door threshold , it looks like there is additional skirting that extends down below structural steel I beams? Does this detail go around all three sides?

Response:

Delete additional skirting to all sides. See revised detail **4/A6.03** attached.

Question:

I have just heard from our flooring subcontractors and they say they need a manufacturer or product name for the sheet flooring.

Response:

Any flooring manufacturer and type that meets the specification will be acceptable. The flooring spec is based on Mondo Harmoni or Mondo Natura.

Question:

Can you confirm if the deck that looks out over the wharf wraps around side of building as shown in appendix A or is it just the small deck on harbour side as shown in architectural drawings included on byandsell website?

Response:

Deck is to be provided as shown in Architectural drawings, not as shown in appendix A.

Question:

Can you tell me if the aluminum bases are supplied with rest of building, as notes on structural drawings for aluminum building says to fabricate bases?

Response:

All aluminium components detailed in drawings noted as drawing number 4-30-16-SF, sheets 1 through 11 are provided by owner as part of aluminium building package.

All components detailed on drawings S2.01 and S2.02 are to be provided as part of the contract.

Question:

It just occurred to me that some details show isolation material between dissimilar metals such as Q-dek to aluminum, steel stud to aluminum frame, but not aluminum frame to eps panels.

Response:

The galvalume skin on the EPS panels does not react significantly with the aluminium building frame. This system has been tried and tested in several applications. A concern for galvanic reaction between dissimilar metals is present with the steel deck and steel studs to the aluminium frame. This is due in part to the different volumes of dissimilar metals. So as a precautionary measure we are separating them with foam gaskets or membrane flashings. –see drawings for method at specific locations.

ARCHITECTURAL

Refer to architectural Drawings:

4/A6.03 – see revised attached
Disregard revised 4/A6.03 issued in addendum 1.

ELECTRICAL

1. See attached Electrical Addendum 1 (8 pages)

SPECIFICATION

SECTION 07 41 16 Pre Fabricated Wall and Roof Panels

1.5 .2 Installer Qualifications:

Delete

- .1 ~~Installer shall be authorized by the panel manufacturer and the work shall be supervised by a person having a minimum of five (5) years experience installing insulated metal standing seam roof panels on similar type and size projects.~~

Add

- .1 .1 Work shall be supervised by a person having a minimum of five (5) years experience in construction supervision and the application of good trade practice in constructing pre-fabricated building assemblies.

End of Addendum 2

Solicitation No. - N° de l'invitation
F1700-165108/A

Amd. No. - N° de la modif.
004

Buyer ID - Id de l'acheteur
pwy028

Client Ref. No. - N° de réf. du client

File No. - N° du dossier CCC No./N°

CCC - FMS No./N° VME

NOTE TO TENDERERS: Use the mailing label below and affix it securely to the outside of the envelope or package containing your tender. Always ensure your company name, return address, tender number and closing date appear legibly on the outside of your bid submission.

REAL PROPERTY CONTRACTING
Public Works & Government Services Canada
219- 800 Burrard Street
Vancouver, B.C. V6Z 0B9

Requisition No.: F1700-165108/A
Tender Closing Date & Time: December 13, 2016 @ 2:00pm PST
Project Description: SAR Building Reconstruction
Fairview Harbour, Prince Rupert, B.C.

TL