


GENERAL DEMOLITION NOTES:

- A. THESE NOTES ARE TO BE READ IN CONJUNCTION WITH SPECIFICATION SECTION 26 05 00.
- B. CONTRACTOR MUST VERIFY EXTENT OF WORK AS WELL AS ALL DIMENSIONS AND CONDITIONS ON SITE BEFORE PROCEEDING WITH ANY PORTION OF THIS WORK. DO NOT SCALE FROM DRAWINGS.
- C. DRAWINGS DO NOT NECESSARILY SHOW FULL EXTENT OF DEMOLITION.
- D. REFER TO ARCH., MECH., AND ELECT. DRAWINGS AND SPECIFICATIONS FOR EXTENT OF WORK AND COORDINATE WITH OTHER TRADES PRIOR TO THE COMMENCEMENT OF ANY WORK.
- E. DURING CONSTRUCTION, REMOVE AND CAREFULLY STORE ANY EXISTING FIXTURES, EQUIPMENT, ETC. TO REMAIN OR BE RELOCATED, AND RE-INSTALL AFTER CONSTRUCTION HAS BEEN COMPLETED.
- F. ANY BREAKERS NO LONGER REQUIRED AS A RESULT OF THIS WORK ARE TO BE RE-LABELLED AS 'SPARE'. PROVIDE NEW PANEL SCHEDULES FOR ALL ELECTRICAL PANELS IN THE BUILDING AT COMPLETION OF PROJECT. IF ANY LOADS ARE UNKNOWN AT THE COMPLETION OF THE PROJECT, THE CONTRACTOR SHALL INVESTIGATE AND UPDATE THE PANEL SCHEDULES ACCORDINGLY.
- G. CONTRACTOR TO PROVIDE BLANK COVER PLATES FOR EXISTING JUNCTION BOXES AS REQUIRED.
- H. RE-SUPPORT EXISTING CONDUITS AS REQUIRED.
- I. CONTRACTOR SHALL PROVIDE TEMPORARY SUPPORT FOR ALL EXISTING DEVICES AS REQUIRED DURING CONSTRUCTION. IF DISCONNECTION OF EXISTING DEVICES IS NECESSARY, CONTRACTOR SHALL RE-INSTATE SAME TO THE REQUIREMENTS OF THE SPECIFICATION.

NOTES:

1. ALL EXISTING LIGHTING, LIGHTING CONTROL, POWER, TELECOMMUNICATIONS DEVICES, AND ASSOCIATED WIRING TO BE REMOVED.
2. REMOVE ALL ELECTRICAL EQUIPMENT. CABLES TO BE PULLED BACK TO PANEL.
3. REMOVE AND RE-INSTALL POWER OUTLETS AND EMERGENCY LIGHTS AT APPROPRIATE HEIGHTS BASED ON NEW FLOORING.
4. REMOVE SPEAKERS AND ASSOCIATED WIRING.
5. A/V EQUIPMENT TO BE REMOVED BY PARKS CANADA REPRESENTATIVE.
6. EXISTING LIGHTING SHOWN TO BE RELOCATED TO SUIT NEW LAYOUT. COORDINATE NEW LOCATIONS ON SITE.



DEMOLITION PLAN

SCALE : 1:40

0mm 1mm 2mm 3mm 4mm 5mm

1
E03/E03

THE ASSOCIATION OF
PROFESSIONAL ENGINEERS
OF THE PROVINCE OF
PRINCE EDWARD ISLAND
VALID FOR THE YEAR 2018

Randy O'Connor
No. 1275
DATE: Nov 30/16

LICENSED
PROFESSIONAL ENGINEER
Province of
PRINCE EDWARD ISLAND

2	ISSUED FOR TENDER	11.29 2016
1	100% SUBMISSION	11.23 2016
0	99% SUBMISSION	11.08 2016
revisions		date

project project
GREEN GABLES-PHASE 1
BARN EXPANSION
AND RENOVATION
QUEENS CO., PEI

drawing dessin
ELECTRICAL
DEMOLITION

designed JAS conçu
date OCT-2016
drawn ALW dessiné
date NOV-2016
approved approuvé
date
Tender Soumission
PWGSC Project Manager Administrateur de projets TPWSC
project number no. du projet
R.081199.001
drawing no. no. du dessin
E03 OF 7