

ADDENDUM



Project:	Prince Rupert SAR Station	Addendum No.:	A-M01
Project No.:	131-19106-04	Date:	November 23, 2016
Distribution:	Number 10 Architectural Group - Rob Halliday		

GENERAL

This Addendum forms part of the Contract Documents for the above Project and amends the original drawings and Specifications. The following revisions supersede the information contained in the original drawings and Specifications issued to the extent referenced and shall become part thereof. No adjustment to the Contract Price will be considered or allowed due to the Contractor or to any Sub-Contractor or Supplier not being familiar with this Addendum.

1.0 DRAWINGS

1.1 M0.01 – Heat Pump (Split Type) Schedule

- .1 Revise heat pump electric heating capacity from 7.2kW to 10.2kW.
- .2 Omit the requirement for a double circuited coil.

END OF MECHANICAL ADDENDUM